

DOE 2002 SCR/SNCR Workshop

O&M Cost Reduction of a Coal-Fired US Merchant Plant Through an Optimized SCR Management Strategy Involving Catalyst Regeneration

**Douglas W.
Bullock, P.E.**

**Hans-Ulrich
Hartenstein**



SCR-Tech LLC

PG&E National Energy Group and any other company referenced herein which uses the PG&E name or logo are not the same company as Pacific Gas and Electric Company, the California utility. These companies are not regulated by the California Public Utilities Commission, and customers do not have to buy products from these companies in order to continue to receive quality regulated services from the utility.

The Indiantown Generating Plant



Location: Indiantown, Florida

Owner: ICLP – Indiantown Cogeneration Limited Partnership

Operator: PG&E National Energy Group

Capacity: 360 MW electricity, 270 t process steam


Start-up: 1995

Boiler: Bituminous coal, PC-wall-fired

SCR: 3 layer reactor, initial fill 1 layer, plate-type catalyst, ~ 55% NO_x removal efficiency

Catalyst Addition 1995 – 2000

After start-up on the initial catalyst fill of 2 half-layers in July 1995, additional half-layers of catalyst were installed as soon as the ammonia concentration in the flyash exceeded acceptable levels according to the following schedule:



Catalyst Deactivation Experience

Initial catalyst consumption: 6 half-layers in 7 years (1995 – 2002)

Catalyst suppliers forecast: 1 half-layer per year on the average


European SCR experience: ~15% of catalyst replacement annually

Indiantown Generating Plant's SCR versus European SCRs:


- Comparable coal
- Comparable boiler/burner configuration
- Comparable removal efficiencies
- Comparable unit size
- Indiantown operating experience of 1 half-layer per year on average equals ~16% of catalyst replacement annually

Conclusion: A long-term replacement frequency of 1 half-layer per year on average is expected for the Indiantown Generating Plant.

Catalyst Replacement Cost Estimate




Catalyst Regeneration Cost Estimate



Economic Comparison Regeneration Versus New Catalyst

Comparison of Catalyst Regeneration vs Replacement



PG&E National
Energy Group™

Conclusions of Economic Comparison

Assumptions:

- Regeneration recovers activity of $k_{\text{reg}}/k_0 > 0.9$
- Regenerated catalyst deactivates at the same rate as new catalyst in the same reactor
- A 20 year catalyst exchange program forecast is used
- Cost of regeneration is ~ 52% of new catalyst

Conclusions:

- Accumulated savings over 20 years > 50% of the cost of new catalyst
- Accumulated savings over a period of 20 years > \$ 5 million in catalyst alone
- Avoidance of any potential liability exposure associated with the disposal of spent catalyst as hazardous waste


Catalyst Regeneration Test Program

Catalyst Regeneration Test Program demanded by PG&E NEG:


- Bench-scale testing of deactivated catalyst sample
- Chemical composition analysis of deactivated catalyst sample
- Catalyst regeneration of that sample witnessed by PG&E NEG
- Bench-scale testing of that regenerated catalyst sample
- Chemical composition analysis of regenerated catalyst sample
- Personal contact of PG&E NEG personnel with three power plant operators who have long-term operating experience with regenerated catalyst to verify SCR-Tech's claims first hand

The personal contact, power plant site visits and the Catalyst Regeneration Test Program were completed with the assistance of SCR-Tech in Germany in March 2002.


Catalyst Regeneration Test Program – Chemical Analysis Results



Catalyst Regeneration Test Program – Chemical Analysis Results




Catalyst Regeneration Test Program – Chemical Analysis Results



Catalyst Regeneration Test Program – Activity Test Results

regeneration result of Indiantown catalyst



Activity of new catalyst is based on vendor information and deactivated catalyst. Regenerated catalyst activities were determined by bench-scale reactor testing.

Catalyst Regeneration Test Program – Conclusions

Catalyst Regeneration Test Program demanded by PG&E NEG revealed the following results:

- Catalyst was deactivated as expected ($k/k_0 \sim 0.5$)
- Catalyst poisons can be successfully removed
- Catalyst activity after regeneration was $k_{\text{reg}}/k_0 = 0.99$
- No increase of the SO_2/SO_3 conversion rate above the original conversion rate guarantee for new catalyst

Conclusion: Catalyst regeneration appears technically feasible and economically viable!

Bremen City Utilities (swb-synor)

Hastedt Cogeneration Station Unit 15

- 170 MW PC-fired, dry bottom boiler, start-up in 1989
- Burns mostly world market import coal plus secondary fuel (e.g. pet coke, sewage sludge, bone meal etc.)
- 4-layer SCR reactor, 3 layers in operation, 144 m³ of catalyst
- NO_x removal efficiency ~ 75%, NH₃ slip < 1ppm
- Catalyst regeneration used since 1999, $k_{\text{reg}}/k_0 > 0,94$ on average
- Total amount of catalyst regenerated for all units ~ 700 m³

Conclusions:

- Catalyst is exchanged randomly between the various SCRs with no differentiation between new and regenerated catalyst.
- No difference in deactivation between new and regenerated catalyst; deactivation rate depends on fuel type only.

Power Cooperative Weser (GKW)

Veltheim Power Station Unit 3

- 330 MW cyclone fired, wet bottom boiler with 100% flyash re-injection (very high gaseous As-concentration), start-up in 1970
- Burns mostly world market import coal plus secondary fuel (e.g. sewage sludge, bone meal etc.)
- 5-layer SCR reactor, 4 layers in operation, 640 m³ of catalyst
- NO_x removal efficiency > 85%, NH₃ slip < 3 ppm
- Regenerated catalyst used since 2000, average deactivation rate ~ 10% after > 10,000 operating hours, identical with other catalyst

Conclusions:

- No difference in deactivation between new and regenerated catalyst; deactivation rate only dependent on arsenic content.
- Limestone injection effectively curbs catalyst deactivation.

Hamburg City Utilities (HEW)

Tiefstack Cogeneration Station Units 1 & 2

- 180 MW PC-fired, dry bottom boilers, start-up in 1991/92
- Burns mostly world market import coal, no secondary fuel
- 4-layer SCR reactor, 3 layers in operation, 300 m³ of catalyst
- NO_x removal efficiency ~ 90%, NH₃ slip < 2 ppm
- Regenerated catalyst used since 1998, total amount of catalyst regenerated for all units ~ 500 m³, $k_0/k_{reg} > 1$ on average
- Some catalyst has been regenerated twice already

Conclusions:

- Catalyst is exchanged randomly between the various SCRs with no differentiation between new and regenerated catalyst.
- No difference in deactivation between new, regenerated and re-regenerated catalyst; deactivation rate for all catalyst is 6 – 8% annually at base load.

Site Visits and Experience Verification – Conclusions

The personal visits with three power plant operators with long term operating experience with regenerated catalyst revealed:

- No different deactivation of regenerated versus new catalyst observed during operation
- 2. No need for differentiation between new and/or regenerated catalyst by the operator
- Several regenerations seem possible without degradation in regeneration or catalyst performance

Conclusion: Operating experience with regenerated catalyst was confirmed to be positive throughout!

Future Catalyst Management Strategy

Original catalyst management strategy was based on a 3 full-layer operation with a perpetual exchange of 1 full-layer as needed and disposal of spent catalyst.

New catalyst management strategy is based on 4 half-layers installed with a perpetual exchange of 1 half-layer as needed by a regenerated half-layer kept in stand-by by SCR-Tech.

Advantages:

- **Savings of over \$ 5 million in cumulative SCR maintenance cost over the next 20 years of operation**
- **Savings of > \$ 60,000 in additional annual revenue through reduced parasitic load**
- **Reduced SO₃ load in the system**

4 Half-Layer SCR Operation After 2002

Transition period: May 02 – Replacement of the 2 initial half-layers by 1 new half-layer; regeneration of 1 half-layer of the removed catalyst.



Oct 02 – Removal of all but the new half-layers, regeneration of 2 half-layers; reinstallation of 3 regenerated half-layers.


Future SCR operation:

- Operation of only 4 half-layers at any given time.
- Replacement of 1 half-layer of exhausted catalyst by 1 half-layer of regenerated catalyst, regeneration of the removed half-layer and placement in stand-by.



Catalyst Exchange Plan After 2002

Transition from the former 3 full-layer SCR operating scheme to the new 4 half-layer SCR operating scheme including future catalyst exchange and regeneration cycles:



Conclusions

- Catalyst regeneration was found to be a technically feasible technology and is economically very attractive.
- Long term operating experience was found to be positive, meaning deactivation of regenerated catalyst is identical to new catalyst in the same SCR reactor.
- Maintenance cost savings for ICLP of ~ 50% on average over catalyst replacement (> \$ 5 million over 20 years).
- 4 half-layer operation saves PG&E NEG > \$ 60,000 per year in operating cost over a 3 full-layer operation.
- Cost & potential hazardous waste liabilities associated with catalyst disposal can be largely avoided.

?? Questions ??

Douglas W. Bullock, P.E.
PG&E National Energy Group
Indiantown Generating Plant
P.O. Box 1799
13303 SW Silver Fox Lane
Indiantown, Florida 34956
e-mail: douglas.bullock@neg.pge.com
phone: 561- 597- 6500 Ext. 15
fax: 561-597- 6520

Hans-Ulrich Hartenstein,
SCR-Tech LLC
6015 Glendale Chase Court, Suite 208
Charlotte, N.C. 28217
e-mail: h.hartenstein@envica.com
phone: 704-521-2585
fax: 704-521-2591



**PG&E National
Energy Group™**