

10 CFR 830 Major Modification Determination for ATR Diesel Bus (E-3) and Switchgear Replacement

May 2011



The INL is a U.S. Department of Energy National Laboratory
operated by Battelle Energy Alliance

10 CFR 830 Major Modification Determination for ATR Diesel Bus (E-3) and Switchgear Replacement

May 2011

**Idaho National Laboratory
Idaho Falls, Idaho 83415**

<http://www.inl.gov>

**Prepared for the
U.S. Department of Energy
Office of Nuclear Energy
Under DOE Idaho Operations Office
Contract DE-AC07-05ID14517**

DISCLAIMER

This information was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

Advanced Test Reactor

**10 CFR 830 Major Modification Determination
for
ATR Diesel Bus (E-3) and Switchgear Replacement**

INL/EXT-11-22062
Revision 0

May 2011

Developed by:



N. R. Duckwitz, Safety Analyst

5/19/2011

Date

Approved by:



M. A. Lehto, Manager Facility Safety Engineering

5/23/2011

Date



J. A. Jacobi, Chair Safety Operation Review Committee

5/26/2011

Date



M. D. Love, Director ATR Complex Program *OPERATION*

6/2/2011

Date



P. Henslee, Director ATR Life Extension Project

6/2/2011

Date

CONTENTS

| | | |
|----|--|----|
| 1. | INTRODUCTION | 1 |
| 2. | PROJECT DESCRIPTION | 1 |
| 3. | HAZARDS DISCUSSION..... | 2 |
| 4. | MAJOR MODIFICATION EVALUATION CRITERIA | 3 |
| 5. | CONCLUSION | 11 |
| 6. | REFERENCES | 11 |

TABLES

| | | |
|----------|--|---|
| Table 1. | Major modification evaluation criteria. | 4 |
|----------|--|---|

FIGURES

| | | |
|-----------|---|----|
| Figure 1. | Facility modification process (taken from DOE-STD-1189, Figure 8-1). | 10 |
|-----------|---|----|

DEFINITIONS

Major modification - A modification to a DOE nuclear facility that is completed on or after May 9, 2001 that substantially changes the existing safety basis for the facility. (10 CFR 830)

Nuclear facility - A reactor or a nonreactor nuclear facility where an activity is conducted for or on behalf of DOE and includes any related area, structure, facility, or activity to the extent necessary to ensure proper implementation of the requirements established by 10 CFR 830. (10 CFR 830)

Safety basis - The documented safety analysis and hazard controls that provide reasonable assurance that a DOE nuclear facility can be operated safely in a manner that adequately protects workers, the public, and the environment. (10 CFR 830)

Simple modification - A modification to a DOE nuclear facility not requiring a new or revised hazard analysis and accident analysis and new safety controls. (DOE-STD-1189)

Substantial change to the existing safety basis - Required by facility modification that is considered a major modification. (DOE-STD-1189)

ACRONYMS and ABBREVIATIONS

| | |
|-------|--|
| ATR | Advanced Test Reactor |
| CDF | core damage frequency |
| CFR | Code of Federal Regulation |
| CSDR | conceptual safety design report |
| DOE | U.S. Department of Energy |
| EEB | electrical equipment building |
| GFE | government furnished equipment |
| HC | hazard category |
| INL | Idaho National Laboratory |
| MAR | material at risk |
| MCA | material condition assessment |
| NE | Office of Nuclear Energy |
| NPH | natural phenomena hazards |
| OEM | original equipment manufacturer |
| PC | performance category |
| PDSA | preliminary documented safety analysis |
| PSDR | preliminary safety design report |
| SAR | safety analysis report |
| SC | safety class |
| SDS | safety design strategy |
| SS | safety significant |
| SSC | structure, system or component |
| STD | standard |
| TFR | technical and functional requirements |
| UFSAR | updated final safety analysis report |
| UPS | uninterruptible power supply |

10 CFR 830 Major Modification Determination for the ATR Diesel Bus (E-3) and Switchgear Replacement

1. INTRODUCTION

The Advanced Test Reactor (ATR), located in the Advanced Test Reactor Complex of the Idaho National Laboratory (INL), was constructed in the 1960s for the purpose of irradiating reactor fuels and materials. Other irradiation services, such as radioisotope production, are also performed at ATR.

The continued safe and reliable operation of the ATR is critical to the Department of Energy (DOE) Office of Nuclear Energy (NE) mission. While ATR is safely fulfilling current mission requirements, a variety of aging and obsolescence issues challenge ATR engineering and maintenance personnel's capability to sustain ATR over the long term. First documented in a series of independent assessments, beginning with an OA Environmental Safety and Health Assessment conducted in 2003, the issues were validated in a detailed Material Condition Assessment (MCA) conducted as a part of the ATR Life Extension Program in 2007. Accordingly, near term replacement of aging and obsolescent original ATR equipment has become important to ensure ATR capability in support of NE's long term national missions. To that end, a mission needs statement has been prepared for a non-major system acquisition which is comprised of three interdependent subprojects. The first project, subject of this determination, will replace the existent diesel-electrical bus (E-3) and associated switchgear. More specifically, INL proposes transitioning ATR to 100% commercial power with appropriate emergency backup to include:

- Provide commercial power as the normal source of power to the ATR loads currently supplied by diesel-electric power.
- Provide backup power to the critical ATR loads in the event of a loss of commercial power.
- Replace obsolescent critical ATR power distribution equipment, e.g., switchgear, transformers, motor control centers, distribution panels.

Completion of this and two other age-related projects (primary coolant pump and motor replacement and emergency firewater injection system replacement) will resolve major age-related operational issues plus make a significant contribution in sustaining the ATR safety and reliability profile.

2. PROJECT DESCRIPTION

This project description is based on the drafted Mission Need Statement for ATR Reliability Sustainment Project¹ and the pre-conceptual phase technical and function requirements for transition of ATR to 100% commercial power.² (Note that further system studies may identify the need for changes.)

Experience with commercial power in Eastern Idaho in the late 1950s, during ATR design, demonstrated that even mild weather phenomena could disturb the available commercial power delivery systems resulting in frequent power outages for both domestic and commercial users. The high likelihood of power disruptions mandated the plant's designers incorporate a diesel electric bus in the ATR design to ensure the availability of reliable continuous power for plant safety systems and heat removal in the event of unplanned commercial power disruption. Mitigation was provided through installation of a diesel-electric bus (switchgear) supplied by diesel generators designed to run continuously during plant operations. The prime movers were (and are) large low speed marine diesels of what is now an antiquated design with severely limited vendor support. The marine diesels are backed up by a safety-related standby diesel generator 674-M-6. The diesel electric bus provides all necessary safety-related power to

accommodate unplanned shutdowns and necessary core heat removal. Today, however, the prime movers are, through age, rapidly becoming the source of reliability issues that can impair mission accomplishment.

Commercial power availability at the INL is now, itself, significantly more reliable than that available at the time of ATR design and construction. Transition to available and reliable commercial power with appropriate and available emergency backup emergency power systems will allow retirement of the 50-year-old emergency diesels, no longer original equipment manufacturer (OEM) supported. With this project, commercial power will replace continuous-run diesel generators as the normal power source for the safety-related 670-E-3, 4.16 kV “diesel bus.” In the event of loss of commercial power, the safety-related bus will receive seamless, reliable power from a safety-related uninterruptible power supply (UPS) and two safety-related quick start diesel generators. The two diesel generators will provide triple redundancy with the current safety-related standby diesel generator 674-M-6 that currently backs up the normal continuous run, diesel power.

This project will also replace the aged, E-3 670-E-3 “diesel bus” and switchgear with modern equipment. The safety-related E-3 bus/switchgear, safety-related UPS, two safety-related quick start diesel generators, and supporting unitized power centers for each diesel generator will be located in a new electrical equipment building (EEB). The EEB will be a separate building built near the reactor building, designed to Performance Category 4 (PC-4) standards, inclusive of all building support systems. PC-4 standards are to be maintained to the point of connection to the current ATR electrical distribution system.

This project may also replace the two existing 13.8 to 4.16 kV commercial transformers. Based on MCA findings, the two existing 13.8 to 4.16 kV commercial transformers are also nearing the end of their design service life. No longer supported by OEMs, transformer maintenance activities are becoming increasingly difficult and, due to their oil-cooled design, the old transformers are unnecessarily hazardous to ATR staff compared to currently available replacement equipment. The old oil-filled transformers also present fire hazards most readily mediated through replacement with modern, current design, replacement transformers.

3. HAZARDS DISCUSSION

Material at Risk

The ATR material at risk (MAR) consists of the reactor core, the radioactive materials (irradiated fuel elements and other hardware) stored in the canal, isotope production targets, and experiments containing fuel and non-fueled components. The ATR is a Category A reactor with an operating power level up to 250 MW_t and, as such, has a radioactive material inventory with the potential for significant off-site consequences. The proposed project has no effect on the quantity of MAR.

Fires and/or Explosions

The new EEB facility diesel generators, associated diesel generator fuel tanks, UPS, and switchgear include inherent fire/explosion hazards that will be minimized through the proper design and selection of construction materials. Recharging of the UPS batteries introduces the explosion hazard associated with hydrogen generation. Any fire or explosion associated with these components will not introduce any new mechanism for release of radioactive material from ATR; however, the impact to the safety function for the safety-related components will need to be evaluated to ensure the design is adequate to preclude adverse impact to the reactor safety (e.g. core damage frequency [CDF]).

Natural Phenomena Hazards

Natural phenomena hazards (NPHs), including earthquakes (seismic events), extreme wind, tornado, flood, volcanic, and lightning, are potential hazards to the facility for causing building damage and/or

failure of safety-related operational equipment. These NPH hazards were evaluated in SAR-153 for existing facilities in support of current operations. The pre-conceptual phase technical and function requirements (TFR) document² for this project includes NPH criteria for the building and equipment consistent with the anticipated safety classification.

4. MAJOR MODIFICATION EVALUATION CRITERIA

DOE-STD-1189, “Integration of Safety into the Design Process,”³ was developed to provide consistent DOE complex-wide criteria to be used in determining if a change constitutes a major modification. The standard includes Table 8-1, “Major Modification Evaluation Criteria.” The table provides a methodology for evaluating a project against the 10 CFR830 major modification evaluation criteria⁴ and was used as a basis for this major modification determination. The table is reproduced herein as Table 1, “Major Modification Evaluation Criteria.” The purpose of Table 1 is to focus on the nature of the modification and the associated impact on the existing facility safety basis for the ATR facility.

Major modifications are defined as those changes that “substantially change the existing safety basis for the facility.” The guidance for applying the table states that in applying the criteria, the intent is not to automatically trigger the need for a preliminary documented safety analysis (PDSA) if one or more of the criteria are met. Rather, it is intended that each criterion be assessed individually and then an integrated evaluation be performed based on the collective set of individual results. In performing this evaluation, the focus should be on the nature of the modification and its associated impact on the existing facility safety basis. Even a project that results in changes that ripple through the safety basis documents does not “substantially change the existing safety basis for the facility” solely because many parts or pages of the safety basis documentation need to be revised.

A major modification requires the development of a PDSA, per 10 CFR 830.206, following the facility modification process as depicted in Figure 1. Since DOE-STD-3009, “Preparation Guide for U. S. Department of Energy Nonreactor Nuclear Facility Documented Safety Analyses,”⁵ is not the safe harbor format for the ATR Updated Final Safety Analysis Report (UFSAR), the safety design strategy (SDS) must establish the expectations and the format for integrating the subject major modifications to the update of the UFSAR.

Table 1. Major modification evaluation criteria.

| Major Modification Evaluation Criteria (DOE-STD-1189, Table 8-1) | | | |
|---|---|--|--|
| <u>Project Information</u> | | | |
| <p>The proposed project will transition ATR to 100% commercial power at a TEC of \$65 m. A new EEB will be constructed to house two safety-related, quick-start diesel generators, a safety-related UPS, and a replacement bus/switchgear for the aged, safety-related, E-3 diesel bus. Commercial power, backed up with the diesel generators and UPS, will provide continuous power to the replacement E-3 bus. The commercial power will be the normal power source for the E-3 bus and replace the existing, aged continuous run diesel generators which will be retired in-place.</p> <p>In addition to installing a replacement E-3 bus, the two aged 13.8 to 4.16 kV transformers for the ATR Complex may be replaced.</p> | | | |
| Evaluation Criterion No. | Evaluation Criteria | DOE-STD-1189 Discussion | ATR Diesel Bus (E-3) and Switchgear Replacement Discussion |
| 1 | Add a new building or facility with a material inventory \geq Hazard Category 3 (HC 3) limits or increase the HC of an existing facility? | A new building may be a structure within an existing facility segment. That structure may or may not have direct process ties to the remainder of the segment/process. The requirements of DOE-STD-1027-92, Change Notice 1, September 1997, are used in evaluating hazard categorization impacts. | No, it does not change the HC of the existing facilities and, by itself, is a non-radiological facility. The proposed modification adds a new stand-alone EEB to house the project's replacement components and provide space for future replacement of current ATR switchgear, motor control centers, and associated electrical equipment. The building is physically separate from the ATR reactor building and will not hold any radiological inventory (i.e., will be a non-radiological building); however, it will be one of the buildings/structures that make up the ATR Complex Advanced Test Reactor as currently listed in the Upgraded Final Safety Analysis (UFSAR). ⁶ As stated in the UFSAR (Section ES-2), these buildings and structures are necessary for safe operation of ATR. |

| Evaluation Criterion No. | Evaluation Criteria | DOE-STD-1189 Discussion | ATR Diesel Bus (E-3) and Switchgear Replacement Discussion |
|--------------------------|--|---|--|
| 2 | Change the footprint of an existing HC 1, 2 or 3 facility with the potential to adversely affect any safety class (SC) or safety significant (SS) safety function or associated structure, system and component (SSC)? | A change in the footprint of an existing facility requires the identification and evaluation of any potential adverse impacts on SC or SS safety functions or associated SSC (e.g., structural qualification, evacuation egress path, fire suppression spray pattern) or safety analysis assumptions. Changes that may involve adverse impacts require careful attention to maintaining adherence to applicable engineering standards and nuclear safety design criteria. | Yes. The footprint of buildings and structures that make up the ATR Complex Advanced Test Reactor are listed in Section 5.2 of NS-18303, "INL Nuclear Facilities and Nuclear Facility Managers." ⁷ The new, EEB will be added to the list and be an addition to the "footprint" for the HC1 ATR reactor. As stated in Section 2.4 of the pre-conceptual phase TFR document, 30054.046-2, all systems and components for the replacement E-3 bus, including two quick start diesel generators and UPS, perform a safety function. Likewise, the new EEB that houses the replacement E-3 bus and the associated equipment and components also performs a safety function. Safety classification will be determined by INL based on the safety analysis/probabilistic risk assessment. |

| Evaluation Criterion No. | Evaluation Criteria | DOE-STD-1189 Discussion | ATR Diesel Bus (E-3) and Switchgear Replacement Discussion |
|--------------------------|---|---|--|
| 3 | Change an existing process or add a new process resulting in the need for a safety basis change requiring DOE approval? | A change to an existing process may negatively affect the efficacy of an approved set of hazard controls for a given event or accident. Likewise, potential safety concerns associated with a new process may not be adequately addressed by the existing approved control sets. In this case, it is assumed that the existing analyses addressed the hazards associated with the new or revised process, but the specified control set(s) may no longer be valid. The evaluation of any new hazards introduced by the revised or new process should be addressed via Criterion 6 | <p>Yes. The proposed activity does change an existing process resulting in a safety basis change that requires DOE approval.</p> <p>The current process is to provide continuous diesel generator power to the safety-related 4.16 kV diesel bus 670-E-3. Currently diesel generator power is provided through continuous operation of the two non-safety-related diesel generators 670-M-42 or 670-M-43 or, upon their failure, startup and loading (within 20 seconds) of the safety-related standby diesel generator 674-M-6. The safety-related 4.16 kV diesel bus 670-E-3 supplies power through a safety-related step down transformer 670-E-8 to the safety-related 480 V diesel bus 670-E-9 that supplies power through safety-related automatic transfer switch ATS 670-E-228 to the diesel commercial bus 670-E-15. The diesel commercial bus provides power for the safety-related emergency coolant pump 670-M-10.</p> <p>Per the pre-conceptual TFR for the transition to 100% commercial power distribution, the obsolete non-safety-related diesel generators 670-M-42 and 670-M-43 will be retired. The continuous diesel generator power to bus 670-E-3 will be replaced with normal commercial power. Commercial power and an UPS (expected to be classified safety-related) will provide seamless power to the bus until, in the event of a loss of commercial power, the safety-related diesel generator 674-M-6 picks up the load. Two quick start diesel generators (expected to be classified safety-related) will provide redundancy to 674-M-6. The diesel generators, UPS, and replacement for the 4.16 kV diesel bus 670-E-3 will be located in a new EEB with the appropriate safety/seismic classification for a facility housing safety-related equipment.</p> |

| Evaluation Criterion No. | Evaluation Criteria | DOE-STD-1189 Discussion | ATR Diesel Bus (E-3) and Switchgear Replacement Discussion |
|--------------------------|--|--|---|
| 4 | Utilize new technology or government furnished equipment (GFE) not currently in use or not previously formally reviewed / approved by DOE for the affected facility? | This assessment should include consideration of the impact that the use of new technology (including technology scale-up issues) or GFE may have on the ability to specify the applicable nuclear safety design criteria with a high degree of certainty in the early stages of the project. Additionally, refer to GFE discussion in Section 8.3. GFE may have a technical baseline that is not directly and fully supportive of the project functional and performance requirements. An example would be employing a new technology for removal of certain nuclides from a waste stream. | No. The proposed activity will utilize like-for-like, functionally equivalent replacement equipment that is current technology to the nuclear power industry. Diesel generators 670-M-42 and 670-M-43 are low speed marine diesels of what is now an antiquated design with severely limited vendor support. They will be replaced with normal commercial power and available backup emergency power systems (an UPS with two quick start diesels). Replacement buses/switchgear and transformers employ commercially accepted, current technology. |

| Evaluation Criterion No. | Evaluation Criteria | DOE-STD-1189 Discussion | ATR Diesel Bus (E-3) and Switchgear Replacement Discussion |
|--------------------------|---|---|--|
| 5 | Create the need for new or revised safety SSCs? | <p>Consideration should be given to the relative complexity of the controls and the ease with which the controls can be implemented. The use of a complicated multi-channel Safety Class seismically qualified instrumented system to provide multiple interlock and alarm functions would typically pose a higher risk to the project than the use of a safety significant passive design feature. The degree of design and regulatory uncertainty should be addressed for this criterion for the development, review, and approval of new or revised safety analysis and attendant controls (e.g., presence of multiple regulatory/technical agencies on a single project).</p> | <p>Yes. It is expected that the proposed activity will result in a revised list of safety-related SSCs. Specifically, based on the pre-conceptual TFR, it is anticipated that the following SSCs will be added to the credited list of safety SSCs:</p> <ul style="list-style-type: none"> • The replacement 4.16 kV diesel bus • The UPS • The two additional quick-start 4.16 kV diesel generators and associated power coordination/distribution controls • The EEB housing these systems |

| Evaluation Criterion No. | Evaluation Criteria | DOE-STD-1189 Discussion | ATR Diesel Bus (E-3) and Switchgear Replacement Discussion |
|--------------------------|---|---|--|
| 6 | Involve a hazard not previously evaluated in the Documented Safety Analysis ? | Hazards can include the introduction of an accident or failure mode of a different type from that previously analyzed in addition to radiological or toxicological hazards. The need to address a new hazard early in the design process may lead to some degree of uncertainty related to the proper specification of applicable nuclear safety design criteria. In such cases, this uncertainty should be addressed within this evaluation. | Yes. The proposed activity does introduce a large UPS located in the new EEB with the safety-related E-3 diesel bus. The charging of the UPS batteries does introduce concerns with hydrogen generation which, although not unique to the proposed activity, will need to be evaluated. In addition, the ATR probabilistic risk assessment will have to be updated to confirm that the proposed activity meets its objective to maintain or reduce the CDF for the ATR. It is anticipated that the increased reliability of commercial power with the addition of the UPS and two additional quick start diesel generators will achieve the CDF objective; however, the ATR probabilistic risk assessment will have to be updated to confirm the objective is met. |

Summary and Recommendation: Four of the six criteria (Criterion 2, 3, 5 and 6) were tripped in this major modification evaluation. As discussed above, the proposed project does not introduce any new significant hazards (other than UPS H₂ generation) requiring new accident analyses. However, the proposed strategy for providing reliable power for the safety-related emergency cooling pumps requires the designation of new equipment (quick start diesels and UPS) as safety-related SSCs. The safety-related designation requires careful attention to maintaining adherence to applicable engineering and nuclear safety design criteria (e.g., seismic qualification, isolation of redundant trains from common fault failures) to ensure no adverse impacts to their designated safety functions. Based on these considerations, it is concluded that this project constitutes a major modification and will, therefore, require the development, review, and approval of a PDSA. It is recommended that the project proceed accordingly. Also, since DOE-STD-3009 is not the safe harbor format for the ATR UFSAR, the SDS must establish the expectations and the format for the preliminary safety design report (PSDR) (if needed) and PDSA to integrate the subject major modifications into the ATR UFSAR.

5. CONCLUSION

The major modification criteria evaluation of the project pre-conceptual design identified several issues make the project a major modification:

1. Evaluation Criteria #2 (Footprint change). The addition of a new PC-4 structure to the ATR Facility to house safety-related SSCs requires careful attention to maintaining adherence to applicable engineering and nuclear safety design criteria (e.g., structural qualification, fire suppression) to ensure no adverse impacts to the safety-related functions of the housed equipment.
2. Evaluation Criteria #3 (Change of existing process). The change to the strategy for providing continuous reliable power to the safety-related emergency coolant pumps requires careful attention and analysis to ensure it meets a project primary object to maintain or reduce CDF and does not negatively affect the efficacy of the currently approved strategy.
3. Evaluation Criteria #5 (Create the need for new or revised safety SSCs). The change to the strategy for providing continuous reliable power to the safety-related emergency coolant pumps, based on the pre-conceptual design, will require the addition of two quick start diesel generators, their associated power coordination/distribution controls, and a UPS to the list of safety-related SSCs. Similarly to item 1 above, the addition of these active SSCs to the list of safety-related SSCs and replacement of the E-3 bus requires careful attention to maintaining adherence to applicable engineering and nuclear safety design criteria (e.g., seismic qualification, isolation of redundant trains from common fault failures) to ensure no adverse impacts to the safety-related functions.

As discussed in 1, 2, and 3 above, the positive major modification determination is driven by the need to carefully establish the engineering and nuclear safety design criteria for new safety-related SSCs and structures. Since the proposed project does not introduce significant new hazards, the safety analysis will need to be tailored appropriately as discussed in the following text from DOE-STD-1189, Chapter 8:

“Where a major modification is found to exist, an SDS must be developed that addresses (1) the need for a CSDR or PSDR (as well as the required PDSA) to support project phases, (2) the graded content of the PDSA necessary to support the design and modification, (3) the application of nuclear safety design criteria, and (4) the interface with the existing facility, its operations, and construction activities.”

6. REFERENCES

1. Mission Need Statement for Advanced Test Reactor Reliability Sustainment Project, March 2011 Draft.
2. Doc. ID 30054.046-2, “Transition the Advanced Test Reactor (ATR) to 100% Commercial Power, Technical and Functional Requirements (Pre-Conceptual Phase),” URS Corporation, September 2010.
3. DOE-STD-1189-2008, “Integration of Safety into the Design Process,” Department of Energy, March 2008.
4. 10 CFR 830, Subpart B, “Nuclear Safety Management,” *Code of Federal Regulations*, Office of the Federal Register, current revision.
5. DOE-STD-3009-94, Change 3, “Preparation Guide for U. S. Department of Energy Nonreactor Nuclear Facility Documented Safety Analyses,” Department of Energy, March 2006.

6. SAR-153, "Upgraded Final Safety Analysis Report for the Advanced Test Reactor," Rev. 30, February 2011.
7. NS-18303, "INL Nuclear Facilities and Nuclear Facility Managers," current revision.