

Station 4

ENGINEERING DATA TRANSMITTAL

2. To: (Receiving Organization) Distribution	3. From: (Originating Organization) Retrieval System Development	4. Related EDT No.: NA
5. Proj./Prog./Dept./Div.: RPP/Retrieval System Development	6. Design Authority/Design Agent/Cog. Engr.: W.L. Willis	7. Purchase Order No.: NA
8. Originator Remarks: For approval and release.		9. Equip./Component No.: NA
11. Receiver Remarks:		10. System/Bldg./Facility: Tk AY101&102, AZ101&102
11A. Design Baseline Document? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		12. Major Assm. Dwg. No.: NA
		13. Permit/Permit Application No.: NA
		14. Required Response Date: NA

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	RPP-6536	--	0	Decision Document for	NA	1	1	-
				Heat Removal from		2		
				High-Level Waste Tanks				

16. KEY		
Approval Designator (F)	Reason for Transmittal (G)	Disposition (H) & (I)
E, S, Q, D OR N/A (See WHC-CM-3-5, Sec. 12.7)	1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)	1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
		Design Authority				1	1	A. F. Choho	<i>AFC</i>	7/18/00	
		Design Agent									
1	1	Cog. Eng. W.L. Willis	<i>W.L. Willis</i>	7/31/00							
1	1	Cog. Mgr. P.J. Certa	<i>P.J. Certa</i>	7/31/00							
		QA									
		Safety									
		Env.									

18. <i>W.L. Willis</i> Signature of EDT Originator Date: 7/31/00	19. <i>P.J. Certa</i> Authorized Representative for Receiving Organization Date: 7/31/00	20. <i>P.J. Certa</i> Design Authority/ Cognizant Manager Date: 7/31/00	21. DOE APPROVAL (if required) Ctrl No. _____ <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/comments <input type="checkbox"/> Disapproved w/comments
--	--	--	--

Decision Document for Heat Removal from High-Level Waste Tanks

W. L. Willis

Numatec Hanford Corporation

Richland, WA 99352

U.S. Department of Energy Contract DE-AC06-99RL14047

EDT/ECN: 629063

UC: 721

Cost Center: 6N100

Charge Code: 110350/BA10

B&R Code: EW3130000

Total Pages: 70 14 12
KW 7/31/00 KW 7/31/00

Key Words:


Retrieval, mixer pump, sludge, fluffed sludge, fluffing factor, thermal analysis, GOTH_SNF, settling, waste temperature

Abstract: This document establishes the combination of design and operational configurations that will be used to provide heat removal from high-level waste tanks during Phase 1 waste feed delivery to prevent the waste temperature from exceeding tank safety requirement limits. The chosen method--to use the primary and annulus ventilation systems to remove heat from the high-level waste tanks--is documented herein.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

 7/31/00
Release Approval Date



Release Stamp

Approved For Public Release

Decision Document for Heat Removal from High-Level Waste Tanks

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

CH2MHILL

Hanford Group, Inc.

Richland, Washington

Contractor for the U.S. Department of Energy
Office of River Protection under Contract DE-AC06-99RL14047

Approved for Public Release; Further Dissemination Unlimited

LEGAL DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced from the best available copy.

Available in paper copy and microfiche.

Available electronically at
<http://www.doe.gov/bridge>. Available for a processing fee to the U.S. Department of Energy and its contractors, in paper, from:
U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831-0062
phone: 865-576-8401
fax: 865-576-5728
email: [reports@adonis.osti.gov\(423\)](mailto:reports@adonis.osti.gov(423)) 576-8401

Available for sale to the public, in paper, from:
U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
Phone: 800-553-6847
fax: 703-605-6900
email: orders@ntis.fedworld.gov
online ordering:
<http://www.ntis.gov/ordering.htm>

Decision Document for Heat Removal from High-Level Waste Tanks

Prepared by:
W. L. Willis
Numatec Hanford Corporation
Richland, Washington

Date Published
July 2000

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

CH2MHILL

Hanford Group, Inc.

P. O. Box 1500
Richland, Washington

Contractor for the U.S. Department of Energy
Office of River Protection under Contract DE-AC06-99RL14047

Approved for Public Release; Further Dissemination Unlimited

**DECISION DOCUMENT FOR HEAT REMOVAL
FROM HIGH-LEVEL WASTE TANKS**

DECISION-MAKER APPROVAL



R. A. Dodd, Acting Manager
Double-Shell Tank and Waste Feed Delivery Project

07/31/00

Date

**DECISION DOCUMENT FOR HEAT REMOVAL
FROM HIGH-LEVEL WASTE TANKS**

DECISION SUPPORT BOARD CONCURRENCE

Your signature indicates that you agree that the description given in Section 5.0 of this document is a fair and complete representation of the recommendation and that you agree with the recommendation.




G. P. Duncan, Project Definition Operations

7-17-00
Date




A. F. Choho, Retrieval Engineering

7-18-00
Date



R. S. Popielarczyk, Chief Engineer

7/26/00
Date



C. E. Leach, Nuclear Safety and Licensing

7/26/00
Date

CONTENTS

1.0 STATEMENT OF THE PROBLEM 1

2.0 DATE OF SELECTION 1

3.0 DECISION-MAKER 1

4.0 DECISION ACTION OFFICER..... 2

5.0 SELECTED ALTERNATIVE 2

6.0 SCREENING CRITERIA 3

7.0 FUNDAMENTAL OBJECTIVES OF WASTE FEED DELIVERY 3

8.0 ASSUMPTIONS 3

9.0 ALTERNATIVES REJECTED 4

10.0 ADDITIONAL AUTHORIZATION BASIS CONSIDERATIONS 4

11.0 REFERENCES..... 5

1.0 STATEMENT OF THE PROBLEM

This decision considers the following problem:

What is the preferred combination of design and operational configurations to provide heat removal from high-level waste tanks during Phase 1 feed delivery to prevent the waste temperature from exceeding tank safety requirement limits as specified in the technical safety requirements (HNF-SD-WM-TSR-006, *Tank Waste Remediation System Technical Safety Requirements*)?

The temperature limits in the technical safety requirements are imposed to avoid a tank bump accident, which might result in the release of radioactive material onsite. The technical safety requirements includes a safety limit, SL 2.1.1, which states:

“The WASTE temperature shall be $\leq 250^{\circ}\text{F}$.”

The technical safety requirements also include a related limiting condition for operation, LCO 3.3.2, which states:

"The WASTE temperature shall be either:

- (1) $\leq 195^{\circ}\text{F}$ in all levels of the WASTE
OR
- (2) $\leq 195^{\circ}\text{F}$ in the top 15 ft of the WASTE
AND
 $\leq 215^{\circ}\text{F}$ in the WASTE below 15 ft."

For further discussion of the problem, see HNF-4433, *Alternatives Generation and Analysis for Heat Removal from High-Level Waste Tanks*, Section 1.0.

2.0 DATE OF SELECTION

An interim decision was reached on March 2, 2000, and documented on March 20, 2000, in Memorandum 79C00-00-012, *High-Level Waste Heat Removal Interim Decision*, sent from G. P. Duncan to A. F. Choho (Duncan 2000). The date of the final decision is the date that the decision-maker signs this document.

3.0 DECISION-MAKER

The decision-maker is R. A. Dodd, Acting Manager of Double-Shell Tank and Waste Feed Delivery Project.

4.0 DECISION ACTION OFFICER

The decision action officer is A. F. Choho, Manager, Retrieval Engineering.

5.0 SELECTED ALTERNATIVE

The decision-maker selected the following alternative for heat removal from high-level waste tanks:

- Primary Ventilation Systems
 - The minimum required once-through flow rate of noncooled air through the headspaces of Tanks 241-AY-101, 241-AY-102, 241-AZ-101, and 241-AZ-102 will be 0.24 m³/s (500 ft³/min) per tank when undergoing mixing and settling.
 - The primary ventilation systems—specifically, the equipment performing the heat-removal function—for each of the four high-level waste tanks are assumed to be designated safety significant for the tank bump accident.
- Annulus (Secondary) Ventilation Systems
 - The minimum required once-through flow rate of noncooled air through the cooling channels (slots) of Tanks 241-AY-101, 241-AY-102, 241-AZ-101, and 241-AZ-102 is 0.40 m³/s (850 ft³/min) per tank; the nominal design flow rate is 0.47 m³/s (1,000 ft³/min).
 - The annulus ventilation systems—specifically, the equipment performing the heat-removal function—for each of the four high-level waste tanks are assumed to be designated safety significant for the tank bump accident.

The selected alternative is discussed in HNF-4433, Sections 3.0 and 4.0.

The decision to use the ventilation systems for heat removal from high-level waste tanks was driven primarily by the following considerations:

- No other alternative was shown to be capable of safely and reliably maintaining the waste to within the temperature limits in the technical safety requirements.
- Operation of the ventilation systems to control waste temperature meets the fundamental objectives of the Waste Feed Delivery Program and presents little risk to the successful completion of the waste feed delivery mission.

The basis for this decision is discussed further in the executive summary of HNF-4433.

6.0 SCREENING CRITERIA

Several potential solutions to the heat removal problem were posed and then screened against the following requirements and constraints:

- The waste must be maintained within the temperature limits imposed by the technical safety requirements.
- The primary ventilation system must maintain the tank dome pressure below atmospheric pressure.
- The annulus ventilation system must operate within the tank pressure design limits.
- Heat removal systems must be capable of removing the bounding heat load and limiting the maximum temperature in the tank, including the temperature in the settled sludge.
- An acceptable alternative must be capable of being made safety significant.

Only one alternative (use of the primary and annulus ventilation systems for heat removal) satisfied the requirements and constraints.

7.0 FUNDAMENTAL OBJECTIVES OF WASTE FEED DELIVERY

Following screening, the single remaining alternative was compared to the following fundamental objectives of waste feed delivery:

- Maximize public, worker, and environmental safety
- Maximize regulatory compliance
- Minimize life-cycle cost
- Maximize the chances of success of the waste feed delivery mission.

The alternative was found to satisfy all of the fundamental objectives. In addition, an assessment showed that the risks associated with using the ventilation systems to control temperature were manageable and acceptable.

8.0 ASSUMPTIONS

The following were the most important assumptions used in this decision:

- The GOTH_SNF thermal modeling results accurately reflect the tank waste temperature profiles under the conditions assumed.
- The bounding temperature in the settled sludge is produced in Tank 241-AZ-102 when the tank is mixed and the solids are allowed to resettle to a fluffed condition.

Additional information on the assumptions, constraints, and requirements is given in HNF-4433, Section 2.0.

9.0 ALTERNATIVES REJECTED

The following alternatives were considered and ultimately rejected:

- Use the airlift circulators to keep the solids in suspension
- Use heat exchangers to cool the waste
- Use mixer pumps to keep the solids in suspension
- Delay the decision pending the final results of the Tank 241-AZ-101 mixer pump test¹
- Alter the safety limits for temperature specified in the technical safety requirements.

A description of the rejected alternatives and an explanation of why each was rejected are provided in HNF-4433, Section 3.0

10.0 ADDITIONAL AUTHORIZATION BASIS CONSIDERATIONS

The result of the interim decision reached in March 2000 and the underlying assumptions relative to the authorization basis that led to the final decision are accurately documented herein. However, in response to direction from the Office of River Protection, the authorization basis continues to evolve relative to the accident of concern—the tank bump accident. Ongoing authorization basis amendments related to the tank bump accident that may have an impact on this decision are described in subsequent paragraphs.

The tank bump accident has been reanalyzed for the safe-storage mission, and an authorization basis amendment reflecting this reanalysis was submitted to the Office of River Protection on June 30, 2000 (Bratzel and DeLozier 2000). If approved, this authorization basis amendment will reduce the onsite radiological consequences for the tank bump accident from the 250 rem reflected in the current final safety analysis report (HNF-SD-WM-SAR-067, *Tank Waste Remediation System Final Safety Analysis Report*) to 5 rem and reduce the onsite toxicological dose by approximately 99 percent. The new radiological dose is equal to the onsite risk evaluation guideline, and the new toxicological dose is above the risk evaluation guideline of 1.

Reanalysis of the tank bump accident for waste feed delivery operations, applying methodologies similar to those used for the safe-storage case, is ongoing and should be completed by the end of July. Preliminary results indicate that the consequences of the safe-storage case will bound the waste feed delivery case. Control decision meetings will be held soon after the analysis is completed. Although the waste feed delivery tank bump accident is expected to have lower consequences than the safe-storage tank bump accident, the radiological consequences probably

¹ While the results of the mixer pump test are extremely valuable, it was determined in HNF-4433 that the results would not change the outcome of the alternatives generation and analysis.

will equal a significant percentage of the risk guidelines and the toxicological consequences still may exceed the guidelines. Therefore, it is reasonable to assume that some technical safety requirement controls will be selected to prevent this accident. The current limiting condition for operation on double-shell tank waste temperature (LCO 3.3.2) is a highly effective, low-cost control. Continued application of LCO 3.3.2 likely will be selected as the primary means for preventing tank bump accidents during waste feed delivery operations. Because of the reduced consequences and because the tank bump accident is slow to develop, the most conservative analyses indicate that in the absence of any primary or annulus ventilation it would take a minimum of 50 days for the waste to reach saturation temperature. Therefore, the ventilation systems probably will not be designated as safety significant.

Although the authorization basis probably will not prescribe how to control waste temperature, this should not affect the decision that use of the primary and annulus ventilation systems is the preferred choice of temperature control from an operational standpoint.

11.0 REFERENCES

- Bratzel, D. R., and M. P. DeLozier, 2000, *Submittal of Authorization Basis Amendment for Re-analysis of the Tank Bump Accident to Meet Performance Incentive Number ORP2.1.1, Revision 1, "Authorization Basis Management Process Efficiency Improvement," Section 3, Standard IID., and Section 4, Standard II.D.*, (Letter CHG-0003436 to R. T. French, Office of River Protection, dated June 29), CH2M HILL Hanford Group, Inc., Richland, Washington.
- Duncan, G. P., 2000, *High-Level Waste Heat Removal Interim Decision*, (Memorandum 79C00-00-012 to A. F. Choho, Numatec Hanford Corporation, dated March 20), CH2M HILL Hanford Group, Inc., Richland, Washington.
- HNF-4433, 2000, *Alternatives Generation and Analysis for Heat Removal from High-Level Waste Tanks*, Rev. 0, Numatec Hanford Corporation for CH2M HILL Hanford Group, Inc., Richland, Washington.
- HNF-SD-WM-SAR-067, 2000, *Tank Waste Remediation System Final Safety Analysis Report*, Rev. 1-I, CH2M HILL Hanford Group, Inc., Richland, Washington.
- HNF-SD-WM-TSR-006, 1999, *Tank Waste Remediation System Technical Safety Requirements*, Rev. 0T, Fluor Daniel Hanford, Inc., Richland, Washington.

DISTRIBUTION**Onsite**

15	<u>CH2M HILL Hanford Group, Inc.</u>	
	Bailey, J. W.	R3-25
	Bratzel, D. R.	R1-44
	Crawford, T. W.	R3-73
	Defigh-Price, C.	R2-12
	Dodd, R. A.	R3-72
	Duncan, G. P.	R3-72
	Goetz, T. G.	R1-49
	Hodgson, K. M.	R2-11
	Leach, C. E.	R1-44
	Lentsch, J. W.	R3-25
	Meacham, J. E.	R1-49
	Powell, R. W.	R3-75
	Popielarczyk, R. S.	R2-58
	Schmitz, P.	R3-73
	Thompson, W. T.	R3-73
1	<u>Fluor Hanford, Inc.</u>	
	Schliebe, M. J.	L6-13
5	<u>Lockheed Martin Services, Inc.</u>	
	Rice, R. L. (3)	R3-73
	Central Files	B1-07
	Document Processing Center	A3-94
20	<u>Numatec Hanford Corporation</u>	
	Carlson, A. B.	R3-73
	Certa, P. J. (2)	R3-73
	Choho, A. F.	R3-73
	Conrads, T. J.	R3-73
	Galbraith, J. D.	R3-73
	Garfield, J. S.	R3-73
	G. Senetz	R3-73
	W. L. Willis (12)	R3-73

DISTRIBUTION (CONT)

Onsite

1	<u>Pacific Northwest National Laboratories</u>	
	Hanford Technical Library	P8-55
5	<u>Subcontractors</u>	
	Ogden, D. M., JMI	R3-73
	Sederburg, J. P., ARES Corp.	R3-73
	Symons, G. A., COGEMA	H3-27
	Thurgood, M., JMI	
	Treat, R. L., INFO	H6-19
1	<u>U.S. Department of Energy</u>	
	<u>Richland Operations Office</u>	
	Reading Room	H2-53