

<b>ENGINEERING CHANGE NOTICE</b>	Page 1 of <u>2</u>	1. ECN <b>660780</b>
		Proj. ECN

<b>2. ECN Category (mark one)</b> Supplemental <input type="checkbox"/> Direct Revision <input checked="" type="checkbox"/> Change ECN <input type="checkbox"/> Temporary <input type="checkbox"/> Standby <input type="checkbox"/> Supersedure <input type="checkbox"/> Cancel/Void <input type="checkbox"/>	<b>3. Originator's Name, Organization, MSIN, and Telephone No.</b> Jaka, Omar M., ISE, S7-24, 372-2322	<b>4. USQ Required?</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>5. Date</b> 6/28/00
<b>6. Project Title/No./Work Order No.</b> DESIGN REVIEW REP., CONCRETE COVER BLOCK REPLACED BY STEEL PLATE		<b>7. Bldg./Sys./Fac. No.</b> See 13a.	<b>8. Approval Designator</b> SQ
<b>9. Document Numbers Changed by this ECN (includes sheet no. and rev.)</b> RPP-5416 Rev. 1		<b>10. Related ECN No(s).</b> ECN-660753	<b>11. Related PO No.</b> N/A

<b>12a. Modification Work</b> <input type="checkbox"/> Yes (fill out Blk. 12b) <input checked="" type="checkbox"/> No (NA Blks. 12b, 12c, 12d)	<b>12b. Work Package No.</b> N/A	<b>12c. Modification Work Completed</b> N/A Design Authority/Cog. Engineer Signature & Date	<b>12d. Restored to Original Condition (Temp. or Standby ECNs only)</b> N/A Design Authority/Cog. Engineer Signature & Date
--	-------------------------------------	---	---

**13a. Description of Change** **13b. Design Baseline Document?**  Yes  No

Revise the Formal Design Review Report for U-109 and U-105 Cover Plate to include Design Review of 7 additional Cover Plate modifications by similarity and comparison:

- 1) U-103
- 2) AX-101
- 3) A-101
- 4) SX-105
- 5) S-A VALVE PIT
- 6) S-C VALVE PIT
- 7) SX-A VALVE PIT

This ECN is covered by Categorical Exclusion USQ# TF-96-0690 Rev. 2 items 5,6,9

<b>14a. Justification (mark one)</b> Criteria Change <input checked="" type="checkbox"/> Design Improvement <input type="checkbox"/> Environmental <input type="checkbox"/> Facility Deactivation <input type="checkbox"/> As-Found <input type="checkbox"/> Facilitate Const. <input type="checkbox"/> Const. Error/Omission <input type="checkbox"/> Design Error/Omission <input type="checkbox"/>	<b>14b. Justification Details</b> Design verification of 7 additional cover plates were evaluated against previously approved cover plate for U-109 pump pit as per subsec 4.1.2 of sec 4.24 of HNF-IP-0824 vol. IV. This modification will not result in a change to exposure > 1 person-REM (Whole Body) or 10 person-REM (extremities) for the installation, maintenance and operation of the life of the modification. NEPA screening not required-administrative change.
---	--

**15. Distribution (include name, MSIN, and no. of copies)**

OM Jaka	S7-24
WF Zuroff	S7-24
MR Koch	S7-24
TJ Volkman	S7-34
LL Penn	S7-07
LA Flowers	S7-07
KJ Hull	T4-07
DK DeFord	S7-24
KR Ellingson	S7-24

**RELEASE STAMP**

DATE: **JUL 27 2000**

STA: **A**

RELEASE

ID: **2**

# ENGINEERING CHANGE NOTICE

**16. Design Verification Required**

Yes

No

**17. Cost Impact**

ENGINEERING

Additional  \$ N/A

Savings  \$ N/A

CONSTRUCTION

Additional  \$ N/A

Savings  \$ N/A

**18. Schedule Impact (days)**

Improvement  N/A

Delay  N/A

**19. Change Impact Review:** Indicate the related documents (other than the engineering documents identified on Side 1) that will be affected by the change described in Block 13. Enter the affected document number in Block 20.

<p>SDD/DD <input type="checkbox"/></p> <p>Functional Design Criteria <input type="checkbox"/></p> <p>Operating Specification <input type="checkbox"/></p> <p>Criticality Specification <input type="checkbox"/></p> <p>Conceptual Design Report <input type="checkbox"/></p> <p>Equipment Spec. <input type="checkbox"/></p> <p>Const. Spec. <input type="checkbox"/></p> <p>Procurement Spec. <input type="checkbox"/></p> <p>Vendor Information <input type="checkbox"/></p> <p>OM Manual <input type="checkbox"/></p> <p>FSAR/SAR <input type="checkbox"/></p> <p>Safety Equipment List <input type="checkbox"/></p> <p>Radiation Work Permit <input type="checkbox"/></p> <p>Environmental Impact Statement <input type="checkbox"/></p> <p>Environmental Report <input type="checkbox"/></p> <p>Environmental Permit <input type="checkbox"/></p>	<p>Seismic/Stress Analysis <input type="checkbox"/></p> <p>Stress/Design Report <input type="checkbox"/></p> <p>Interface Control Drawing <input type="checkbox"/></p> <p>Calibration Procedure <input type="checkbox"/></p> <p>Installation Procedure <input type="checkbox"/></p> <p>Maintenance Procedure <input type="checkbox"/></p> <p>Engineering Procedure <input type="checkbox"/></p> <p>Operating Instruction <input type="checkbox"/></p> <p>Operating Procedure <input type="checkbox"/></p> <p>Operational Safety Requirement <input type="checkbox"/></p> <p>IEFD Drawing <input type="checkbox"/></p> <p>Cell Arrangement Drawing <input type="checkbox"/></p> <p>Essential Material Specification <input type="checkbox"/></p> <p>Fac. Proc. Samp. Schedule <input type="checkbox"/></p> <p>Inspection Plan <input type="checkbox"/></p> <p>Inventory Adjustment Request <input type="checkbox"/></p>	<p>Tank Calibration Manual <input type="checkbox"/></p> <p>Health Physics Procedure <input type="checkbox"/></p> <p>Spares Multiple Unit Listing <input type="checkbox"/></p> <p>Test Procedures/Specification <input type="checkbox"/></p> <p>Component Index <input type="checkbox"/></p> <p>ASME Coded Item <input type="checkbox"/></p> <p>Human Factor Consideration <input type="checkbox"/></p> <p>Computer Software <input type="checkbox"/></p> <p>Electric Circuit Schedule <input type="checkbox"/></p> <p>ICRS Procedure <input type="checkbox"/></p> <p>Process Control Manual/Plan <input type="checkbox"/></p> <p>Process Flow Chart <input type="checkbox"/></p> <p>Purchase Requisition <input type="checkbox"/></p> <p>Tickler File <input type="checkbox"/></p> <p><u>None</u> <input checked="" type="checkbox"/></p>
--	--	---

**20. Other Affected Documents:** (NOTE: Documents listed below will not be revised by this ECN.) Signatures below indicate that the signing organization has been notified of other affected documents listed below.

Document Number/Revision	Document Number/Revision	Document Number/Revision
N/A	N/A	N/A

**21. Approvals**

	Signature	Date		Signature	Date
Design Authority <u>WF Zurhoff</u>		<u>7/26/00</u>	Design Agent	_____	_____
Cog. Eng. <u>DK DeFord</u>		<u>7/17/00</u>	PE	_____	_____
Cog. Mgr. <u>MR Koch</u>		<u>7/12/00</u>	QA	_____	_____
QA <u>TJ Volkman</u>		<u>7/12/00</u>	Safety	_____	_____
Safety <u>LA Flowers</u>		<u>7/20/00</u>	Design	_____	_____
Environ. <u>LL Penn</u>		<u>7/17/00</u>	Environ.	_____	_____
Other <u>OM Jaka</u>		<u>7/17/00</u>	Other	_____	_____
FAC. Cog <u>KJ Hull</u>		<u>7/19/00</u>		_____	_____

**DEPARTMENT OF ENERGY**

Signature or a Control Number that tracks the Approval Signature

**ADDITIONAL**

# DESIGN REVIEW REPORT, CONCRETE COVER BLOCK REPLACED BY STEEL PLATE

O. M. Jaka

CH2MHILL HANFORD GROUP, INC

Richland, WA 99352

U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 660780

UC:

Org Code: 74D00

Charge Code: 103361

B&R Code:


Total Pages: ~~56~~ 57  
d7-7-27-00.


Key Words: 241-U-109, 241-U-105, 241-U-103, 241-AX-101, 241-A-101,  
241-SX-105, 241-S-A, 241-S-C, 241-SX-A, DESIGN REVIEW REPORT, COVER  
PLATE, FSAR

Abstract: The design for the steel cover plates to replace concrete cover  
blocks for U-109 was reviewed and approved in a design review meeting.  
The design for steel plates to replace concrete blocks were reviewed and  
approved by comparison and similarity with U-109 for the following  
additional pits: 241-U-105, 241-U-103, 241-AX-101, 241-A-101,  
241-SX-105, 241-S-A, 241-S-C, 241-SX-A.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name,  
trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or  
favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services,  
P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

  
Release Approval Date 7/26/00



**Approved For Public Release**



**TABLE OF CONTENTS**

1.0 SCOPE.....1  
2.0 SUMMARY.....4  
3.0 DOCUMENTATION.....6

**U-109**

- APPENDIX A- MEETING MINUTES
- APPENDIX B- REVIEW COMMENT RECORDS
- APPENDIX C- STRUCTURAL CALCULATIONS

**U-105 & U-103**

- APPENDIX D- U-105 & U-103: STRUCTURAL CALCULATIONS

**AX-101**

- APPENDIX E- STRUCTURAL CALCULATIONS

**A-101**

- APPENDIX F- STRUCTURAL CALCULATIONS

**SX-105**

- APPENDIX G- STRUCTURAL CALCULATIONS

**S-A, S-C, & SX-A VALVE PITS**

- APPENDIX H- S-A: STRUCTURAL CALCULATIONS
- APPENDIX I- S-C: STRUCTURAL CALCULATIONS
- APPENDIX J- SX-A: STRUCTURAL CALCULATIONS

## 1.0 Scope

A design review meeting was held to review ECN 648492. During the review meeting all RCR comments were reviewed and dispositioned to the satisfaction of the reviewers. This review covered the modification of the existing Safety Class 1" Carbon Steel (CS) Cover Plate over the Saltwell Pump Pit for 241-U-109 tank and also adding additional 2" CS plate for shielding purposes. Modification of this 1" plate was needed to cut four additional slots for inserting the electrical wire connection from the PIC (Pumping and Instrumentation Control) Skid and to provide a 8"X6" hole to insert a sensor for the Flammable Gas Monitor (FGM).

A design review of ECN 648484 to modify existing 1" plate and add 2" steel plate is done of 241-U-105 by comparison with 241-U-109 cover plates, which has the same size cover plates.

**A design review for CS cover plates to replace concrete cover blocks is done by similarity and comparison with 241-U-109 cover plates for the following pits: 241-U-103, 241-AX-101, 241-A-101, 241-SX-105, 241-S-A, 241-S-C, and 241-SX-A.**

The FSAR, HNF-SD-WM-SAR-067 Rev. 1, Table 3.4.2.9-3 identifies cover blocks (or Cover Plates for Saltwell Pumping) as Safety Class to knockdown spray leak and to limit the release of waste aerosols into the atmosphere. Pit covers are also a mitigative feature for other accidents and provides radiation protection (i.e. shielding) for facility workers.

NOTE: The following are documents relevant to a particular cover plate modification. Those without a document number are included as appendices to this design review report. [See Table of Contents for a description of appendices.]

Documents Reviewed:

- 1) ECN-648492, Install 2" shielding Plate & Modify 1" cover plate on 241-U-109.
- 2) USQ TF-99-0229, Rev. 5, Install Saltwell Pumps and Jumpers, 241-U Tank Farm, Modify Cover Plate
- 3) RPP-5989, Rev. 0, Radiological Design Review Screening-Saltwell Pumping at 241-U-109 Pump Pit.
- 4) Calculations for structural Integrity of steel cover plate dated: 11/9/99.

Documents for cover plates at U-105 and U-103:

- 1) ECN-648484, Install 2" Shielding Plate: 241-U-105
- 2) RPP-6641, Rev. 0, Radiological Design Review Screening-Saltwell Pumping at 241-U-105 Pump Pit.
- 3) USQ TF-99-0229, Rev. 4, Install Saltwell Pumps and Jumpers, 241-U Tank Farm, Modify Cover Plate (for U-105)
- 4) **Calculations for structural Integrity of steel cover plate U-105 and U-103 dated: 3/11/99.**
- 5) ECN-648470, Install 2" Shielding Plate: 241-U-103
- 6) RPP-6640, Rev. 0, Radiological Design Review Screening-Saltwell Pumping at 241-U-103 Pump Pit.

- 7) USQ TF-99-0229, Rev. 3, Install Saltwell Pumps and Jumpers, 241-U Tank Farm, Modify Cover Plate (for U-103)

Documents for cover plates at AX-101:

- 1) ECN-659244, Fab and Install Cover Plate on Distributor Pit AX-101
- 2) RPP-5844, Rev. 0, Radiological Design Review Screening-Saltwell Pumping at 241-AX-101 Pump Pit.
- 3) USQ TF-00-0128 Rev. 3, Replace 1" and add 2" Steel Plate on Distributor Pit AX-101
- 4) Calculations for structural Integrity of steel cover plate AX-101, 3/14/00.

Documents for cover plates at A-101:

- 1) ECN-652568, Replace 241-A-101 Pit Cover blocks by 2" Steel Cover Plate
- 2) RPP-6642, Rev. 0, Radiological Design Review Screening- 2" Carbon Steel Cover Plate Installation at 241-A-101 Pump Pit
- 3) USQ TF-99-9950, Rev. 0, Replace Cover Block by 2" Steel Plate on Distributor Pit for Saltwell Pumping Tank A-101
- 4) Structural calculations for A-101 cover plate dated: 2/25/00.

Documents for cover plates at SX-105:

- 1) ECN-638579, Replace 241-SX-105 Distributor Pit Cover block by Steel Plate
- 2) RPP-6162, Rev. 0, Radiological Design Review Screening- 2" Carbon Steel Cover Plate Installation at 241-SX-105 Pump Pit
- 3) USQ TF-99-0615, Rev. 1, 241-SX-105- Distributor Pit Cover Plate
- 4) Structural calculations for SX-105 cover plate dated: 5/30/00

Documents for cover plates at S-A, S-C, and SX-A Valve Pits:

- 1) ECN-659207, Replace East Cover Block on S-A Valve Pit by 3" Steel Plate
- 2) ECN-659208, Replace West Cover Block on S-C Valve Pit by 3" Steel Plate
- 3) ECN-659209, Replace West Cover Block on SX-A Valve Pit by 3" Steel Plate
- 4) RPP- 6161, Rev. 0, Radiological Design Review Screening-241-SX-105 Hose-in-Hose Transfer System for the IS Program (screening of S-A, S-C, and SX-A Valve Pits)
- 5) USQ TF-00-0370 Rev. 0, Replace Concrete Cover Blocks by Steel Cover Plates on S and SX Farm Pits
- 6) Structural Calculations and Design of 3" Cover Plate for 241-S-A Valve Pit dated: 6/8/00.
- 7) Structural Calculations and Design of 3" Cover Plate for 241-S-C Valve Pit dated: 6/7/00.
- 8) Structural Calculations and Design of 3" Cover Plate for 241-SX-A Valve Pit dated: 6/7/00.

The ECN provided the layout of a 2" steel shielding plate with slot holes, a FGM sensor hole and valve handle holes to match with holes in the existing 1" plate. A layout was also provided of new slot holes and a FGM sensor hole in the existing 1" plate. The ECN provided the details for the Safety Class Shield Plug to cover the 8"X6" hole for the FGM.

The USQ TF-99-0229, Rev. 5 provided the screening for the modification of the existing 1" cover plate and 2" additional shielding plate. This screening has all "No" or "N/A" responses, therefore it did not require a USQ Determination.

The Radiological Design Review Screening provided the Dose Rate of 139 mrem/hr over the existing 1" cover plate during the pumping operation. This high Dose rate will limit the personnel occupancy over the pump pit cover which is required during the life cycle of Saltwell Pumping for 241-U-109 Tank.

By analysis, the addition of a 2" steel carbon plate on top of a 1" existing plate will drop the dose rate to 21 mrem/hr, which will allow operations personnel to spend the required time during the lifecycle of the project, and will not result in exposure to > 1 person-REM.

By analysis, an adequate factor of safety exists for maximum stress and deflection of the 1" plate. Also the 2" plate is supported in the same way on the pit wall as the 1" plate.

All documentation is related to the Interim Stabilization program for Saltwell Pumping of Tank 241-U-109 in 241-U Tank Farm. All objectives of this review has been to establish the design approval for the 1" Safety Class cover plate and additional 2" shielding plate on 241-U-109 pump pit.

As the cover plates for 241-U-105 and 241-U-109 are identical, the factor of safety for bending stress and deflection are very similar. The radiological dose rate for 241-U-105 is 20 mrem/hr, compared to 21 mrem/hr for 241-U-109. From the analysis given here, the cover plates for 241-U-105 provide adequate safety function as per FSAR requirements.

To perform saltwell pumping the concrete cover blocks were replaced with steel cover plates for seven pits in addition to 241-U-109 and 241-U-105, namely: 241-U-103, 241-AX-101, 241-A-101, 241-SX-105, 241-S-A, 241-S-C, and 241-SX-A. The cover plates for six out of seven of these pits have a higher factor of safety for bending stress and deflection than U-109, and all have adequate safety factors. The radiological dose rates for the U-103, AX-101, and A-101 pump pits, are less than or equal to that of U-109, or 21 mrem/hr. The radiological dose rates for the SX-105 pump pit and the S-A, S-C, and SX-A valve pits were between 30 and 35 mrem/hr. Although this is a higher dose rate than U-109, these pits each have a shorter duration of pumping. Thus, their total radiation exposure is close to that of U-109 and within the exposure limit. From the analysis given here, the cover plates for 241-U-103, 241-AX-101, 241-A-101, 241-SX-105, 241-S-A, 241-S-C, and 241-SX-A provide adequate safety function and shielding as per FSAR requirements.

## 2.0 SUMMARY

The design review meeting was held on November 9, 1999. The meeting minutes are attached in Appendix A. Comments were recorded on Review Comment Records (Appendix B) and in the meeting minutes. All comments were dispositioned in the meeting and no further comments were made. It was concluded that the 1" existing cover plate with the additional 2" steel shielding plate will meet the requirements of the FSAR. The FSAR requirements have been met for spray leak knockdown and shielding for facility workers.

There are no outstanding action items remaining on the design for the existing cover plate or shielding plate for 241-U-109 Saltwell Pump Pit.

By comparing the data from analysis of 241-U-105 cover plates shown below, it is concluded that the 241-U-105 cover plates will meet the requirements of FSAR.

By comparing the data shown in the table below from analysis of 241-U-109 cover plates with 241-U-103, 241-AX-101, 241-A-101, 241-SX-105, 241-S-A, 241-S-C, and 241-SX-A, it is concluded that the additional seven cover plate designs will meet the requirements of FSAR.

## Design Review by Comparison

	Steel Plates:	Stress Safety Factor:	Deflection SF:	Radiation Dose Rate: (mrem/hr)
<b>Design Verified Cover Plate: U-109 Pump Pit ECN-648492</b>	<b>1"+2" thk. 7'-8"x7'-8"</b>	<b>10.092</b>	<b>1.172</b>	<b>21</b>
U-105 Pump Pit ECN-648484	1"+2" thk. 7'-8"x7'-7 1/2"	11.31	2.9	20
U-103 Pump Pit ECN-648470	1"+2" thk. 7'-8"x7'-8"	11.31	2.63	20
AX-101 Pump Pit ECN-659244	1"+2" thk. 6'-6"x11'-2"	7.963	4.732	21
A-101 Pump Pit ECN-652568	2" thk. 7'-0"x7'-6"	31.826	8.813	13
SX-105 Pump Pit ECN-638579	3" thk. 8'-0"x8'-2"	43.233	14.829	30*
S-A Valve Pit ECN-659207	3" thk. 8'-0"x11'-10"	39.26	19.573	35*
S-C Valve Pit ECN-659208	3" thk. 8'-0"x11'-10"	12.0	8.2	35*
SX-A Valve Pit ECN-659209	3" thk. 8'-0"x11'-10"	12.0	7.88	35*

\*The total Radiation dose for these pits is comparable to U-109. Although their radiological dose rate is higher than that of U-109, their duration of pumping is shorter.

Conclusion:

By comparing results given in the table U-105 cover plate has the better safety factors and it will provide adequate safety functions to knock down spray leak and limit the release of waste aerosol to the atmosphere. Duration of pumping for U-105 is 9 months compared to 24 months for U-109 so total Radiation dose will be less for U-105 and it will be within the exposure limit. Hence U-105 plate is acceptable by comparison.

Comparing the data for 241-U-109 with the seven additional pits, namely: 241-U-103, 241-AX-101, 241-A-101, 241-SX-105, 241-S-A, 241-S-C, and 241-SX-A, shows that adequate safety is provided and the total Radiation dose will be within the exposure limit. Thus, the new steel cover plates for these seven pits are acceptable by comparison.

### 3.0 DOCUMENTATION

#### Design Review Committee Members:

O. M. Jaka*	Design Agent
M. A. White*	Cognizant Engineer
M. R. Koch*	Cognizant Engineering Manager
W. F. Zuroff*	Design Authority
L. L. Penn*	Environmental
T. J. Volkman*	Quality Assurance
F. A. Zak*	Safety
K. J. Hull*	Cognizant Engineer (SST)
K. R. Ellingson*	Administration

#### \*Meeting Attendees

#### Documents:

Meeting Minutes, dated 11/9/99

Radiological Design Review Screening, 2" Carbon Steel Cover Plate Installation at 241-U-109 Pump Pit, dated

Unreviewed Safety Question (USQ) Screening/Determination, TF-99-0229, dated 10/28/99.

Design Calculations for Structural Integrity of existing 1" Plate for additional holes, dated

APPENDIX A

MEETING MINUTES  
DESIGN REVIEW MEETING ECN 648492  
241-U-109 COVER PLATE

<b>MEETING MINUTES</b>
------------------------

<b>SUBJECT: Design Review for the Modification of the Existing 1" Cover Plate and Adding a 2" Shielding Plate</b>
---

<b>TO:</b> Distribution	<b>Building:</b> 2704-HV/G-133	<b>Date:</b> 11/9/99
<b>FROM:</b> Interim Stabilization Engineering	<b>Chairman:</b> W. F. Zuroff	<b>Number Attending:</b> 9

## Design Review Committee Members:

O.M. Jaka*	Design Agent
M.A. White*	Cognizant Engineer
M.R. Koch*	Cognizant Engineering Manager
W.F. Zuroff*	Design Authority, Chairman
L.L. Penn*	Environmental
T.J. Volkman*	Quality Assurance
F.A. Zak*	Safety
K.J. Hull*	Cognizant Engineer (SST)
K.R. Ellingson*	Administration

## Attendees\*

This Design Review Meeting was called to review the proposed changes noted on ECN 648492, "Modification of the Existing 1" Cover Plate and Adding a 2"Shielding Plate on Tank 241-U-109, Saltwell Pump Pit"

Comments were received by Review Comment Record's (RCR) and these comments were dispositioned during the meeting to the satisfaction of the reviewers. Additional comments were taken during the meeting and are as follows:

**Koch****Question:**

Is the shielding plate sitting on all four sides of the pit?

**Disposition:**

Yes, is supported by 3 walls and adjacent cover block.

**Question:**

What is the structural strength?

**Disposition:**

Yes, Analysis treated as a dead load sitting on the plate. The 1" and 2" plate are supporting their own loads. The safety factor is adequate against yield strength and deflection.

**Question:**

Will the lifting bails be removed from the 1" plate?

**Disposition:**

No.

**Question:**

Will the 2" shielding plate have it's own hoisting rings?

**Disposition:**

Yes

**Question:**

Is there a painting diagram for the pit?

**Disposition:**

Yes

**Comment:**

Page 4 of ECN "CS Shielding Plate per detail "Z" change to detail "P".

**Disposition:**

Agreed, will correct

**Comment:**

Add bolt call out.

**Disposition:**

Agreed, will correct

**Question:**

Is the shielding plug 2" and the slot cover's 1"?

**Disposition:**

Yes

**Question:**

Should page 4 of this ECN be detail "P"?

**Disposition:**

Yes

**Comment:**

Specify that the holes will be plugged on the 2" plate after the hoist rings are removed.

**Disposition:**

Agreed

**Comment:**

Specify bolt length

**Disposition:**

Agreed

**Question:**

How far does the slot overhang the pit walls?

**Disposition:**

A little more than 6" in length.

**Question:**

Has the plug been fabricated yet?

**Disposition:**

Yes

**Zuroff**

**Comment:**

The Belhaven unit will be replaced by a remotely calibrated sensor.

**Question:**

Is the sheet metal box a cover for the existing slot?

**Disposition:**

Yes

**Question:**

Will the hole be covered by a safety class cover?

**Disposition:**

Yes, the cover will be modified to accept the sensor signal cable and the calibration gas tubing. This design review will serve as the design review for the modification of the S/C cover.

**Swaney**

**Comment:**

On Page 6 of ECN 648492, in the "Shielding Application Table" delete "Assembly X" and add "not required"

**Disposition:**

Agreed

**Comment:**

On page 4 of ECN 648492 remove the call out from the top left corner, it is repeated.

**Disposition:**

Agreed

**Hull**

**Question:**

Will you be using the existing slot?

**Disposition:**

No

**Question:**

Are the dimensions shown on pages 3, 4 and 5 of ECN 648492 correct?

**Disposition:**

Yes,

Page 3 of this ECN shows a dimension of 3'-10' for the center line of the riser.

Page 5 of this ECN shows a dimension of 3'-9' 7/8" for the 4" hole.

Page 4 of this ECN shows the 4" hole is not in the center of the cover plate.

**Question:**

Are all related ECNs work complete?

**Disposition:**

Yes

**Comment:**

Specify the bolt length.

**Disposition:**

Agree

APPENDIX B

REVIEW COMMENT RECORDS  
241-U-109 COVER PLATE





# REVIEW COMMENT RECORD (RCR)

1. Date <u>11/9/99</u> 3. Project No. <u>I.S.F.</u>	2. Review No. 4. Page 1 of 1	8. Organization/Group <u>SAFETY</u>	9. Location/Phone
5. Document Number(s)/Title(s) <u>64849Z</u> <u>ECN</u>	6. Program/Project/Building Number <u>U-109</u>	7. Reviewer <u>FA ZAK</u>	11. CLOSED
17. Comment Submittal Approval:  Organization Manager (Optional) _____ Date _____		10. Agreement with indicated comment disposition(s)  Reviewer/Point of Contract _____ Date _____ Author/Originator _____	
12. Item  1.	13. Comment(s)/Discrepancy(s) (Provide technical justification for the comment and detailed recommendation of the action required to correct/resolve the discrepancy/problem indicated.)  <p style="text-align: center; font-size: 1.2em;">No Comment</p>	14. Hold Point	15. Disposition (Provide justification if NOT accepted.)  16. Status









# REVIEW COMMENT RECORD (RCR)

1. Date <u>11/9/99</u>		2. Review No.	
3. Project No.		4. Page 1 of 1	
5. Document Number(s)/Title(s)  <u>ECN 648492</u>	6. Program/Project/Building Number	7. Reviewer  <u>LUCINDA L. PENAL</u>	8. Organization/Group <u>REG. COMPLIANCE ENVIRONMENTAL ENG.</u>
9. Location/Phone <u>2704 HV</u>		10. Agreement with indicated comment disposition(s)  11. CLOSED	
12. Comment(s)/Discrepancy(s) (Provide technical justification for the comment and detailed recommendation of the action required to correct/resolve the discrepancy/problem indicated.)  <u>No COMMENTS - ACCEPT AS IS</u>		13. Comment(s)/Discrepancy(s) (Provide technical justification for the comment and detailed recommendation of the action required to correct/resolve the discrepancy/problem indicated.)	
14. Hold Point	15. Disposition (Provide justification if NOT accepted.)		
16. Status	17. Comment Submittal Approval:		

_____ Organization Manager (Optional)	_____ Reviewer/Point of Contract	_____ Author/Originator
_____ Date	_____ Date	_____ Author/Originator

_____ Reviewer/Point of Contact	_____ Date	_____ Author/Originator
------------------------------------	---------------	----------------------------

RPP-5416, Rev. 2

APPENDIX C

STRUCTURAL CALCULATIONS

241-U-109

Determine factors of safety for 241-U-109 pump pit cover plate design (ECN-648492) with respect to maximum allowable deflection and bending stress:

**ASSUMPTIONS -**

Neglect plate penetrations (largest penetration dia (6") << plate width)

Plate is simply supported on three edges, one edge free (worst case)

Plate is uniformly loaded over entire plate

$$a := 92 \text{ in} \quad (\text{Width of plate}) \quad b := 92 \text{ in} \quad (\text{Length of plate - free side})$$

$$t_{\text{steel}} := 1 \text{ in} \quad (\text{Thickness of plate})$$

$$A := a \cdot b \quad A = 8.464 \cdot 10^3 \text{ in}^2 \quad (\text{Area of plate})$$

$$V_{\text{steel}} := a \cdot b \cdot t_{\text{steel}} \quad V_{\text{steel}} = 8.464 \cdot 10^3 \text{ in}^3 \quad (\text{Volume of plate})$$

$$\rho_{\text{steel}} := 487 \frac{\text{lb}}{\text{ft}^3} \quad (\text{Density of ASTM A36 steel}) \quad E := 29 \cdot 10^6 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Modulus of elasticity, ASTM A36 steel})$$

$$W_{\text{steel}} := \rho_{\text{steel}} \cdot V_{\text{steel}} \quad W_{\text{steel}} = 2.385 \cdot 10^3 \text{ lb} \quad (\text{Weight of steel plate})$$

$$q_{\text{steel}} := \frac{W_{\text{steel}}}{A} \quad q_{\text{steel}} = 0.282 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Distributed dead load due to weight of steel plate})$$

Use Uniformly distributed live load = 50 lbs/sq ft = 0.3472 lb/sq ft

$$q_{\text{udl}} := 0.3472 \frac{\text{lb}}{\text{in}^2} \quad q_{\text{total}} := q_{\text{steel}} + q_{\text{udl}}$$

$$q_{\text{total}} = 0.629 \text{ lb} \cdot \text{in}^{-2}$$

$$\text{adivb} := \begin{bmatrix} .5 \\ .667 \\ 1.0 \\ 1.5 \\ 2.0 \\ 4.0 \end{bmatrix} \quad \beta := \begin{bmatrix} .36 \\ .45 \\ .67 \\ .77 \\ .79 \\ .80 \end{bmatrix} \quad \alpha := \begin{bmatrix} .080 \\ .106 \\ .140 \\ .160 \\ .165 \\ .167 \end{bmatrix} \quad \text{From Roark, Table 26, Pg.461 Case 2b.}$$

Use curve fitting to determine  $\beta$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \beta) \quad \beta := \text{interp}(\text{fit}, \text{adivb}, \beta, \frac{a}{b}) \quad \beta = 0.67$$

Originator m. Omar Jaka  
Omar Jaka

Date 11/9/95

Checked by: Mike A. White

Date 11/9/95

**Calculate maximum stress and safety factor:**

$$\sigma_{\max} := \frac{\beta \cdot q_{\text{total}} \cdot b^2}{t_{\text{steel}}^2} \quad \sigma_{\max} = 3.567 \cdot 10^3 \text{ lb} \cdot \text{in}^{-2} \quad \sigma_{\text{yield}} := 36000 \text{ lb} \cdot \text{in}^{-2} \quad (\text{ASTM A36})$$

$$\sigma_{\text{allow.}} := .6 F_y \quad (\text{AISC F1-5})$$

$$\text{Gives } SF_{\min} := 1.666$$

$$SF := \frac{\sigma_{\text{yield}}}{\sigma_{\max}} \quad SF = 10.092 \quad \underline{\underline{SF_{\min} = 1.66, SF \gg SF_{\min}, \text{O.K.}}}$$

**Calculate maximum deflection and safety factor:**Use curve fitting to determine  $\alpha$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \alpha) \quad \alpha := \text{interp}\left(\text{fit}, \text{adivb}, \alpha, \frac{a}{b}\right) \quad \alpha = 0.14$$

UBC Section 1608: any structural member deflection shall not exceed L/360 (Table 16-D)

Max Deflection := L/360 = 92/360 = 0.255 in

$$y_{\max} := \frac{-\alpha \cdot q_{\text{total}} \cdot b^4}{E \cdot t_{\text{steel}}^3} \quad y_{\max} = -0.218 \text{ in} \quad \underline{\underline{< 0.255 \text{ in, O.K.}}}$$

Originator: m. Omar Jaka Date: 11/9/99 Checked by: MA White Date: 11/9/99  
 Omar Jaka Mike A. White

APPENDIX D

STRUCTURAL CALCULATIONS

241-U-102

241-U-103

241-U-105

241-U-107

241-U-108

241-U-111

Note: Appendix D assumes structural calculations for the worst case U Farm pump

**ENGINEERING CHANGE NOTICE  
CONTINUATION SHEET**

**H-2-73720 SH 1, REV 2, ADD JET PUMP/JUMPER INSTALLATION AND COVER PLATE MODIFICATION STATUS TABLE AS SHOWN:**

TANK NO.	JET PUMP/JUMPER INSTALLATION AND COVER PLATE MODIFICATION STATUS
241-U-102	NOT INSTALLED
241-U-103	NOT INSTALLED
241-U-105	NOT INSTALLED
241-U-106	NOT INSTALLED
241-U-107	NOT INSTALLED
241-U-108	NOT INSTALLED
241-U-109	NOT INSTALLED
241-U-111	NOT INSTALLED

**NOTE – THE FOLLOWING CALCULATIONS ARE FOR INFORMATION ONLY,  
DO NOT INCORPORATE ON DRAWINGS**

**Determine factors of safety for worst case 241-U pump pit cover plate design with respect to maximum allowable deflection and bending stress, considering stress concentration resulting from valve wrench penetrations:**

**ASSUMPTIONS -**

Plate is simply supported on three edges, one edge free (worst case)

Plate is uniformly loaded over entire plate

'Worst Case' is defined as "COVER PLATE PLAN A & D" due to potential for no support on one side and valve handle penetration near center of plate (location of greatest bending stress)

$a := 91.5 \text{ in}$  (Width of plate)       $b := 92 \text{ in}$  (Length of plate - free side)

$t_{\text{steel}} := 1 \text{ in}$  (Thickness of plate)

$A := a \cdot b$        $A = 8.418 \cdot 10^3 \text{ in}^2$  (Area of plate)

$V_{\text{steel}} := a \cdot b \cdot t_{\text{steel}}$        $V_{\text{steel}} = 8.418 \cdot 10^3 \text{ in}^3$  (Volume of plate)

$\rho_{\text{steel}} := 487 \frac{\text{lb}}{\text{ft}^3}$  (Density of ASTM A36 steel)       $E := 29 \cdot 10^6 \text{ lb} \cdot \text{in}^{-2}$  (Modulus of elasticity, ASTM A36 steel)

$W_{\text{steel}} := \rho_{\text{steel}} \cdot V_{\text{steel}}$        $W_{\text{steel}} = 2.372 \cdot 10^3 \text{ lb}$  (Weight of steel plate)

Originator: M. A. White      Date: 3/17/99      Checked By: J. S. Boettger      Date: 3/18/99

# ENGINEERING CHANGE NOTICE CONTINUATION SHEET

ECN: 651971

Page 19 of 20

Date: 3/11/99

$$q_{\text{steel}} := \frac{W_{\text{steel}}}{A} \quad q_{\text{steel}} = 0.282 \cdot \text{lb} \cdot \text{in}^{-2} \text{ (Distributed dead load due to weight of steel plate)}$$

$$\text{adivb} := \begin{bmatrix} .5 \\ .667 \\ 1.0 \\ 1.5 \\ 2.0 \\ 4.0 \end{bmatrix} \quad \beta := \begin{bmatrix} .36 \\ .45 \\ .67 \\ .77 \\ .79 \\ .80 \end{bmatrix} \quad \alpha := \begin{bmatrix} .080 \\ .106 \\ .140 \\ .160 \\ .165 \\ .167 \end{bmatrix}$$

From Roark, Table 26, Pg.461  
Case 2b.Use curve fitting to determine  $\beta$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \beta) \quad \beta := \text{interp}\left(\text{fit}, \text{adivb}, \beta, \frac{a}{b}\right) \quad \beta = 0.667$$

Calculate bending stress:

$$\sigma_b := \frac{\beta \cdot q_{\text{steel}} \cdot b^2}{t_{\text{steel}}^2} \quad \sigma_b = 1.592 \cdot 10^3 \cdot \text{lb} \cdot \text{in}^{-2} \quad \sigma_{\text{yield}} := 36000 \text{ lb} \cdot \text{in}^{-2} \text{ (ASTM A36)}$$

From *Advanced Mechanics of Materials*, 4th Ed., Boresi and Sidebottom, since width of plate is much greater than the diameter of the hole ( $92'' \gg 4''$ ), for case of symmetrical plate, uniformly loaded, Stress concentration factor will be  $Sc=2$  (pg.533, 570).

Calculate stress increased by concentration factor  $Sc$ :

$$Sc := 2 \quad \sigma_{Sc} := \sigma_b \cdot Sc \quad \sigma_{Sc} = 4.584 \cdot 10^3 \text{ lb} \cdot \text{ft}^{-2}$$

$$SF := \frac{\sigma_{\text{yield}}}{\sigma_{Sc}} \quad SF = 11.31 \quad \mathbf{SF > 2, O.K.}$$

Use curve fitting to determine  $\alpha$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \alpha) \quad \alpha := \text{interp}\left(\text{fit}, \text{adivb}, \alpha, \frac{a}{b}\right) \quad \alpha = 0.14$$

Calculate maximum deflection and safety factor:

$$y_{\text{max}} := \frac{-\alpha \cdot q_{\text{steel}} \cdot b^4}{E \cdot t_{\text{steel}}^3} \quad y_{\text{max}} = -0.097 \text{ in}$$

From US Steel Handbook, page P-39, deflection should be held to  $< 1/100$  of span.

$$\frac{a}{100} = 0.915 \text{ in} \quad \mathbf{.097'' \ll .915'', O.K.}$$

Originator: M. A. White Date: 3/17/99 Checked By: J. S. Boettger Date: 3/18/99

# ENGINEERING CHANGE NOTICE CONTINUATION SHEET

ECN: 651971

Page 20 of 20

Date: 3/11/99

Determine factors of safety with 1" thick lead shielding distributed evenly over plate surface:

$$\rho_{\text{lead}} := 710 \frac{\text{lb}}{\text{ft}^3} \quad (\text{Density of lead used for shielding})$$

$$t_{\text{lead}} := 1 \text{ in} \quad (\text{Thickness of lead required})$$

$$V_{\text{lead}} := a \cdot b \cdot t_{\text{lead}} \quad V_{\text{lead}} = 4.872 \text{ ft}^3 \quad (\text{Volume of lead plate})$$

$$W_{\text{lead}} := \rho_{\text{lead}} \cdot V_{\text{lead}} \quad W_{\text{lead}} = 3.45910^3 \text{ lb} \quad (\text{Weight of lead plate})$$

$$q_{\text{lead}} := \frac{W_{\text{lead}}}{A} \quad q_{\text{lead}} = 0.411 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Loading due to lead plate})$$

$$\rho_{\text{sheet}} := 487 \frac{\text{lb}}{\text{ft}^3} \quad (\text{Density of sheet used to cover lead shielding})$$

$$t_{\text{sheet}} := 2 \cdot 0.125 \text{ in} \quad (\text{Thickness of sheet (11 Ga.) x top \& bottom})$$

$$V_{\text{sheet}} := a \cdot b \cdot t_{\text{sheet}} \quad V_{\text{sheet}} = 1.218 \text{ ft}^3 \quad (\text{Volume of sheet})$$

$$W_{\text{sheet}} := \rho_{\text{sheet}} \cdot V_{\text{sheet}} \quad W_{\text{sheet}} = 593.109 \text{ lb} \quad (\text{Weight of sheet})$$

$$q_{\text{sheet}} := \frac{W_{\text{sheet}}}{A} \quad q_{\text{sheet}} = 0.07 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Loading due to sheet})$$

$$\Sigma q := q_{\text{lead}} + q_{\text{steel}} + q_{\text{sheet}} \quad \Sigma q = 0.763 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Total distributed load on plate})$$

Assuming no friction between lead and steel plates-

Calculate bending stress w/lead:

$$\sigma_{\text{bl}} := \frac{\beta \cdot \Sigma q \cdot b^2}{t_{\text{steel}}^2} \quad \sigma_{\text{bl}} = 4.31 \cdot 10^3 \text{ lb} \cdot \text{in}^{-2} \quad \sigma_{\text{yield}} := 36000 \text{ lb} \cdot \text{in}^{-2} \quad (\text{ASTM A36})$$

Calculate stress increased by concentration factor  $S_c$ , w/lead :

$$S_c := 2 \quad \sigma_{\text{Sc1}} := \sigma_{\text{bl}} \cdot S_c \quad \sigma_{\text{Sc1}} = 1.241 \cdot 10^6 \text{ lb} \cdot \text{ft}^{-2}$$

$$SF := \frac{\sigma_{\text{yield}}}{\sigma_{\text{Sc1}}} \quad SF = 4.177 \quad \mathbf{SF > 2, O.K.}$$

calculate maximum deflection and safety factor:

$$y_{\text{max}} := \frac{-\alpha \cdot \Sigma q \cdot b^4}{E \cdot t_{\text{steel}}^3} \quad y_{\text{max}} = -0.263 \text{ in} \quad \mathbf{.263" < .915", O.K.}$$

Originator: M. A. White

M. A. White

Date: 3/17/99Checked By: J. S. Boettger

J. S. Boettger

Date: 3/18/99

RPP-5416, Rev. 2

APPENDIX E

STRUCTURAL CALCULATIONS  
241-AX-101

Determine factors of safety for 241-AX-101 Distributor Pit cover plate design (ECN-657823) with respect to maximum allowable bending stress and deflection:

**ASSUMPTIONS -**

Neglect plate penetrations (largest penetration 3"x13" << plate width)  
 Plate is simply supported on three edges, one edge free (worst case)  
 Plate is uniformly loaded over entire plate

$$a := 78.00 \text{ in} \quad (\text{Width of plate}) \quad b := 134 \text{ in} \quad (\text{Length of plate - free side})$$

$$t_{\text{steel}} := 1 \text{ in} \quad (\text{Thickness of plate, The worst case}) \quad (2" \text{ plate will support itself})$$

$$A := a \cdot b \quad A = 1.045 \cdot 10^4 \cdot \text{in}^2 \quad (\text{Area of plate})$$

$$V_{\text{steel}} := a \cdot b \cdot t_{\text{steel}} \quad V_{\text{steel}} = 1.045 \cdot 10^4 \cdot \text{in}^3 \quad (\text{Volume of plate})$$

$$\rho_{\text{steel}} := 487 \frac{\text{lb}}{\text{ft}^3} \quad (\text{Density of ASTM A36 steel}) \quad E := 29 \cdot 10^6 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Modulus of elasticity, ASTM A36 steel})$$

$$W_{\text{steel}} := \rho_{\text{steel}} \cdot V_{\text{steel}} \quad W_{\text{steel}} = 2.946 \cdot 10^3 \text{ lb} \quad (\text{Weight of steel plate})$$

$$q_{\text{steel}} := \frac{W_{\text{steel}}}{A} \quad q_{\text{steel}} = 0.282 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Distributed dead load due to weight of steel plate})$$

$$q_{\text{liveload}} := 50 \frac{\text{lb}}{\text{ft}^2} \quad q_{\text{liveload}} := .35 \frac{\text{lb}}{\text{in}^2} \quad q_{\text{total}} := q_{\text{steel}} + q_{\text{liveload}}$$

$$q_{\text{total}} = 90.983 \text{ lb} \cdot \text{ft}^{-2}$$

$\text{adivb} := \begin{bmatrix} .5 \\ .667 \\ 1.0 \\ 1.5 \\ 2.0 \\ 4.0 \end{bmatrix}$	$\beta := \begin{bmatrix} .36 \\ .45 \\ .67 \\ .77 \\ .79 \\ .80 \end{bmatrix}$	$\alpha := \begin{bmatrix} .080 \\ .106 \\ .140 \\ .160 \\ .165 \\ .167 \end{bmatrix}$	From Roark, Ed. 6, Table 26, Case 2a, Pg.461
--	---	--	---

Use curve fitting to determine  $\beta$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \beta) \quad \beta := \text{interp}\left(\text{fit}, \text{adivb}, \beta, \frac{a}{b}\right) \quad \beta = 0.398$$

Calculate maximum stress and safety factor:

$$\sigma_{\text{max}} := \frac{\beta \cdot q_{\text{total}} \cdot b^2}{t_{\text{steel}}^2} \quad \sigma_{\text{max}} = 6.51 \cdot 10^5 \text{ lb} \cdot \text{ft}^{-2} \quad \sigma_{\text{yield}} := 36000 \text{ lb} \cdot \text{in}^{-2} \quad (\text{ASTM A36})$$

$$\text{SF} := \frac{\sigma_{\text{yield}}}{\sigma_{\text{max}}} \quad \text{SF} = 7.963 \quad \underline{\text{SFmin}=5, \text{SF}>\text{SFMIN}, \text{O.K.}}$$

Originator: m. b. Omar Jaka Date: 3/4/00  
 Omar Jaka

Checked by: J. S. Boettger Date: 3/14/00  
 J. S. Boettger

Calculate maximum deflection and safety factor  
using 2" thick plate which is on top:

Use curve fitting to determine  $\alpha$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \alpha) \quad \alpha := \text{interp}\left(\text{fit}, \text{adivb}, \alpha, \frac{a}{b}\right) \quad \alpha = 0.094$$

$$t_{\text{steel}} := 2 \text{ in}$$

UBC section 1608, table 16-D deflection not to exceed L/360: (L=Length of span)

$$y_{\text{allow}} := \frac{L}{360} = \frac{140}{360} = 0.389$$

$$y_{\text{allow}} := -0.389 \text{ in}$$

$$y_{\text{max}} := \frac{-\alpha \cdot q_{\text{total}} \cdot b^4}{E \cdot t_{\text{steel}}^3} \quad y_{\text{max}} = -0.082 \text{ in} \quad \ll 0.389 \text{ in, O.K.}$$

$$\text{SF} := \frac{y_{\text{allow}}}{y_{\text{max}}}$$

$$\text{SF} = 4.732 \quad \text{Good}$$

Originator: m. Omar Jaka Date: 3/4/00  
Omar Jaka

Checked by: J. S. Boettger Date: 3/14/00  
J. S. Boettger

## ANALYTICAL CALCULATIONS

Page 3 of 3Subject 241-AX-101 DISTRIBUTOR PIT COVER PLATESOriginator OMAR JAKA Date 3/3/2000Checker J. Britton Date 3/14/2000CHECK THE HOIST RINGS & 3/4"  $\Phi$  CONNECTION BOLTS:

1. WT. OF 1" PLATE =  $\frac{1}{12} \times 6.5 \times 11.16 \times 490 = 2962$  #

2. WT. OF 2" PLATE =  $\frac{2}{12} \times 6.5 \times 11.16 \times 490 = 5924$  #

(USING UNIT WT. OF STEEL = 490 LBS/FT<sup>3</sup>)  $\frac{8886}{\text{#}}$

1. CHECK HOIST RINGS:

USING McMASTER-CARR HOIST RINGS 3052T67 (CATALOG LOG)

WORK LOAD LIMIT = 10,000 lbs.

4 - HOIST RINGS CAPACITY = 40,000 lbs.

WORST CASE 2 - HOIST RINGS SUPPORTING THE PLATES = 20,000 lbs.

 $> 8886$  lbsHENCE 4 - HOIST RINGS 3052T67 ARE ADEQUATE  $\therefore$  O.K.2. CHECK 8 - 3/4"  $\Phi$  A307 CR. B BOLTS HOLDING 2 PLATES TOGETHER:

(AISC 8TH EDITION) PAGES 4-344-5)

3/4"  $\Phi$  A 307 THREADED BOLT SHEAR CAPACITY = 4.4 K / BOLT

" " " " TENSION " = 8.8 K / BOLT

(a) CHECK FOR TENSION IF 1" PLATE DEFLECTS (WORST CASE):

TENSION = WT. OF 1" PLATE = 2962 # = 2.962 K &lt; 8 x 8.8 K

 $\therefore$  O.K.(b) CHECK FOR SHEAR DURING SEISMIC EVENT:

2" PLATE SLIDING OVER 1" PLATE

\* AISC 8TH ED.  
PAGE 5-15

SHEARING FORCE = WT. OF PLATE + \* IMPACT (50%)

= 5924 + 0.5 x 5924

= 8886 lbs

= 8.89 K &lt; 8 BOLTS x 4.4 K / BOLT = 35.2 K

 $\therefore$  O.K. $\therefore$  8 - 3/4"  $\Phi$  A-307 BOLTS ARE ADEQUATE

RPP-5416, Rev. 2

APPENDIX F

STRUCTURAL CALCULATIONS

241-A-101

Determine factors of safety for 241-A-101 pump pit cover plate design (ECN-652568) with respect to maximum allowable deflection and bending stress:

**ASSUMPTIONS -**

Neglect plate penetrations (largest penetration dia (8"x6") << plate width)  
 Plate is simply supported on four edges, Plate is uniformly loaded over entire plate

$a := 90.00 \text{ in}$  (Width of plate)     $b := 84.00 \text{ in}$  (All edges simply supported)

$t_{\text{steel}} := 2 \text{ in}$  (Thickness of plate)

$A := a \cdot b$      $A = 52.5 \text{ ft}^2$  (Area of plate)

$V_{\text{steel}} := a \cdot b \cdot t_{\text{steel}}$      $V_{\text{steel}} = 8.75 \text{ ft}^3$  (Volume of plate)

$\rho_{\text{steel}} := 487 \frac{\text{lb}}{\text{ft}^3}$  (Density of ASTM A36 steel)     $E := 29 \cdot 10^6 \text{ lb-in}^{-2}$  (Modulus of elasticity, ASTM A36 steel)

$W_{\text{steel}} := \rho_{\text{steel}} \cdot V_{\text{steel}}$      $W_{\text{steel}} = 4.261 \cdot 10^3 \text{ lb}$  (Weight of steel plate)

$q_{\text{steel}} := \frac{W_{\text{steel}}}{A}$      $q_{\text{steel}} = 81.167 \text{ lb-ft}^{-2}$  (Distributed dead load due to weight of steel plate)

$q_{\text{liveload}} := 50 \frac{\text{lb}}{\text{ft}^2}$      $q_{\text{liveload}} := .35 \frac{\text{lb}}{\text{in}^2}$      $q_{\text{total}} := q_{\text{steel}} + q_{\text{liveload}}$

$q_{\text{total}} = 131.567 \text{ lb-ft}^{-2}$

From Roark, Ed. 6, Table 26, Case 2a, Pg.461

$\text{adivb} :=$	1.0	$\beta :=$	0.2874	$\alpha :=$	0.0444	$\gamma :=$	0.420
	1.2		0.3762		0.0616		0.455
	1.4		0.4530		0.0770		0.478
	1.6		0.5172		0.0906		0.491
	1.8		0.5688		0.1017		0.499
	2.0		0.6102		0.1110		0.503
	3.0		0.7134		0.1335		0.505
	4.0		0.7410		0.1400		0.502
	5.0		0.7476		0.1417		0.501
	1000.0		0.7500		0.1421		.500

Use curve fitting to determine  $\beta$ :

$\text{fit} := \text{cspline}(\text{adivb}, \beta)$      $\beta := \text{interp}\left(\text{fit}, \text{adivb}, \beta, \frac{a}{b}\right)$      $\beta = 0.32$

Originator m. b. Omar Jaka Date 1/13/00    Checked by D.D. Wiggins Date 02/25/00  
 Omar Jaka    D.D. Wiggins

Calculate maximum stress and safety factor:

$$\sigma_{\max} := \frac{\beta \cdot q_{\text{total}} \cdot b^2}{t_{\text{steel}}^2} \quad \sigma_{\max} = 7.437 \cdot 10^4 \text{ lb}\cdot\text{ft}^{-2} \quad \sigma_{\text{yield}} := 36000 \text{ lb}\cdot\text{in}^{-2} \quad (\text{ASTM A36})$$

$$\text{SF} := \frac{\sigma_{\text{yield}}}{\sigma_{\max}} \quad \text{SF} = 69.703 \quad \underline{\text{SFmin}=5, \text{SF}>\text{SFMIN}, \text{O.K.}}$$

Calculate maximum deflection and safety factor: :

Use curve fitting to determine  $\alpha$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \alpha) \quad \alpha := \text{interp}\left(\text{fit}, \text{adivb}, \alpha, \frac{a}{b}\right) \quad \alpha = 0.051$$

$$t_{\text{steel}} := 2 \text{ in}$$

UBC section 1608, table 16-D deflection not to exceed  $L/360$ : (L=Length of span)

$$y_{\text{allow}} := \frac{L}{360} \quad \frac{140}{360} = 0.389$$

$$y_{\text{allow}} = 0.389 \text{ in}$$

$$y_{\max} := \frac{-\alpha \cdot q_{\text{total}} \cdot b^4}{E \cdot t_{\text{steel}}^3} \quad y_{\max} = -9.954 \cdot 10^{-3} \text{ in} \quad \underline{\ll 0.389 \text{ in}, \text{O.K.}}$$

$$\text{SF} := \frac{y_{\text{allow}}}{y_{\max}}$$

$$\text{SF} = 39.079 \quad \text{Good}$$

Originator: m. Omar Jaka Date: 1/13/00 Checked by: Dirk Wiggins Date: 12/25/00  
 Omar Jaka D. D. Wiggins

**CONSERVATIVE CALCULATION WITH 3-SIDE SUPPORTED**

Determine factors of safety for 241-A101 pump pit cover plate design (ECN-652568) with respect to maximum allowable deflection and bending stress:

**ASSUMPTIONS -**

Neglect plate penetrations (largest penetration dia (3"x9") << plate width)

Plate is simply supported on three edges, one edge free (worst case)

Plate is uniformly loaded over entire plate

$$a := 90.00 \text{ in} \quad (\text{Width of plate}) \quad b := 84.00 \text{ in} \quad (\text{Length of plate - free side})$$

$$t_{\text{steel}} := 2 \text{ in} \quad (\text{Thickness of plate})$$

$$A := a \cdot b \quad A = 52.5 \text{ ft}^2 \quad (\text{Area of plate})$$

$$V_{\text{steel}} := a \cdot b \cdot t_{\text{steel}} \quad V_{\text{steel}} = 8.75 \text{ ft}^3 \quad (\text{Volume of plate})$$

$$\rho_{\text{steel}} := 487 \frac{\text{lb}}{\text{ft}^3} \quad (\text{Density of ASTM A36 steel}) \quad E := 29 \cdot 10^6 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Modulus of elasticity, ASTM A36 steel})$$

$$W_{\text{steel}} := \rho_{\text{steel}} \cdot V_{\text{steel}} \quad W_{\text{steel}} = 4.261 \cdot 10^3 \text{ lb} \quad (\text{Weight of steel plate})$$

$$q_{\text{steel}} := \frac{W_{\text{steel}}}{A} \quad q_{\text{steel}} = 81.167 \text{ lb} \cdot \text{ft}^{-2} \quad (\text{Distributed dead load due to weight of steel plate})$$

$$q_{\text{liveload}} := 50 \frac{\text{lb}}{\text{ft}^2} \quad q_{\text{liveload}} := .35 \frac{\text{lb}}{\text{in}^2} \quad q_{\text{total}} := q_{\text{steel}} + q_{\text{liveload}}$$

$$q_{\text{total}} = 131.567 \text{ lb} \cdot \text{ft}^{-2}$$

$$\text{adivb} := \begin{bmatrix} .5 \\ .667 \\ 1.0 \\ 1.5 \\ 2.0 \\ 4.0 \end{bmatrix} \quad \beta := \begin{bmatrix} .36 \\ .45 \\ .67 \\ .77 \\ .79 \\ .80 \end{bmatrix} \quad \alpha := \begin{bmatrix} .080 \\ .106 \\ .140 \\ .160 \\ .165 \\ .167 \end{bmatrix}$$

From Roark, Ed. 6, Table 26, Case 2a, Pg.461

Use curve fitting to determine  $\beta$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \beta) \quad \beta := \text{interp}(\text{fit}, \text{adivb}, \beta, \frac{a}{b}) \quad \beta = 0.702$$

Calculate maximum stress and safety factor:

$$\sigma_{\text{max}} := \frac{\beta \cdot q_{\text{total}} \cdot b^2}{t_{\text{steel}}^2} \quad \sigma_{\text{max}} = 1.629 \cdot 10^5 \text{ lb} \cdot \text{ft}^{-2} \quad \sigma_{\text{yield}} := 36000 \text{ lb} \cdot \text{in}^{-2} \quad (\text{ASTM A36})$$

$$\text{SF} := \frac{\sigma_{\text{yield}}}{\sigma_{\text{max}}} \quad \text{SF} = 31.826 \quad \text{SFmin}=5, \text{SF}>\text{SFMIN}, \text{O.K.}$$

Originator: m. Omar Jaka Date: 1/13/00 Checked by: Dick Wiggins Date: 02/25/00  
Omar Jaka D. D. Wiggins

Calculate maximum deflection and safety factor:

Use curve fitting to determine  $\alpha$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \alpha) \quad \alpha := \text{interp}\left(\text{fit}, \text{adivb}, \alpha, \frac{a}{b}\right) \quad \alpha = 0.145$$

$$t_{\text{steel}} := 2 \text{ in}$$

UBC section 1608, table 16-D deflection not to exceed  $L/360$ : (L=Length of span)

$$y_{\text{allow}} := \frac{b}{360} = \frac{90}{360} = 0.25$$

$$y_{\text{allow}} := -0.25 \text{ in}$$

$$y_{\text{max}} := \frac{-\alpha \cdot q_{\text{total}} \cdot b^4}{E \cdot t_{\text{steel}}^3} \quad y_{\text{max}} = -0.028 \text{ in} \quad \ll 0.25 \text{ in, O.K.}$$

$$\text{SF} := \frac{y_{\text{allow}}}{y_{\text{max}}}$$

$$\text{SF} = 8.813 \quad \text{Good}$$

Originator: m. Omar Jaka Date: 1/13/00 Checked by: D. D. Wiggins Date: 02/25/00  
 Omar Jaka D. D. Wiggins

RPP-5416, Rev. 2

APPENDIX G

STRUCTURAL CALCULATIONS  
241-SX-105

**CONSERVATIVE CALCULATION WITH 3-SIDE SUPPORTED**

Determine factors of safety for 241-SX-105 Distributor pit cover plate design (ECN-638579) with respect to maximum allowable deflection and bending stress:

**ASSUMPTIONS -**

Neglect plate penetrations (largest penetration dia (8"x6") << plate width)

Plate is simply supported on three edges, one edge free (worst case)

Plate is uniformly loaded over entire plate

$$a := 98.00 \text{ in} \quad (\text{Width of plate}) \quad b := 96.00 \text{ in} \quad (\text{Length of plate - free side})$$

$$t_{\text{steel}} := 3 \text{ in} \quad (\text{Thickness of plate})$$

$$A := a \cdot b \quad A = 65.333 \text{ ft}^2 \quad (\text{Area of plate})$$

$$V_{\text{steel}} := a \cdot b \cdot t_{\text{steel}} \quad V_{\text{steel}} = 16.333 \text{ ft}^3 \quad (\text{Volume of plate})$$

$$\rho_{\text{steel}} := 487 \frac{\text{lb}}{\text{ft}^3} \quad (\text{Density of ASTM A36 steel}) \quad E := 29 \cdot 10^6 \text{ lb} \cdot \text{in}^{-2} \quad (\text{Modulus of elasticity, ASTM A36 steel})$$

$$W_{\text{steel}} := \rho_{\text{steel}} \cdot V_{\text{steel}} \quad W_{\text{steel}} = 7.954 \times 10^3 \text{ lb} \quad (\text{Weight of steel plate})$$

$$q_{\text{steel}} := \frac{W_{\text{steel}}}{A} \quad q_{\text{steel}} = 121.75 \text{ lb ft}^{-2} \quad (\text{Distributed dead load due to weight of steel plate})$$

$$q_{\text{liveload}} := 50 \frac{\text{lb}}{\text{ft}^2} \quad q_{\text{liveload}} := .35 \frac{\text{lb}}{\text{in}^2} \quad q_{\text{total}} := q_{\text{steel}} + q_{\text{liveload}}$$

$$q_{\text{total}} = 172.15 \text{ lb ft}^{-2}$$

$$\text{adivb} := \begin{pmatrix} .5 \\ .667 \\ 1.0 \\ 1.5 \\ 2.0 \\ 4.0 \end{pmatrix} \quad \beta := \begin{pmatrix} .36 \\ .45 \\ .67 \\ .77 \\ .79 \\ .80 \end{pmatrix} \quad \alpha := \begin{pmatrix} .080 \\ .106 \\ .140 \\ .160 \\ .165 \\ .167 \end{pmatrix} \quad \text{From Roark, Ed. 6, Table 26, Case 2a, Pg. 461}$$

Use curve fitting to determine  $\beta$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \beta) \quad \beta := \text{interp}\left(\text{fit}, \text{adivb}, \beta, \frac{a}{b}\right) \quad \beta = 0.68$$

Calculate maximum stress and safety factor:

$$\sigma_{\text{max}} := \frac{\beta \cdot q_{\text{total}} \cdot b^2}{t_{\text{steel}}^2} \quad \sigma_{\text{max}} = 1.199 \times 10^5 \text{ lb ft}^{-2} \quad \sigma_{\text{yield}} := 36000 \text{ lb} \cdot \text{in}^{-2} \quad (\text{ASTM A36})$$

$$\text{SF} := \frac{\sigma_{\text{yield}}}{\sigma_{\text{max}}} \quad \text{SF} = 43.233 \quad \text{SFmin} = 5, \text{ SF} > \text{SFmin}, \text{ O.K.}$$

Originator: M. Omar Jaka Date: 5/23/00 Checked by: D. K. DeFord Date: 5/30/00  
Omar Jaka D. K. DeFord

Calculate maximum deflection and safety factor:

Use curve fitting to determine  $\alpha$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \alpha) \quad \alpha := \text{interp}\left(\text{fit}, \text{adivb}, \alpha, \frac{a}{b}\right) \quad \alpha = 0.141$$

$$t_{\text{steel}} := 3 \text{ in}$$

UBC section 1608, table 16-D deflection not to exceed  $L/360$ : (L=Length of span)

$$y_{\text{allow}} := \frac{b}{360} = \frac{98}{360} = 0.272$$

$$y_{\text{allow}} := .272 \text{ in}$$

$$y_{\text{max}} := \frac{-\alpha \cdot q_{\text{total}} \cdot b^4}{E \cdot t_{\text{steel}}^3} \quad y_{\text{max}} = -0.018 \text{ in} \quad \ll 0.272 \text{ in, O.K.}$$

$$\text{SF} := \frac{y_{\text{allow}}}{y_{\text{max}}}$$

$$\text{SF} = -14.829 \quad \text{Good}$$

Originator: m. Omar Jaka Date: 5/23/00 Checked by: D. DeFord Date: 5/30/00  
 Omar Jaka D. K. DeFord

## ANALYTICAL CALCULATIONS

Page 3 of 3Subject CALCS FOR SX-105 COVER PLATEOriginator OMAR JAKA Date 5/30/00Checker D. Def. d Date 5/30/00CHECK  $3/8"$   $\phi$  HOIST RING FOR OGT COVERWT. OF TEMPORARY COVER FOR OGT =  $12 \times 17.5 \times 3 +$ 

$$(12 \times 17.5 \times 3) + (12 \times 18 \times 3) =$$

$$630 + 648 = 1278 \text{ CU. IN.}$$

$$= 0.739 \text{ CU. FT.}$$

(REF. TO McMASTER-CARR  
CATALOG FOR  $3/8"$   $\phi$   
HOIST RING 3052756  
CAPACITY 1000 #)

$$\text{WT.} = 0.739 \times 490 = 363 \# < 1000 \# \text{ CAPACITY } \therefore \text{O.K.}$$

CHECK FOR  $1"$   $\phi$  HOIST RINGS FOR PLATE (4 USED)

McMaster-CARR 3052767 CAPACITY 10,000 # EACH

$$\text{TOTAL WT. OF PLATES} = 8 \times 8.16 \times \frac{3}{12} \times 490 + 1.25 \times (57.2) \times \frac{3}{12} \times 490$$

$$= 9099 \# < 4 \times 10,000 \#$$

$$< 40,000 \therefore \text{O.K.}$$

DOME LOAD CHECK:

$$\text{WT. OF CONC. BLOCK REMOVED} = (6' - 5\frac{1}{2}" \times 7' - 1\frac{3}{4}" \times 1' - 3") \times 150$$

$$= 6.458 \times 7.146 \times 1.25 \times 150$$

$$= 8653 \#$$

$$\text{WT. OF CONC. BLOCK REMOVED} = 8653 \# > \text{WT. OF STEEL PLATE}$$

HENCE THERE IS NO ADDITIONAL LOAD ON THE DOME.

∴ O.K.

APPENDIX H  
STRUCTURAL CALCULATIONS  
241-S-A

Determine factors of safety for 241-S-A valve pit cover plate design (ECN-659207) with respect to maximum allowable deflection and bending stress:

**ASSUMPTIONS -**

Neglect plate penetrations (largest penetration 20"x22") << plate width)

Plate is simply supported on three edges, one edge free (worst case). Plate is uniformly loaded over entire plate with 50 lbs/sft.

$$a := 142.00 \text{ in (Width of plate)} \quad b := 96.00 \text{ in (Length of plate - free side)}$$

$$t_{\text{steel}} := 3 \text{ in (Thickness of plate, The worst case)}$$

$$A := a \cdot b \quad A = 1.363 \times 10^4 \text{ in}^2 \text{ (Area of plate)}$$

$$V_{\text{steel}} := a \cdot b \cdot t_{\text{steel}} \quad V_{\text{steel}} = 4.09 \times 10^4 \text{ in}^3 \text{ (Volume of plate)}$$

$$\rho_{\text{steel}} := 487 \frac{\text{lb}}{\text{ft}^3} \text{ (Density of ASTM A36 steel)} \quad E := 29 \cdot 10^6 \text{ lb} \cdot \text{in}^{-2} \text{ (Modulus of elasticity, ASTM A36 steel)}$$

$$W_{\text{steel}} := \rho_{\text{steel}} \cdot V_{\text{steel}} \quad W_{\text{steel}} = 1.153 \times 10^4 \text{ lb (Weight of steel plate)}$$

$$q_{\text{steel}} := \frac{W_{\text{steel}}}{A} \quad q_{\text{steel}} = 0.845 \text{ lb} \cdot \text{in}^{-2} \text{ (Distributed dead load due to weight of steel plate)}$$

$$q_{\text{liveload}} := 50 \frac{\text{lb}}{\text{ft}^2} \quad q_{\text{liveload}} := .35 \frac{\text{lb}}{\text{in}^2} \quad q_{\text{total}} := q_{\text{steel}} + q_{\text{liveload}}$$

$$q_{\text{total}} = 172.15 \text{ lb ft}^{-2}$$

$$\text{adivb} := \begin{pmatrix} .5 \\ .667 \\ 1.0 \\ 1.5 \\ 2.0 \\ 4.0 \end{pmatrix} \quad \beta := \begin{pmatrix} .36 \\ .45 \\ .67 \\ .77 \\ .79 \\ .80 \end{pmatrix} \quad \alpha := \begin{pmatrix} .080 \\ .106 \\ .140 \\ .160 \\ .165 \\ .167 \end{pmatrix} \quad \text{From Roark, Ed. 6, Table 26, Case 2a, Pg.461}$$

Use curve fitting to determine  $\beta$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \beta) \quad \beta := \text{interp}(\text{fit}, \text{adivb}, \beta, \frac{a}{b}) \quad \beta = 0.769$$

Calculate maximum stress and safety factor:

$$\sigma_{\text{max}} := \frac{\beta \cdot q_{\text{total}} \cdot b^2}{t_{\text{steel}}^2} \quad \sigma_{\text{max}} = 1.356 \times 10^5 \text{ lb ft}^{-2} \quad \sigma_{\text{yield}} := 36000 \text{ lb} \cdot \text{in}^{-2} \text{ (ASTM A36)}$$

$$\text{SF} := \frac{\sigma_{\text{yield}}}{\sigma_{\text{max}}} \quad \text{SF} = 38.237 \quad \text{SFmin}=5, \text{SF}>\text{SFMIN, O.K.}$$

Originator: m. O. Jaka Date: 5/27/00 Checked by: D. DeFord Date: 6/8/00  
Omar Jaka Doug DeFord

Calculate maximum deflection and safety factor  
using 3" thick plate.

Use curve fitting to determine  $\alpha$ :

$$\text{fit} := \text{cspline}(\text{adivb}, \alpha) \quad \alpha := \text{interp}\left(\text{fit}, \text{adivb}, \alpha, \frac{a}{b}\right) \quad \alpha = 0.16$$

$$t_{\text{steel}} := 3 \text{ in}$$

UBC section 1608, table 16-D deflection not to exceed  $L/360$ : (L=Length of span)

$$y_{\text{allow}} := \frac{L}{360} \quad \frac{142}{360} = 0.394$$

$$y_{\text{allow}} := -0.394 \text{ in}$$


$$y_{\text{max}} := \frac{-\alpha \cdot q_{\text{total}} \cdot b^4}{E \cdot t_{\text{steel}}^3} \quad y_{\text{max}} = -0.021 \text{ in} \quad \ll 0.394 \text{ in, O.K.}$$

$$\text{SF} := \frac{y_{\text{allow}}}{y_{\text{max}}}$$

$$\text{SF} = 19.038 \quad \text{O.K.}$$

Originator: \_\_\_\_\_ Date: \_\_\_\_\_ Checked by: D. DeFord Date: 6/8/00  
Omar Jaka Doug DeFord

## ANALYTICAL CALCULATIONS

Page 3 of 3Subject DESIGN OF 3" COVER PLATE FOR 241-S-A VALVE PITOriginator OMAR JAKADate 6/2/00Checker Ray D. F. dDate 6/8/00ALTERNATE CALCULATIONS: PLATE IS 3" X 11'-10" X 8'-0"ASSUMPTIONS:

- ① DUE TO SEVERAL CUTOUT FROM PLATE USE DIAGONAL STRIP FOR ANALYSIS.
- ② USE LIVE LOAD OF 50 #/ft<sup>2</sup>

MAX. MOMENT

REF. AISC MANUAL  
8TH. EDITION  
P. 2-114

$$M_{MAX} = \frac{w l^2}{8}$$

$$= \frac{1.195 \times 171^2}{8}$$

$$= 4368 \text{ LB-IN}$$


BENDING STRESS @ CENTER

$$f_b = \frac{M c}{I} = \frac{4368 \times 1.5}{6.75} = 971 \text{ PSI}$$

$$F_y = 36000 \text{ PSI}$$

BENDING STRESS SAFETY FACTOR:

$$S.F. = \frac{36000}{961} = 37.1 > 5.0 \therefore \text{O.K.}$$



$$l = \sqrt{11.83^2 + 8^2}$$

$$= \sqrt{203.95}$$

$$= 14.28' = 171''$$

$$w = \text{WT. OF STEEL} + \text{LIVE LOAD}$$

$$= 1' \times 1' \times 3' \times \frac{490 \text{ #/ft}^2}{12^3} + \frac{50 \text{ #/ft}^2}{12^2}$$

$$= 3 \times \frac{490}{12^3} + \frac{50}{12^2}$$

$$= 0.851 + 0.344 = 1.195 \text{ #/ft}$$

TO CALCULATE I &amp; C

$$3'' = d \quad c = \frac{d}{2} = \frac{3}{2} = 1.5''$$

$$I = \frac{d^4}{12} = \frac{3^4}{12} = 6.75 \text{ IN}^4$$

DEFLECTION SAFETY FACTOR (S.F.):

MAX. DEFLEC @ CENTER

REF. AISC MANUAL  
8TH. EDITION  
P. 2-114

$$\Delta_{MAX} = \frac{5 w l^4}{384 E I}$$

$$= \frac{5 \times 1.195 \times 171^4}{384 \times 29000 \times 10^3 \times 6.75}$$

$$= 0.068''$$

$$\Delta_{ALLOW} = \frac{l}{360}$$

$$= \frac{171}{360}$$

$$= 0.475$$

E = MODULUS OF ELASTICITY  
= 29000 KSI FOR STEELI = MOMENT OF INERTIA (IN<sup>4</sup>)(FROM UBC, SEC. 1608)  
TABLE 16-D

l = SPAN LENGTH

$$S.F. = \frac{\Delta_{ALLOW}}{\Delta_{ACTUAL}} = \frac{0.475}{0.068}$$

$$= 7.0 > 1.0 \therefore \text{O.K.}$$

RPP-5416, Rev. 2

APPENDIX I

STRUCTURAL CALCULATIONS  
241-S-C

## ANALYTICAL CALCULATIONS

Page 1 of 4Subject DESIGN OF 3" COVER PLATE FOR 241-S-C VALVE PITOriginator OMAR JAKA Date 6/6/00Checker Dong DePd Date 6/7/00

REF. DWG. H-2-46153

REPLACING WEST CORR. COVER BLOCK BY 3" COVER PLATE  
AS SHOWN IN ECN 6592083" COVER PLATE <sup>(11'-10" x 8'-0")</sup> WITH PENETRATIONS AS SHOWN ON  
PAGE A OF B OF ECN 659208.PLATE HAS BEEN ANALYZED BY COSMOS GEOSTAR 2.5 AND  
ON 6/5/00 AND RESULTS FOR STRESS AND DEFLECTIONS  
ARE SHOWN ON PAGE 3 & 4

CHECK FACTORS OF SAFETY FOR STRESS AND DEFLECTION

STRESS SAFETY FACTOR: REFER TO SHEET # 3 OF 4  
PLATE IS  $F_y = 36 \text{ KSI} = \sigma_{\text{YIELD}}$ ACTUAL MAX STRESS  $\sigma_{\text{MAX}} = 3000 \text{ PSI}$ 

$$S.F. = \frac{\sigma_{\text{YIELD}}}{\sigma_{\text{MAX}}} = \frac{36000}{3000} = 12 > 5 \quad \therefore \text{O.K.}$$

DEFLECTION SAFETY FACTOR:

REFER TO SHEET # 4 OF 4

$$\Delta_{\text{ALLOW}} = \frac{l}{360} = \frac{142}{360} = 0.394''$$

ALLOW. DEFLECTION =  $\frac{l}{360}$   
(UBC, SECTION 1602 TABLE 16-D) $l = \text{span length}$ 

$$\Delta_{\text{ACTUAL}} = 0.048''$$

$$S.F. = \frac{\Delta_{\text{ALLOW}}}{\Delta_{\text{ACTUAL}}} = \frac{0.394}{0.048} = 8.2 > 1.0 \quad \therefore \text{O.K.}$$

**ANALYTICAL CALCULATIONS**



Subject DESIGN OF 3" COVER PLATE FOR 241-S-C VALVE PIT

Originator OMAR JAKA Date 6/6/00

Checker Doug Pelf Date 6/7/00

ALTERATE CALCULATIONS:

PLATE IS 11'-0" X 8'-0"



ASSUMPTION:  
DUE TO SEVERAL CUTOUT IN THE PLATE, USE DIAGONAL STRIP FOR SPANNING

REF. AISI MANUAL 8TH. EDITION P. 2-114

$$M_{max} = \frac{w l^2}{8}$$

$$= \frac{1.195 \times 171^2}{8}$$

$$= 4368 \text{ lb-in}$$

$$L = \sqrt{11.83^2 + 8^2}$$

$$= \sqrt{203.95}$$

$$= 14.28' = 171''$$

W = WT. OF STEEL + LIVE LOAD

$$= 1' \times 1' \times 3' \times 490 \frac{\text{#}}{\text{ft}^3} + 50 \frac{\text{#}}{\text{ft}^2}$$

$$= \frac{3 \times 490}{123} + \frac{50}{12^2}$$

$$= 0.851 + 0.344$$

$$= 1.195 \text{ #/ft}$$

BENDING MOMENT @ CENTER

$$f_b = \frac{M c}{I} = \frac{4368 \times 1.5}{6.75}$$

$$= 971 \text{ PSI}$$

$$F_y = 36000 \text{ PSI}$$

TO CALCULATE I  $\square \begin{matrix} 1'' \\ 3''=d \end{matrix}$

$$c = \frac{d}{2} \quad I = \frac{d^4}{12}$$

$$= \frac{3}{2} \quad = \frac{3^4}{12} = 6.75 \text{ in}^4$$

$$= 1.5'' \quad = 1.5''$$

STRESS  $SF = \frac{36000}{971} = \boxed{37.1} > 5 \therefore \text{O.K. (TOO HIGH COMPARED TO COMPUTER RESULT)}$

DEFLECTION SAFETY FACTOR (SF):

MAX DEFLECTION AT CENTER  $\Delta_{max} = \frac{5 w l^4}{384 E I} = \frac{5 \times 1.195 \times 171^4}{384 \times 29000 \times 10^3 \times 6.75}$

$$E = 29000 \text{ KSI}$$

$$= 0.068''$$


$$\Delta_{Allow} = \frac{l}{360} = \frac{171}{360} = 0.475'' \quad SF = \frac{0.475}{0.068} = 7.0 > 1.0 \therefore \text{O.K. (CLOSE TO COMPUTER RESULT)}$$

**USE SAFETY FACTOR ANALYZED BY COMPUTER PROGRAM**

Geostar 2.5 (128K Version): 241-S-C - [Main]

FOR BENDING STRESSES

LINE STRESS Lc=1



Von Mises

5677.300
4984.300
4291.400
3598.400
2905.400
2212.400
1519.500
826.5100
133.5400

MAX STRESS  
≈ 3000 PSI

ANALYZED BY *B.J. Crowell*

CHECKED BY *M.D. ...*

DATED: 6/5/00



GeoStar 2.5 (128K Version) : 241-S-C - [Main]

FOR DEFLECTION

MAX DEFLECT Le.V

0.048"

Disp. Res



Lin DISP Le=1

ANALYZED BY BT Corryell

CHECKED BY m.o. m.Jtk

DATED: 6/5/00

APPENDIX J  
STRUCTURAL CALCULATIONS  
241-SX-A

## ANALYTICAL CALCULATIONS

Page 1 of 4Subject DESIGN OF 3" COVER PLATE FOR 241-SX-A VALVE PITOriginator OMAR JAKA Date 6/6/00Checker Doug Beled Date 6/7/00

REPLACING WEST CONCRETE COVER BLOCK BY 3" THK. STEEL COVER PLATE AS SHOWN IN ECN 659209

3" COVER PLATE (11'-10" x 8'-0") WITH PENETRATION AS SHOWN ON PAGE 4 OF 8 OF ECN 659209

PLATE HAS BEEN ANALYZED COSMOS "GEOSTAR 2.5" COMPUTER PROGRAM ON 6/5/00, RESULTS FOR STRESSES AND DEFLECTION ARE ATTACHED AS PAGE 3 & 4.

CHECK FACTORS OF SAFETY FOR STRESS AND DEFLECTION

STRESS SAFETY FACTOR: REFER TO PAGE 3 OF 4

PLATE IS  $F_y = 36 \text{ ksi} = \sigma_{YIELD}$

ACTUAL MAX STRESS =  $\sigma_{MAX} = 3000 \text{ PSI}$

$$S.F. = \frac{\sigma_{YIELD}}{\sigma_{MAX}} = \frac{36000}{3000} = \boxed{12} > 5 \therefore \text{O.K.}$$

DEFLECTION SAFETY FACTOR:

REFER TO PAGE 4 OF 4

$$Y_{ALLOW} = \frac{l}{360} = \frac{142}{360} = 0.394"$$

$$ALLOW DEFLECTION = \frac{l}{360}$$

$$Y_{ACTUAL} = 0.05"$$

(UBC, SECTION 1608 TABLE 16-D)

$l = \text{SPAN LENGTH}$

$$S.F. = \frac{Y_{ALLOW}}{Y_{ACTUAL}} = \frac{0.394}{0.05}$$

$$= \boxed{7.88} > 1.0 \therefore \text{O.K.}$$

$$1 - 8\frac{3}{8} \times 1 - 10\frac{3}{4}$$

$$1.698 \times 1.857$$

$$\text{WT. OF PLATE} = 11.83 \times 8 \times \frac{3}{12} \times 490 = 11593 \#$$

CUTOUT

$$- 5 \times 1.698 \times 1.857 \times \frac{3}{12} \times 490$$

$$\text{EACH CUTOUT} = \frac{1928}{5} = 386 \# < 1000$$

$$11593 - 1928$$

$$= 9669 \# < 4 \times 10000 \text{ O.K.}$$


## ANALYTICAL CALCULATIONS

Page 2 of 4


Subject DESIGN OF 3" COVER PLATE FOR 241-SX-A VALVE PIT  
 Originator OMAR JAKA Date 6/6/00  
 Checker Doug Def-d Date 6/7/00

ALTERNATE CALCULATIONS:

PLATE IS 11'-10" X 8'-0"



ASSUMPTION: ① DUE TO SEVERAL CUTOUT IN THE PLATE, USE DIAGONAL STRIP FOR SPAN  
 ② USE LIVE LOAD OF  $50 \text{ #/ft}^2$



$$l = \sqrt{11.83^2 + 8^2}$$

$$= \sqrt{203.95}$$

$$= 14.28' = 171"$$

MAX. MOMENT AISC MANUAL  
 8th. EDITION  
 P. 2-114

$$\text{MAX} = \frac{w l^2}{8}$$

$$= \frac{1.195 \times 171^2}{8}$$

$$= 4368 \text{ lb-in}$$

BENDING MOMENT @ CENTER:

$$f_b \cong \frac{M c}{I} = \frac{4368 \times 1.5}{6.75}$$

$$= 971 \text{ psi}$$

$$F_y = 36000 \text{ psi}$$

BENDING STRESS SAFETY FACTOR:

$$S.F. = \frac{36000}{971} = \boxed{37.1} > 5 \therefore \text{O.K.}$$

(TOO HIGH COMPARED TO COMPUTER VALUE)

DEFLECTION SAFETY FACTOR:

MAX. DEFLECTION @ CENTER  $\Delta_{\text{MAX}} = \frac{5 w l^4}{384 E I}$  AISC MANUAL  
 P. 2-114

$$= \frac{5 \times 1.195 \times 171^4}{384 \times 29000 \times 1000 \times 6.75}$$

$$= 0.068"$$

$$\Delta_{\text{ALLOW}} = \frac{l}{360} = \frac{171}{360} = 0.475"$$

$$S.F. = \frac{0.475}{0.068} = \boxed{7.0} > 1.0 \therefore \text{O.K. (COMPARABLE TO COMPUTER VALUE)}$$

**∴ USE SAFETY FACTOR ANALYZED BY COMPUTER PROGRAM**


FOR BENDING STRESSES

GeoStar 2.5 (128K Version): 241-SX-A - [Main]

Lin STRESS Loc=1

Von Mises
3786.500
3079.900
4373.300
2666.700
2969.100
2253.500
1546.900
848.3200
133.7200

MAX STRESS  
≈ 3000 PSI



Y  
X

ANALYZED BY *BJ Corwell*

CHECKED BY *m. b. m. Jahn*

DATED: 6/5/00


PAGE 4 OF 4

FOR DEFLECTION

GeoStar 2.5 (128K Version) : 241-SX-A - [Main]

LTn DISP Lev1

MAX. DEFLECTION	Disp_Res
0.05" ←	0.0499300
	0.0436899
	0.0374490
	0.0312070
	0.0249650
	0.0187240
	0.0124830
	0.0062413
	1.09E-033



ANALYZED BY *B. J. Crumell*  
 CHECKED BY *M. D. ...*  
 DATED: 6/5/00