

# Shape Factor for Steady State Heat Transfer between Swimming Pool Water and Surrounding Ground

Aneesh Somwanshi<sup>1\*</sup>, Amrit Dixit<sup>1</sup> and Anil Kumar Tiwari<sup>2</sup>

<sup>1</sup>Disha Institute of Management and Technology, Raipur 492101, India

<sup>2</sup>National Institute of Technology, Raipur 492001, India

## Abstract

A simple, efficient, and abundantly available agricultural waste material, banana pseudo-stem (BPS) was examined as raw material for the extraction of potassium. The effects of various process parameters such as temperature, initial pH, contact time, banana pseudo-stem dosage and size of banana pseudo-stem particles on potassium extraction efficiency were studied by running batch experiments in Erlenmeyer flasks. Response Surface Methodology (RSM) was used to design the experimental runs. Modelling and optimization of process variables to obtain maximum extraction of potassium from raw material were done using RSM. The maximum extraction efficiency of potassium was found to be 83.96% at a temperature of 400C, pH of 1, contact time of 30 min, BPS weight of 26.076 g and initial BPS size of 300. The results revealed that banana pseudo-stem can be used as good source for potassium extraction.

**Keywords:** Shape factor, Thermal simulation, Characteristic length, Swimming pool

## Introduction

Solar energy has been widely used for heating of swimming pools; a number of papers [1-13] on the implementation, analysis and validation, corresponding to the exploitation of various options have been published. The starting point for all the analyses is an energy balance equation, which takes into account the relevant modes of energy exchange between the pool and the surroundings; however a significant aspect viz. the energy exchange between the pool water and the surrounding ground has either been ignored or inadequately addressed to (usually based on one dimensional flow of heat in the ground). In this paper the authors have used the method of experimental simulation for the evaluation of the energy exchange between the pool water and the surrounding ground in the steady state. Such an investigation is also relevant to temperature conditioning of water in a pool by exchange of heat with earth, as proposed recently [14]. The energy storage in the ground has for long been exploited for heating and cooling of buildings [15-19] and hence some attention (not enough) has been given to the study of energy exchange between a building and surrounding ground. For a theoretical analysis one has to solve the Fourier equation of heat conduction with appropriate boundary conditions; except for the simplest cases with high symmetry [20-22] it is not possible to obtain analytical solutions. Numerical solutions have of course been obtained [23-26] for structures with less symmetry. Full scale experiments, to evaluate the rate of heat exchange between a building and surrounding ground are not practicable; further the results are of little use on account of the variety of building designs.

With this background Sodha et al. [27-30] have developed the methods of electrical and thermal simulation (by experiment) to evaluate the heat transfer between a fully or partially underground structure and surrounding ground, where by results on small scale model can be scaled up for bigger realistic situations.

## Theoretical Basis

Sodha et al. [27,10,31] modeled the steady state temperature distribution in the ground, the boundary conditions and the heat exchange between the body and the ground viz,

$$\nabla^2(T) = 0, \quad (1a)$$

$$T(z=0) = T_g, \quad (1b)$$

$$T(\text{Surface of body}) = T_s \quad (1c)$$

and,

$$\dot{Q} = KLF(T_s - T_g), \quad (1d)$$

The method of simulation is based on the fact [27,31] that in general for the steady state Eq. (1d) may be put in the form,

$$\dot{Q} = KLF(T_s - T_g), \quad (2)$$

Where F depends on the relative (divided by L) dimensions of the body, relative depth and the orientation of the body and L is a characteristic dimension. Thus the steady state heat transfer between a body and the ground under any situation (characterized by L, thermal conductivity K of the medium and  $(T_s - T_g)$ ) can be evaluated with a knowledge of the shape factor F, which may be determined by an experiment on a convenient scale or value of L (keeping the relative depth, relative dimensions of the body and the orientation of the body with respect to the surface the same) and convenient values of K and  $(T_s - T_g)$ . In this paper, the shape factor corresponding to the heat transfer between the ground and three designs of swimming pools have been obtained by simulated experiments on a small scale.

## Experiment

This paper reports on the experimental determination of the shape factor for heat transfer between the pool water and the ground for the

**\*Corresponding author:** Aneesh Somwanshi, Disha Institute of Management and Technology, Raipur 492101, India, Tel: +919752322262; E-mail: [aneeshsomwanshi@rediffmail.com](mailto:aneeshsomwanshi@rediffmail.com)

**Received** December 20, 2013; **Accepted** January 29, 2014; **Published** February 06, 2014

**Citation:** Somwanshi A, Dixit A, Anil Kumar T (2013) Shape Factor for Steady State Heat Transfer between Swimming Pool Water and Surrounding Ground. J Fundam Renewable Energy Appl 4: 128. doi: [10.4172/2090-4541.1000128](https://doi.org/10.4172/2090-4541.1000128)

**Copyright:** © 2013 Somwanshi A, et al. This is an open-access article distributed under the terms of the Creative Commons Attribution License, which permits unrestricted use, distribution, and reproduction in any medium, provided the original author and source are credited.

following three designs:-

(I) Length ( $l$ ) = 60m, Breadth ( $b$ ) = 25m, Depth ( $d$ ) = 2m. (Olympic size horizontal base pool [32]).

(II) Length ( $l$ ) = 60m, Breadth ( $b$ ) = 30m: vertical section normal to the breadth is shown in Figure 1(a). (Slanted base pool [33]).

(III) Length ( $l$ ) = 35ft, Breadth ( $b$ ) = 20ft: vertical section normal to the breadth is shown in Figure 1(b). (Diving pool [33]).

In all the cases the characteristic length  $L = b/2$  and the pool is full of water; the water surface is on level with the horizontal ground surface. The models are open boxes without cover; for the three pool designs the simulated dimensions are reduced by the reduction factor as follows:-

(I) Design I= (1/400). (II) Design II= (1/300). (III) Design III= (1/150).

The corresponding characteristic length  $L = b/2$  for these models are  $3.125 \times 10^{-2}$  m,  $5 \times 10^{-2}$  m and  $2 \times 10^{-2}$  m, respectively. The models are closed by thick insulating pads at the top face.

### Determination of Thermal conductivity of sand

The ground is simulated by a 1.5 m x 1.5 m x 1.5 m box full of sand. The thermal conductivity of the sand is determined before every experiment for determining the shape factor. The experimental arrangement for determination of the thermal conductivity of sand is diagrammatically illustrated in Figure 2. A hollow copper sphere of diameter ( $2a$ ) 6 cm is buried in the sand, so that the Centre of the sphere is at depth  $d$ . There is an incandescent bulb or an insulated heating element in the sphere which is connected to a source of alternating emf. The rms values of the potential difference ( $V$ ) and the current ( $I$ ) flowing through the bulb/element is measured; in the steady state the power output of the bulb/element is equal to the power loss from sphere to the ground. Hence from Eq. (2) one gets,

$$VI = FaK(T_s - T_g); \tag{3}$$

Here the radius  $a$  of the sphere is the characteristic length. The temperature difference ( $T_s - T_g$ ) is determined by thermocouples. The shape factor  $F$  for a sphere of radius  $a$  at a depth  $d$  in the ground has been analytically evaluated [29,34] as,




Figure 2: Experimental set up to measure thermal conductivity of sand. 1. Sphere with mica insulation heating element. 2. Voltmeter 3. Microammeter. 4. Temperature sensor. 5. Temperature sensor. 6. Rheostat.

$$F = 2\pi a + 4\pi a \sum_0^{\infty} \exp[-(2n+1)\beta] \cdot \{1 + \cosh[(2n+1)\beta]\}, \tag{4}$$

Where,

$$\cosh\beta = (d/a)$$

Substituting for  $F$  from Eq.(4) in Eq. (3) and using the measured steady state values of  $V, I, T_s, T_g$  and  $a$ , the thermal conductivity of sand can be determined for  $d/a = 2$  and 3. It is seen from Eq.(4) that the values of shape factor  $F$  are 15.3 and 14.5 for  $d/a = 2$  and 3. From three readings for  $d/a = 2$  and three readings for  $d/a = 3$  on different days the authors obtained the value of thermal conductivity of sand  $K = 0.271 \pm 0.004 \text{ W/m}^{\circ}\text{C}$ . A value of  $K = 0.271 \text{ W/m}^{\circ}\text{C}$  has been used in the evaluation of shape factors, corresponding to the three pool designs.

### Determination of shape factor F for three pool designs

The experimental arrangement is diagrammatically illustrated in Figure 3. The copper model of the pool is so buried in sand that the top horizontal surface of the sand is in level with the open face of the model. Ceramic insulation is placed on the model, so that there is no heat loss from the top side. A heating element with mica insulation is placed inside the model and connected to an A.C source, through a millie ammeter and rheostat; the potential difference across the element and the current passing through it are measured by a voltmeter and micro ammeter. Temperature sensors measure the temperature difference ( $T_s - T_g$ ) between the surface of the model and the top surface of the sand. Observations are taken when steady state values of  $T_s$  and  $T_g$  are indicated.

Referring to the half width of the pool as the characteristic length Eq. (2) may be rewritten as

$$VI = F (b/2) K (T_s - T_g); \tag{5}$$

$V$  and  $I$  are the r.m.s values of the potential difference across and the current through the heating element. Knowing all the terms in this equation the shape factor  $F$  for the specific pool designs can be evaluated. It may be remembered that as stated earlier in the paper thermal conductivity  $K$  for sand is taken as  $0.271 \text{ W/m}^{\circ}\text{C}$ .

### Observations and Results

These are presented in Tables 1-3. Thus the shape factors for designs I, II, and III are  $(16.77 \pm 0.73)$ ,  $(15.91 \pm 0.15)$  and  $(34.12 \pm 1.38)$




Figure 1a: Pool Design II.





Figure 1b: Pool Design III.



the uncertainty in the values is less than 5% and should be acceptable for design purpose.

## Conclusions

Experimental simulation has been used to evaluate the shape factor  $F$ , corresponding to steady state heat transfer between water in a swimming pool and the surrounding ground; the shape factor has been determined, corresponding to three designs of the swimming pool. The uncertainty in the values of  $F$  is less than 5% and thus acceptable for design purpose.

## Acknowledgement

The authors are grateful to Prof. MS Sodha, Visiting and Emeritus Professor, CES, IIT Delhi, India for suggesting the problem and valuable guidance.

## References

- Root Jr DE (1959) Simplified engineering approach to swimming pool heating. *Solar Energy* 3: 60-63.
- Root Jr DE (1960) Practical aspects of heating swimming pools by solar energy. *Solar Energy* 4: 23-24.
- Francey JLA, Golding P, Clarke R (1980) Low cost solar heating of community pools using pool covers. *Solar Energy* 25: 407-416.
- Francey JLA, Golding P (1981)The weathering of solar pool covers. *Solar Energy* 26: 237-242.
- Francey JLA, Golding P (1981)The optical characteristic of swimming pool covers used for direct solar heating. *Solar Energy* 26: 59-63.
- Lazzarin R (1983) Alternative heating of a municipal swimming pool. *International Journal of Refrigeration* 6: 118-122.
- Govind,Sodha MS (1983) Thermal model of solar swimming pools. *Energy Conversion and Management* 23: 171-175.
- Sodha MS, Kumar A, Govind (1988) Solar heating of open swimming pool. *International journal of Energy Research* 12: 511-519.
- YadavYP, Tiwari GN (1987) Analytical model of solar swimming pool; transient approach. *Energy Conversion and Management* 27: 49-54.
- Rokopoulos CD, Vazeos E (1987)A model of energy fluxes in a solar heated swimming pool and its experimental validation. *International journal of Energy Conversion and Management* 27: 189-195.
- Alkhamis AI, Sherif SA (1992) Performance analysis of solar assisted swimming pool heating system. *Energy* 17: 1165-1172.
- Wooley J, Hannington J, Modera M (2011) Swimming pool as a heat sink for air conditioners: model design and experimental validation for natural behavior of the pool. *Building Environment* 46: 187-295.

- Dang A (1986) A parametric study of swimming pool heating. *Energy Conversion and Management* 26: 27-31.
- Somwanshi A, Tiwari AK, Sodha MS (2013)Feasibility of earth storage for all weather conditioning of open swimming pool water. *Energy Conversion and Management* 68: 89-93.
- Sodha MS, Sharma AK, Singh SP, Bansal NK, Kumar A (1985) Evaluation of an earth air tunnel system for cooling/heating of a hospital complex. *Building and Environment* 20: 115-122.
- Sodha MS, Budhhi D, Sawhney RL (1981) Thermal performance of underground air pipe: different earth surface treatments. *Energy Conversion and Management* 31: 95-104.
- Sodha MS, Mahajan U, Sawhney RL (1994) Thermal performance of a parallel earth air pipes. *International Journal of energy Research* 18: 437-447.
- Bansal NK, Sodha MS (1986)An earth air tunnel system for cooling buildings. *Tunneling and Underground Space Technology* 1: 177-182.
- Sawhney RL, Mahajan U (1994) Heating and cooling potential of an underground air pipe system. *International Journal of Energy Research* 18: 509-524.
- Shelton J (1975) Underground storage of heat in a solar heating system. *Solar Energy* 17: 137-143.
- Claesson J,Dunand A (1983) Heat extraction from the ground by horizontal pipes: a mathematical analysis. *Swedish Council of Building Research* Stockholm Document D1.
- Carslaw HS, Jaeger JC (1947) *Conduction of heat in solids*. Clarendon Press Oxford.
- Claesson J, Efring B (1980)Optimal distribution of thermal insulation and ground heat losses. *Swedish Council of Building Research* Stockholm Document D33.
- Boileau GG, Latta JK (1968) Calculation of basement heat losses technical paper 292. *Division of Building Research* NRC Canada.
- MitalasGP (1983) Calculation of basement heat loss. *Ashare Transactions* 89: 420-437.
- Shen LS, Ramsey JW (1983) A simplified thermal analysis of the earth sheltered building using a Fourier series boundary method *Ashare Transactions* 89: 438-448.
- Sodha MS, Sawhney RL, Jaishankar JC (1990) Estimation of steady state ground losses from earth coupled structures by simulation. *International Journal Energy Research* 14: 563-571.
- Sodha MS, Sawhney RL, Singh SP, Jaishankar BC (1990) Electrical stimulation of thermal losses from underground structures. *International Journal of Energy Research* 14: 245-248.
- Sodha MS (2001) Simulation of periodic heat transfer between ground and underground structures. *International Journal of Energy Research* 25: 689-693.
- Sodha MS (2001) Simulation of dynamic heat transfer between ground and underground structures. *International Journal of Energy Research* 25: 1391-1394.
- Sodha MS, Mishra D, Tiwari AK (2010) Validation of the basis of experimental simulation of heat transfer between a building and surrounding earth. *Journal of Solar Energy Society of India*.
- Mearig T, Morgan M (1997) *Swimming pool guidelines*. Alaska Department of Education Alaska. USA.
- Pool size shape and depth options for UK indoor and outdoor pools. *Bluepools custom pools and deck designs*.
- Labeledev NN, Skalskaya IP, Uflynd YS (1965) *Problems of mathematical physics*. Prentice Hall Inc Englewood Cliffs.

## Nomenclature

- $\dot{Q}$  Rate of heat loss from the model to the surface of sand ( $W$ )
- $K$  Thermal conductivity of the medium ( $W/mK$ )
- $L$  Characteristic length ( $m$ )
- $F$  Shape factor of model.
- $T_s$  Temperature of the surface of model ( $^{\circ}C$ )

$T_g$  Temperature at the top surface of sand ( $^{\circ}C$ )

$V$  Root mean square (r.m.s) potential difference across the heater element ( $V$ )

$I$  Root mean square (r.m.s) of current flowing through the heater element ( $V$ )

$d$  depth of model sphere below the surface of sand ( $m$ ).

$a$  Radius of model sphere ( $m$ ).

$l$  Length of the swimming pool model ( $m$ ).

$b$  Breadth of the swimming pool model ( $m$ ).

$d$  Depth of the swimming pool model ( $m$ ).

$\beta$   $\cosh^{-1}(d/a)$ .