

Innovative household systems based on solid oxide fuel cells for a northern European climate



Giulio Vialletto, Masoud Rokni*

Technical University of Denmark, Copenhagen 2800, Denmark

ARTICLE INFO

Article history:

Received 24 September 2014

Accepted 5 January 2015

Available online

Keywords:

SOFC

Heat pump

Operating strategy

Hybrid system

ABSTRACT

Energy saving is an open point in most European countries where energy policies are oriented to reduce the use of fossil fuels, greenhouses emissions and energy independence and to increase the use of renewable energies. In the last several years, new technologies have been developed, and some of them received subsidies to increase installation and reduce cost.

This article presents an innovative cogeneration system based on a solid oxide fuel cell (SOFC) system and heat pump for household applications with a focus on primary energy and economic savings using electric equivalent load parameter which is a function of the electricity and heat demand of the user, and allows different operation strategies to be considered. The proposal is to maximize the efficiency of the system and to make it profitable, even though technologies with a high purchase cost are considered. Simulations of the system are performed under different strategies at a resort located in a northern European climate (Denmark) to cover electricity, space heating and domestic hot water (DHW) demands. The results of these simulations are analyzed with thermodynamic and techno-economic benchmarks, considering different economic scenarios. The calculations show the high primary energy saving and profitability of the system.

© 2015 Elsevier Ltd. All rights reserved.

1. Introduction

European countries are working to improve their energy policies: one of the themes is energy saving. Publication of the 2010/31 EU Directive is proof of the importance of energy saving in buildings. Insulation and/or more efficient technology (for example, condensing boilers, heat pumps or district heating related to a cogeneration power plant) could help reach these goals. There is currently an increased interest in developing a distributed system of smaller-scale facilities at a single location, allowing electricity and heat to be produced and distributed close to the end user and thereby minimizing the costs associated with transportation [1,2]. Micro CHP (combined heat and power) for household application falls also within this category. However, micro CHPs face the problem of heat-to power ratio (defined as the ratio between heating demand and electricity consumption) that varies during

the day as well as between the seasons due to the different consumption [3].

Solid oxide fuel cells (SOFC) are one of the most promising types of fuel cells, particularly regarding energy production. They are expected to produce clean electrical energy at high convention rates with low noise and low pollutant emissions [4]. SOFC stacks will soon enter the commercialization phase, while heat pumps have been available in the market for decades. It therefore would be interesting to integrate these two technologies into a single system, combining the benefits of each system to establish a new technology.

Numerous studies have been investigated in the literature on SOFC-based hybrid systems that suggest high thermal efficiencies. The majority of these studies use gas turbines as the bottoming cycle for SOFCs (see, e.g., Refs. [5–7]), resulting in pressurized SOFC cycles. Steam turbines and organic rankine cycles (ORC) have also been used as a bottoming cycle [8–10], resulting in non-pressurized SOFC stacks. A few studies have been performed that utilize a Stirling engine as the bottoming cycle and the fuel cell as the topping cycle (see, e.g., Refs. [1,2,11]). At present, using the Brayton and Rankine cycles as bottoming cycles seems to be the

* Corresponding author.

E-mail address: MR@mek.dtu.dk (M. Rokni).

most practical because of the maturity of these technologies. Given that the development trends suggest that the operating temperature of the SOFC will decrease, using a gas turbine as the bottoming cycle will become less beneficial over time. SOFC-steam hybrid systems are more complex but would be interesting systems when an old steam plant is considered for repowering. SOFC-Stirling engine hybrid systems own their benefits from being small scale, starting from 1 to 2 kW.

However, studies on combined SOFC-heat pumps are very rare, e.g., Ref. [12] studied the operating conditions and performance of domestic heating systems with heat pumps and SOFCs as micro-cogeneration systems in buildings. The emphasis was to indicate the effect of operating conditions and methodologies rather than the detailed analysis and performance of the units. Other studies in SOFC for residential applications as cogeneration system can be found in e.g. Ref. [13] in which the feasibility of a 5 kW SOFC from economical view was considered. A micro CHP with SOFC for single-family detached dwellings was studied in Ref. [14], while the impact of heat-to-power ratio for a SOFC based micro CHP for residential application in European climate was elaborated in Ref. [15]. Variation of the heat to power output ratio to match the electric and hot water demands of a Japanese residence can be found in Ref. [16].

In this article, an innovative system is proposed, which is mainly based on a solid oxide fuel cell (SOFC) and a heat pump. SOFCs are new technology for power generation, and they are still in the study and design phase. Some of their advantages could be mentioned, including high efficiency, the possibility of cogeneration and a building micro-cogeneration system with a nominal power of 1–2 kW. A heat pump, in particular an electric heat pump, is chosen as a backup device to cover the heat demand of the user.

The aim of this study is to not only to present a system suitable for residential applications but also to decrease mismatching between the electricity and heating demand of the user, which is a critical problem in cogeneration systems and particularly in small micro CHP systems. Although the electricity consumption of the user increases when a heat pump is used, heat pumps have considerably higher energy efficiency versus conventional electric heaters, such as electric resistors.

In addition, the aim is also to study the economics of the system presented here by analyzing the thermoeconomy and operating strategy. The operation strategy used here does not follow the electrical or heating demand separately, but considers both together within a single definition. Such investigations are new and have not been considered previously.

2. Overview of the system

The main components of the system proposed here are a solid oxide fuel cell (SOFC) plant, heat pump and water tank. The SOFC plant is fed by natural gas for electricity production and for driving the compressor of the heat pump, while its waste heat is recovered for water heating and is used for space heating and domestic hot water (DHW). Fig. 1 displays how they are connected to each other as well as to the grid. The heat pump is used only when the heat available from the SOFC is lower than the heating demand. The water tank stores hot water when the SOFC produces more heat than the user requests. The system is connected to the grid so that when the electricity requirement (from both user and heat pump) exceeds the electricity production from the SOFC, electricity can be drawn from the grid. In the case where the request is lower than production, electricity will be supplied to the grid without considering any type of subsidy, such as net metering.

2.1. SOFC

An SOFC system fueled by natural gas is simulated using the in-house program DNA. It is made with these components (Fig. 2):

- air compressors to compress the air necessary for the fuel cell system;
- a catalytic partial oxidation (CPO) to convert the heavier hydrocarbons into CH_4 , H_2 and CO ;
- a desulfurizer to remove the sulfur from the fuel and avoid fuel cell poisoning;
- heat exchangers to increase plant efficiency, preheating fuel and air using the off-fuel and off-air, respectively (CP, RP, FP, AP), and to heat water for space heating and domestic hot water (DHW) using the wasted off-gases (HEAT RECOVERY);
- a burner to burn the unused fuel out of the fuel cell;
- SOFC stacks with performances similar to the type developed at DTU Risø National Laboratory.

The SOFC system has electricity consumption because of auxiliary components (air compressors) and DC/AC conversion (inverter). Results from the study of Ref. [2] show that the electricity consumption for auxiliaries in the SOFC plant is about 1.5% of the electricity produced by the fuel cell stacks; thus an auxiliary efficiency (η_{aux}) of 98.5% is defined. The inverter efficiency (η_{inv}) is assumed to be 92%, and therefore, the overall transmitted efficiency (η_{trans}) is defined, considering both auxiliaries and inverter efficiencies as,

$$\eta_{\text{trans}} = \eta_{\text{aux}} \eta_{\text{inv}} \quad (1)$$

Under this hypothesis, the η_{trans} can be calculated as 0.9068.

If F_{SOFC} is the fuel consumption of the SOFC, H_{SOFC} is the heat available for HEAT RECOVERY, and E_{SOFC} is the gross produced electricity (without auxiliary consumption and inverter efficiency), then, the thermal efficiency (η_{thermal}) and electrical efficiency (η_{SOFC}) of the SOFC plant are defined as,

$$\eta_{\text{thermal,SOFC}} = \frac{H_{\text{SOFC}}}{F_{\text{SOFC}}} \quad (2)$$

$$\eta_{\text{electrical,SOFC}} = \frac{E_{\text{SOFC}}}{F_{\text{SOFC}}} \quad (3)$$

Table 1 reports the thermodynamic benchmarks for a simulation of the SOFC system with one stack at full load (1 kW).




Fig. 1. General scheme of the system proposed here with the main component and energy flows: fuel (black), electricity (blue) and heat (red). (For interpretation of the references to color in this figure legend, the reader is referred to the web version of this article.)




Fig. 2. Representation of the SOFC system. CP = cathode preheater, FP = fuel preheater, AP = air preheater, RP = reformer preheater.

2.2. Heat pump

If waste heat from the SOFC is not sufficient to cover heat demand, then it is necessary to have a backup component, such as a gas-fired burner or electric heater. However, in this innovative system, a heat pump is chosen to cover heat demand instead of a burner or heater. Usually, two different types of heat pump are available on the market; ground source heat pump (GSHP) and air source heat pump (ASHP). ASHPs are cheaper but in countries where winter days with a temperature just above 0 °C and a humidity above 50% are more frequent, the possibility of freezing the outdoor section (evaporator) may lead to a decrease in the seasonal performance of the heat pump. Ice has poor heat transfer; therefore, the heat exchange will eventually decrease and then it is necessary to defrost it with, for example, an auxiliary heat source (electrical resistance or gas burner) or by reversing the cycle. A GSHP is chosen for this system because of its higher efficiency, even though it is more expensive. A commercially available GSHP is chosen in this study. To calculate the coefficient of performance (COP) of this heat pump, it was necessary to consider that the working condition differs from the nominal condition. The technical norms of the heat pump used here are:

- UNI-TS 11300-4 to consider different working temperatures at the condenser/evaporator [17];
- EN 14825 to consider the partial load of the heat pump in heating mode based on [18].

In this study, a calculation method based on the model of [19] is developed to consider the UNI-TS 11300-4 standard. The maximum coefficient of performance (COP_{max}) of the GSHP is related to the heat sink temperature ($T_{w, out}$) and the heat source temperature (T_{grd}):

$$COP_{max} = \frac{T_{w, out} + 273.15}{T_{w, out} - T_{grd}} \quad (4)$$

The performances of real GSHP systems are always lower than theoretical COP_{max} , and an exergy efficiency is defined between COP_{max} and COP, where COP is given in the technical data sheet of the heat pump producer,

$$\eta_{ex} = \frac{COP}{COP_{max}} \quad (5)$$

Generally, heat pump performances are highly sensitive to the operating conditions (heat sink and heat source temperatures and

partial load conditions). Following the study of [19] and the method proposed in UNI-TS 11300-4, it is possible to calculate the exergy efficiency of the heat pump if both the nominal performances (COP_{nom}) and nominal temperatures ($T_{w, out, nom}$, $T_{grd, nom}$) are known as,

$$\eta_{ex, nom} = \frac{COP_{nom}}{COP_{max, nom}} = COP_{nom} \left(\frac{T_{w, out, nom} - T_{grd, nom}}{T_{w, out, nom} + 273.15} \right) \quad (6)$$

The exergy efficiency calculated under nominal conditions is supposed to be constant; therefore, it would be possible to define the GSHP performances (COP, Q_{GSHP}) at different temperatures conditions,

$$COP = \left(\frac{T_{w, out} + 273.15}{T_{w, out} - T_{grd}} \right) \eta_{ex, nom} \quad (7)$$

$$Q_{GSHP} = Q_{GSHP, nom} \left(\frac{T_{w, out} - T_{grd, nom}}{T_{w, out} - T_{grd}} \right) \quad (8)$$

To calculate the partial load, the EN 14825 calculation method is also used in this study. The COP at partial load (COP_{PL}) is thus defined as,

$$COP_{PL} = COP[1 - Cd(1 - CR)] \quad (9)$$

where COP is the performance at full load at the same temperature conditions. Cd is the degradation factor of the heat pump, and CR that is the capacity ratio. If the degradation factor is unknown or undetermined, EN 14825 suggests the value of 0.25. The capacity ratio is defined as the ratio between the load required ($Q_{GSHP, req}$) and maximum heating power of the heat pump (Q_{GSHP}) at temperature conditions defined by,

$$CR = \frac{Q_{GSHP, req}}{Q_{GSHP}} \quad (10)$$

For the proposed system, a commercial heat pump is chosen with a COP of 5.1 at W10/W35 conditions (according to EN 14511) and because Cd is unknown, it is assumed to be 0.25 according to EN 14825. To simulate a GSHP, it is necessary to know the temperature of the water coming from the ground out of the heat exchangers. In this case, it is assumed to be 9 °C and constant during the year.

Table 1
Efficiencies of the different components of the system and separate production.

Parameter	Efficiency
SOFC (1 kW, full load), thermal efficiency	$\eta_{\text{thermal,SOFC}} = 0.4378$
SOFC (1 kW, full load), electrical efficiency	$\eta_{\text{electrical,SOFC}} = 0.5299$
SOFC (1 kW, full load), heat-to-power ratio	$H/P = 0.8262$
SOFC auxiliaries consumption, efficiency on electrical output	$\eta_{\text{trans}} = 0.9068$
GSHP, coefficient of performances at W10/W35	$\text{COP} = 5.1$
Boiler	$\eta_{\text{boiler}} = 0.9$
Electricity (from grid)	$\eta_{\text{el}} = 0.439$

2.3. Water tank

A water tank is used to store the waste heat from the SOFC when its heat production is higher than the demand for space heating and/or DHW. The temperature range of the water tank will be between 45 °C and 95 °C for which the lower limit is the lowest hot water temperature set by the user and the higher temperature limit is to avoid vapor formation. For the very rare case when the temperature of the water tank is at upper limit of 95 °C and the waste heat from the SOFC is still available, it is proposed that there is a security system to dissipate the heat. For simplification, there is only one water tank to store the heat for both space heating and DHW. Different criteria could be used to choose the heat capacity of the water tank; however in this study, the heat capacity is assumed to be sufficient to keep heat dissipation below 1% of the total heat production.

3. Data collection

To simulate the energy consumption for a normal house in Denmark, data from the domestic hot water and electrical energy profile must be collected. Data for electricity consumption are taken from a study of heat and power cogeneration [20], which provides the annual consumption of a resort located in the northern countries of Europe, and also the data are logged and stored hourly. Data for the space heating demand is taken from Ref. [21] in which it is assumed that the useful surface of the house is approximately 150 m² and is located in the Copenhagen area. Fig. 3 shows the hourly annual demand for space heating, DHW and electricity. The annual total energy demand for space heating is 10,725 kWh, for DHW is 2970 kWh and for electricity is 3028 kWh. It shall be mentioned that these data are the average values and




Fig. 3. Average monthly demand on electricity, heat and domestic hot water (DHW) for a resort located in Denmark.

may change from household to household depending on the habits and living styles of the tenants.

4. Operation strategy

The operation strategy is an important part of the system designed and proposed here. Thermodynamic and economical performances are strictly related to the operation strategy in cogeneration and trigeneration systems [22]. An innovative operation strategy defined and analyzed in Ref. [22] is also used here, which does not follow electricity or heat demand separately, but considers both of them together and simultaneously. In this strategy, an electric equivalent load (EEL) parameter is defined, which is the electrical demand for both the user and the heat pump. It considers that user heat demand is covered partly by the waste heat of the SOFC and partly by the heat pump. This parameter is thus a function of:

- electrical (E_{USER}) and heating (H_{USER}) user demand;
- heat-to-power ratio (H/P) and auxiliaries consumption (η_{trans}) of the SOFC;
- heat pump efficiency (COP).

To define the EEL, some assumptions are made to simplify the calculation method. The electrical consumption of the user (E_{USER}) and electricity consumption of the GSHP (E_{GSHP}) are assumed to be covered only by the electricity produced from the SOFC (E) as,

$$E_{\text{USER}} + E_{\text{GSHP}} = E \quad (11)$$

The heating demand (H_{USER}) is assumed to be covered by both the GSHP (H_{GSHP}) and waste heat of the SOFC (H_{SOFC}) as,

$$H_{\text{USER}} = H_{\text{GSHP}} + H_{\text{SOFC}} \quad (12)$$

It is thus necessary to consider the efficiencies of both the SOFC and GSHP systems. Taking into account the consumption of the auxiliaries of the SOFC, the electricity of the SOFC can thus be found as,

$$E = \eta_{\text{trans}} E_{\text{SOFC}} \quad (13)$$

By relating the electricity and heat (H_{SOFC}) production of the SOFC using the parameter heat-to-power ratio (H/P),

$$H_{\text{SOFC}} = E_{\text{SOFC}} \frac{H}{P} \quad (14)$$

The Heat production of the GSHP (H_{GSHP}) is related to the electricity consumption with the coefficient of performances (COP) through,

$$H_{\text{GSHP}} = E_{\text{GSHP}} \text{COP} \quad (15)$$

The above equations define the EEL under different conditions. If the waste heat from the SOFC is sufficient to cover the heat demand of the user, then the EEL can be defined as

$$\text{EEL} = \frac{E_{\text{USER}}}{\eta_{\text{trans}}} \quad (16)$$

However, if the waste heat of the SOFC is not sufficient to cover the heat demand of the user, then it is defined as

$$\text{EEL} = \frac{1}{\eta_{\text{trans}}} \times \frac{E_{\text{USER}} + \frac{H_{\text{USER}}}{\text{COP}}}{1 + \frac{H/P}{\text{COP} \cdot \eta_{\text{trans}}}} \quad (17)$$




Fig. 4. Electric equivalent load with ELF 2 kW, annual overview. ELF 2 kW follows EEL until it is lower or equal to 2 kW (the darker color). (For interpretation of the references to color in this figure legend, the reader is referred to the web version of this article.)

After defining the EEL parameter, different operation strategies can be used:

- continuous operation (CO), where the produced electricity is constant during a period;
- equivalent electric load following (ELF), where the produced electricity will be equal to the EEL.

Under the CO strategy, the SOFC works at constant power every hour of the day. It is necessary to define which power fuel cell has to work because electricity, heating and DHW demands change hour by hour. Similarly, heating demand changes month

by month. This criterion is used for each month to calculate an average value for the EEL. The advantage of this strategy is that the SOFC produces the same amount of electricity constantly for a period of time (for many hours); therefore, the thermal stresses on the cells are eluded. The disadvantage is that a larger water tank is needed to store the heat when water is produced but not consumed. Moreover, the possibility of net metering will then be required to exchange electricity with the net because of mismatching between the electricity production and consumption.

The aim of the ELF operation strategy is to follow the EEL and to cover all of the energy requests of the entire system. The advantage




Fig. 5. Electric equivalent load with ELF 1 kW, annual overview. ELF 1 kW follows EEL until it is lower or equal to 1 kW (the darker color). (For interpretation of the references to color in this figure legend, the reader is referred to the web version of this article.)




Fig. 6. Electric equivalent load with continuous operation (CO) strategy, annual overview. CO follows a monthly average of EEL (the darker color). (For interpretation of the references to color in this figure legend, the reader is referred to the web version of this article.)

would be that the energy requirement from the grid is only a few times. The disadvantage would be that the fuel cell has to change the electricity production during operation time, and consequently, the thermal stresses on the cells would be higher than the CO strategy. The EEL is not constant during the day, and heating and especially DHW demands have peak hours during the day. If it is chosen to follow the EEL, then it necessary to cover the peaks, which in turn, requires a SOFC with a higher maximum power. However, using a more powerful SOFC (additional stacks) implicates higher cost and longer payback time.

Three different cases are analyzed here: the CO strategy with a 1-kW maximum electrical power, ELF with a 1-kW maximum power of the SOFC and ELF with 2 kW. Figs. 4 through 6 show the hourly EEL for ELF 2 kW, ELF 1 kW and CO, respectively. Each figure represents the electric equivalent load (EEL) and how the corresponding strategy covers it.

The ELF 2-kW (Fig. 4) operation strategy follows the EEL until the demand is lower than the maximum SOFC power, which is 2 kW. If the EEL is higher, then the SOFC works at 2 kW, and the difference between EEL and SOFC electrical production is covered with the grid. Under this strategy, the system is able to cover 96.3% of the total EEL demand. The ELF 1 kW (Fig. 5) is similar to ELF 2 kW but with a smaller nominal SOFC power that is 1 kW instead. It follows the EEL until 1 kW but when EEL is higher than 1 kW, the SOFC works at 1 kW. Because of a lower nominal power, ELF 1 kW covers 77.1% of the EEL demand. The CO (Fig. 6) strategy does not follow the EEL because the SOFC works continuously at a set power. The set point is the monthly average of the EEL. If the average is higher than 1 kW (maximum power of the SOFC), then the SOFC works at 1 kW.

Table 2
Size of the system components with different operation strategies.

	ELF 2 kW	ELF 1 kW	ELF CO
SOFC	2 kW	1 kW	1 kW
GSHP	8 kW	9 kW	9 kW
Water tank	70 l	70 l	100 l

The size of each component of the system is related to the operation strategy. ELF 1 kW has a smaller SOFC size than ELF 2 kW (1 kW and 2 kW, respectively); therefore, in the first case, it is necessary to have a larger heat pump for covering the heat demand. The size of the fuel cell, heat pump and water tank for different operation strategies is shown in Table 2. The size of the heat pump for ELF 2 kW is approximately 11% smaller than the heat pump for the other two strategies (ELF 1 kW and CO 1 kW), while the size of the water tank for the CO 1-kW strategy must be approximately 43% larger than the other two ELF strategies.

5. Cost estimation

To calculate the total cost of the plant, the investment cost for all of the components and the maintenance cost for heat pump and fuel cell shall be estimated first. These are explained below.

5.1. Components' purchase cost

The cost of the SOFC and related auxiliaries are analyzed first. In the future scenario and under serial production, the purchased cost of each SOFC stack (C_{stack} , in \$) can be estimated as [23],

$$C_{\text{stack}} = (N_{\text{cell}} \pi D_{\text{cell}} L_{\text{cell}}) (2.96 T_{\text{cell}} - 1907) \quad (18)$$

where N_{cell} is the number of the cells, D_{cell} is the diameter of the cell, L_{cell} is the length of the cell, and T_{cell} is the operating temperature of the cell in kelvin. Assuming the number of cells to be 74, the cell diameter to be 0.005 m, the cell length to be 0.12 m and the operating temperature to be 1073 K then the uninstalled cost of each stack can be estimated.

The purchased cost of a counter flow plate heat exchanger (C_{HEX} , in \$) is related to the area of the heat exchanger (A_{HEX} , in m^2) [23]. The area of the heat exchanger is related to the heat flow rate (Q , in W), log mean temperature difference (ΔT_{LMTD}) and heat transfer coefficient (U). For air–air heat exchangers (such as a fuel pre-heater), U is estimated to be $35 \text{ W}/(\text{m}^2 \text{ K})$, while for an air–water heat exchanger (heat recovery heat exchanger), its value is substantially higher and is estimated to be $133 \text{ W}/(\text{m}^2 \text{ K})$.

Table 3
Direct and indirect costs of a system related to PEC.

	PEC percentage
<i>Direct costs</i>	
Purchase – equipment installation	45% PEC
Piping	35% PEC
Instrumentation and controls	20% PEC
<i>Indirect costs</i>	
Engineering and supervisor	8% PEC
Construction costs and profit	15% PEC

$$C_{\text{HEX}} = 130 \left(\frac{A_{\text{HEX}}}{0.093} \right)^{0.78} \quad (19)$$

$$A_{\text{HEX}} = \left(\frac{Q_{\text{HEX}}}{U \Delta T_{\text{LMTD}} 0.093} \right)^{0.78} \quad (20)$$

The burner cost (C_{burner} , in \$) can be estimated from the mass flow of gases ($\dot{m}$ in kg/s) as [24]:

$$C_{\text{burner}} = 42 \left(\frac{\dot{m}}{0.028} \right)^{0.55} \quad (21)$$

To invert the DC from the fuel cells into AC, the inverter cost (C_{inv} , in \$) will be related to the power of the cell (W_{cell} , in W) [25].

$$C_{\text{inv}} = 10^5 \left(\frac{W_{\text{cell}}}{500} \right)^{0.7} \quad (22)$$

The compressor cost (C_{comp} , in \$) is estimated from the compression power (W_{comp} , in kW) [25]:

$$C_{\text{comp}} = 91,562 \left(\frac{W_{\text{comp}}}{445} \right)^{0.67} \quad (23)$$

The pre-reformer cost (C_{PR} , in \$) is related to its characteristics area (A_{PR} , in m^2) and volume (V_{PR} , in m^3) as in [23],

$$C_{\text{PR}} = 130 \left(\frac{A_{\text{PR}}}{0.093} \right)^{0.78} + 3240 V_{\text{PR}}^{0.4} + 21,280 V_{\text{PR}} \quad (24)$$

The cost of the desulfurizer (C_{des} , in \$) is related to its production volume (V_{prod} , assuming it is between 100,000 and 500,000 units/years), its fuel mass flow ($\dot{m}_{\text{fuel}}$, in kg/h) and system power (W_{sys} , in kW) [25],

$$C_{\text{des}} = 135.71 V_{\text{prod}}^{-0.1365} \dot{m}_{\text{fuel}}^{0.67} W_{\text{sys}}^{-1} \quad (25)$$

These costs are the purchase equipment cost (PEC) without considering additional costs arising from direct and indirect costs, such as piping, instrumentation, and electrical equipment. These additional costs can be related to the PEC through a simple estimation discussed in Ref. [26]. Table 3 shows values for each direct or indirect cost considered here. The PEC of other components such as chillers and tanks are not included in the PEC considered in Table 3 because those costs are related to the technical datasheet, and it is assumed that direct and indirect costs are also considered in the respective data sheet.

To convert from the US dollar [\$] to the Euro [€], the exchange rate used is 1.286 €/\$. It shall be mentioned that the cost for the SOFC system is estimated to be 3195 € for 1 kW of nominal electric power, and 5067 € for 2 kW SOFC system. These costs are in agreement with the present cost as well as target cost discussed in Refs. [27] and [28].

5.2. GHSP and water tank purchase cost

For the GSHP, an algebraic power regression is developed here to follow the technical datasheet of the heat pump and relates the cost of the heat pump (C_{HP} , in €) to the nominal heating power of the GSHP (P , in kW). The regression is found to be

$$C_{\text{HP}} = 4704.2 P^{0.2231} \quad (26)$$

It is also necessary to estimate the cost of the ground heat exchanger coupled with the necessary drilling. A calculation method is thus proposed to calculate the heat absorbed by the GSHP (P_{ABS}), which is related to the nominal heating power (P_{nom}) and to the electric consumption of the heat pump (El_{cons}). The electrical consumption is in turn related to the COP of the heat pump as,

$$P_{\text{ABS}} = P_{\text{nom}} - \text{El}_{\text{cons}} = P_{\text{nom}} - \frac{P_{\text{nom}}}{\text{COP}} = P_{\text{nom}} \left(1 - \frac{1}{\text{COP}} \right) \quad (27)$$

The cost related to ground coupling and drilling is approximately 1 € of each 1 W of the absorbed heat (P_{ABS}) from the ground. These criteria are chosen to simplify the cost estimation; otherwise, a cost estimation in €/m of the ground coupling is usually used.

Similarly, for the water tank (storage), a power regression is developed to follow the technical datasheet of the tank and relate the cost estimation ($C_{\text{watertank}}$, in €) to the capacity of the tank ($\dot{m}_{\text{water}}$ in kg/s) as,

$$C_{\text{water tank}} = 12.333 \dot{m}_{\text{water}}^{0.813} \quad (28)$$

5.3. Maintenance cost

The annual maintenance cost for the SOFC is proposed to be 23.23 €/stack (£ 20/stack) according to [29], with an exchange rate of £ 1 = 1.1617 €. For the GSHP, the annual maintenance cost is 1% of the purchase cost according to Ref. [30]. The maintenance costs are affected by inflation, which is assumed to be 2% for all periods (this is the highest acceptable inflation for the ECB). Thus, one has

$$C_t = C_0 (1 + i_{\text{inf}})^{t-1} \quad (29)$$

where C_t is the cost at period t , i_{inf} is the inflation rate, C_0 is the cost at the end of the first year and t is the time period. In the equation, $t - 1$ is used instead of t because the cost of the first year is given, and this cost is assumed to be constant until the next year.

5.4. Energy cost

To calculate the operating cost of the system, it is essential to know the cost of electricity and fuel in Denmark. Data referred to in the second half-year of 2012 was chosen as 0.2972 €/kWh for electricity [31] and 0.1083 €/kWh for natural gas [32] (including tax). Energy prices of gas and electricity are not constant and vary every year. Therefore, it is necessary to define an index, which accounts for the increase of both electricity and gas prices per year. The average yearly increase in the price of electricity and gas has been assumed to be 3.75% and 3.84%, respectively, which corresponds to recent years (2009–2013) in Denmark [31,32]. Thus, one has

$$C_t = C_0 (1 + i_c)^{t-1} \quad (30)$$

where C_t is the cost at period t , i_c is the increasing index for the price, C_0 is the cost at the end of the first year and t is the period. In the equation, $t - 1$ is used instead of t because the cost of the first year is given, and it is assumed to be constant until the next year.

6. Thermodynamic analysis

To analyze the system, thermodynamic benchmarks are used:

- overall efficiency of the fuel cell;
- *primary energy saving* (PES) of the entire system (fuel cell and heat pump);
- production and consumption of different types of energy (electricity and heat) divided for each component of the system.

To provide the same quantities of energy, PES is related to the fuel consumption of the fuel cell, energy consumption of the system (electricity and heat) and also to the efficiency that a traditional system with separated production of heat and electricity has. PES is defined according to the study of a trigeneration system in Ref. [22] as

$$\%PES = 1 - \frac{F_{SOFC} + \frac{E_{Grid}}{\eta_{el}}}{\frac{H_{Demand}}{\eta_{boiler}} + \frac{E_{Demand}}{\eta_{el}}} \quad (31)$$

F_{SOFC} is the fuel consumption of the system, E_{GRID} is the net electricity consumption from the grid (if the system has an exchange of electricity with the grid, then the difference between these two variables is considered), H_{DEMAND} is the heat demand from the user, and E_{DEMAND} is the electricity demand of the user. η_{boiler} is the efficiency of a traditional gas boiler used in a traditional system that covers heating and DHW demands. η_{el} is the efficiency of an electric energy consumer from the grid, considering both generation with a traditional power plant and grid efficiency. A traditional system covers the electricity demand only from the grid, while the innovative system proposed consumes electricity from the grid only when the SOFC produces less electricity than the demand from the user and/or heat pump. Table 1 shows the values that are considered here.

The overall efficiency of the fuel cell (η_{SOFC}) can be defined as

$$\eta_{SOFC} = \frac{E + H_{SOFC}}{F_{SOFC}} \quad (32)$$

where E is the net electricity produced by the SOFC (considering auxiliaries consumption and inverter efficiency), H_{SOFC} is the heat available and F_{SOFC} is the fuel consumption.

Fig. 7 shows the PES and overall efficiency of the fuel cell for all of the different strategies discussed above (ELF 2 kW, ELF 1 kW and ELF CO). As seen, the overall efficiency is higher than 90% for all of the cases considered, while the PES is higher than 45%.




Fig. 7. Fuel cell efficiency and %PES for all of the strategies.




Fig. 8. Energy flux for the ELF 2-kW operation strategy.

6.1. ELF 2 kW

The ELF 2-kW case has the highest value of PES (49.45%) because of the size of the SOFC. A larger fuel cell is able to cover more electricity demand and GSHP consumption. It is also able to cover more waste heat so that the heat required by the heat pump is lower. Under this operation strategy, the electricity required to the grid is low. Fig. 8 shows that only 212 kWh of electricity is consumed from the grid during the periods of high request, and 198 kWh is provided to the grid when the consumption is lower than the request.

6.2. ELF 1 kW

The system working under ELF 1 kW has a smaller fuel cell (nominal power of 1 kW instead of 2 kW); therefore, both the electricity and heat demand covered by the fuel cell is lower compared with the previous case. Consequently, the PES decreases to 45.33%. Fig. 9 shows that the heat recovery is 3854 kWh (28.15% of the user heat demand, 13,695 kWh) while under ELF 2 kW, the heat recovery is 4765 kWh (34.8% of the user heat demand). The electricity consumption from the grid is thus higher because of lower electricity production (4340 kWh in ELF 1 kW instead of 5472 kWh in ELF 2 kW) and because the heat pump consumes more electricity than the ELF 2-kW case, (it is related to the lower waste heat available). Higher electricity consumptions from the grid explain why the PES decreases in this case compared to the previous case.

6.3. ELF CO

The system working under the ELF CO strategy has a fuel cell with constant electricity and heat production during the day. This




Fig. 9. Energy flux for the ELF 1-kW operation strategy.




Fig. 10. Energy flux for the ELF CO strategy.




Fig. 12. Sensitivity analysis on the purchase cost with ELF 2 kW.

constant value is the average of the electricity required during the considered period. Fig. 10 displays this operation strategy has a high exchange of electricity with the grid. Electricity from the grid of 1802 kWh is consumed when the consumption is higher than the demand, while 2025 kWh is given to the grid when the consumption is lower than the demand. This is related to mismatching between the production and consumption of electricity. Because of this mismatching, the heat losses are the highest of all of the cases analyzed here (199 kWh).

7. Economic analysis

The primary aim of the proposed system is to save energy because higher overall efficiency means savings on electricity consumption and/or fuel by lowering the annual operating cost. Each system is analyzed using the following economical benchmarks:

- *Net Present Value (NPV)* and *Pay Back (PB) time* to evaluate the revenue and the duration of the investment. The life expectation of the system is considered to be 20 years, and the interest rate is taken as $i = 3\%$;
- The *Sensitivity Analysis* evaluates which variation of variables (energy costs, fuel cell or other component prices) has a higher influence on the convenience of the investment. It is a useful tool not only for the uncertainty on the prices and the costs in the future but also for understanding which parameters are more important for consideration. The sensitivity analysis is chosen to vary between -50% and 100% of the component purchased cost and between 1% and 10% of the average increasing index of energy costs (both gas and electricity) to see how they affect the NPV value.




Fig. 11. NPV with ELF 2 kW.

No subsidy is considered; thus, the ELF CO strategy is not analyzed here because of the high exchange of electricity between the grid and system. It would be necessary to consider the net metering value, that is, a type of subsidy for power generation.

7.1. ELF 2 kW

The system under the ELF 2-kW operation strategy has an NPV of € 7300 with a PB time of 15 years (Fig. 11). Fig. 12 indicates that the system has a higher sensitivity for the purchase cost of the heat pump. Additionally, by increasing the SOFC purchase cost by 100%, the NPV will still be positive. Uncertainty on the SOFC cost is high because the purchasing cost is an estimation for the future scenario when production volume is sufficiently high. This analysis confirms that there are margins on the higher price of the fuel cell. The gas and electricity prices have different weights on the profit of a system, and it would be interesting to see their effect on the system analyzed here. Fig. 13 displays that if the annual increasing cost rate is lower than 4%, the NPV is more sensitive to the gas price versus the electricity price. If the annual rate is higher than 4%, then the NPV is more sensitive to the electricity price.

7.2. ELF 1 kW

The system under the ELF 1-kW operation strategy has an NPV of € 4800 with a PB time of 16 years (Fig. 14). The purchase cost of the fuel cell is lower in this case because of lower nominal power,




Fig. 13. Sensitivity analysis on the energy cost with ELF 2 kW.




Fig. 14. NPV with ELF 1 kW.

and as the result, the NPV is less sensitive on the SOFC purchase cost. By increasing the fuel cell purchase cost by 100%, the NPV will still be positive as shown in Fig. 15. For electricity and gas prices, Fig. 16 shows that the system is more sensitive when increasing the gas price versus the electricity price. The results are quite different compared to the previous operation strategy discussed above (c.f. Fig. 12), and this can be explained by the different consumption of fuel and electricity from the grid under these operating strategies (c.f. Figs. 8 and 9).

8. Conclusions

An innovative cogeneration system based on the SOFC and GSPH is proposed for a resort located in a northern European country (Denmark). Additionally, an innovative parameter (electric equivalent load) is used to accomplish both the electricity and heat demand of the user and also define three different operation strategies, including ELF 2 kW, ELF 1 kW and ELF CO. For all cases, it is found that there is a high primary energy saving and that the system is profitable, even though the payback time is high (15–16 years). The uncertainty of the energy price and inflation rate is high during a long period.

The ELF 2-kW operation strategy confirms that the system proposed could be independent from the grid when the system is allowed to exchange electricity with the grid and when there is mismatching between The electricity production and request. Eventually, other electrical storage could be interesting to study to make the system stand-alone and independent to the grid.

The ELF 1-kW operation strategy has the highest value of NPV, even if the payback time is the same as the ELF 2 kW strategy. Both




Fig. 15. Sensitivity analysis on the purchase cost with ELF 1 kW.




Fig. 16. Sensitivity analysis on the energy cost with ELF 1 kW.

the ELF 2 kW and ELF 1 kW strategies requires a small water tank because they have the capacity of following the heat demand from the user.

The ELF CO operation strategy also gives high primary energy saving even though the fuel cell works at constant load and does not follow the user demand. In this strategy, high thermal stress because of frequent start and shutdown is avoided. Mismatching between the electricity production and consumption is high, and the economic analysis of this strategy could only be performed once the net metering subsidy is available.

The SOFC stack purchase cost is not the highest weight of profitability for the system proposed here, and this is in fact an advantage because the fuel cell cost is estimated under the assumption of high volume production and therefore allows margins for the higher purchase cost of the stacks.

Gas and electricity have a different weight on the profitability of the system and depend on the operation strategy and annual increase in energy cost.

High thermodynamic performances and a positive NPV prove that this cogeneration system could be a possible solution for household application both for energy saving and distributed generation because the users will be able to cover their own electricity consumption.

References

- [1] Sanchez D, Chacartegui R, Torres M, Sanchez T. Stirling based fuel cell hybrid systems: an alternative for molten carbonate fuel cells. *Power Sources* 2008;192:84–93.
- [2] Rokni M. Thermodynamic analysis of SOFC (solid oxide fuel cell) – Stirling hybrid plants using alternative fuels. *Energy* 2013;61:87–97.
- [3] Lee KH, Strand RK. SOFC cogeneration system for building applications, part 2: system configuration and operating condition design. *Renew Energy* 2009;34(12):2839–46.
- [4] Calise F, Dentice d'Accadia M, Palombo A, Vanoli L. Simulation and exergy analysis of a hybrid solid oxide fuel cell (SOFC)–Gas turbine system. *Energy* 2006;31:3278–99.
- [5] EG&G and G Technical Services Inc.. Fuel cell handbook. 7th ed. U.S. Department of Energy, Office of Fossil Energy, National Energy Technology Laboratory; 2004.
- [6] Riensche E, Achenbach E, Froning D, Haines MR, Heidug WK, Lokurlu A, et al. Clean combined-cycle SOFC power plant—cell modeling and process analysis. *Power Sources* 2000;86(1–2):404–10.
- [7] Bellomare F, Rokni M. Integration of a municipal solid waste gasification with solid oxide fuel cell and gas turbine. *Renew Energy* 2013;55:490–500.
- [8] Rokni M. Thermodynamic analysis of an integrated solid oxide fuel cell cycle with a rankine cycle. *Energy Convers Manag* 2010;51(12):2724–32.
- [9] Rokni M. Plant characteristics of an integrated solid oxide fuel cell and a steam cycle. *Energy* 2010;35:4691–9.
- [10] Pierobon L, Rokni M, Larsen U, Haglund F. Thermodynamic analysis of an integrated gasification solid oxide fuel cell plant combined with an organic Rankine cycle. *Renew Energy* 2013;38:226–34.

- [11] Rokni M. Biomass gasification integrated with a solid oxide fuel cell and Stirling engine. *Energy* 2014;77:6–18. <http://dx.doi.org/10.1016/j.energy.2014.01.078>.
- [12] Cooper SJG, Hammond GP, McManus MC, Ramallo-Gonzalez A, Rogers JG. Effect of operating conditions on performance of domestic heating systems with heat pumps and fuel cell micro-cogeneration. *Energy Build* 2014;70:52–60.
- [13] Bompard E, Napoli R, Wan B, Orsello G. Economics evaluation of a 5kW SOFC power system for residential use. *Hydrogen Energy* 2008;33:3243–7.
- [14] Farhad S, Hamdullahpur F, Yoo Y. Performance evaluation of different configurations of biogas-fuelled SOFC micro-CHP systems for residential applications. *Hydrogen Energy* 2010;35:3758–68.
- [15] Liso V, Brandon N, Zhao Y, Nielsen MP, Koer SK. Analysis of the impact of heat-to-power ratio for a SOFC-based mCHP system for residential application under different climate regions in Europe. *Hydrogen Energy* 2011;36:13715–26.
- [16] Lamas J, Shimizu H, Matsumura E, Senda J. Fuel consumption analysis of a residential cogeneration system using a solid oxide fuel cell with regulation of heat to power ratio. *Hydrogen Energy* 2013;38:16338–43.
- [17] UNI/TS 11300-4. "Renewable energy and other generation systems for space heating and domestic hot water production" (Italian). Ente Nazionale Italiano di Unificazione; 2010.
- [18] EN 14825. Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling - testing and rating at part load conditions and calculation of seasonal performance. European Committee for Standardisation; 2008.
- [19] Busato F, Lazzarin R, Noro M. Energy and economic analysis of different heat pump systems for space heating. *Low-Carbon Technol* 2012;7:104–12.
- [20] Annex 42. The simulation of building-integrated fuel cell and other cogeneration systems (COGEN-SIM). IEA Energy Conservation in Buildings & Community Systems; Feb. 2014. Online available: <http://www.ecbcs.org/annexes/annex42.htm>.
- [21] Typisk varmeforbrug. Varde Forsyning A/S. Online available: <http://vardeforsyning.dk/Varde/Typisk-varmeforbrug.aspx>; Feb. 2014 [in Danish].
- [22] Kavvadias KC, Tosios AP, Maroulis ZB. Design of a combined heating, cooling and power system: sizing, operation strategy selection and parametric analysis. *Energy Convers Manag* 2010;51(4):833–45.
- [23] Arsalis A. Thermo economic modelling and parametric study of hybrid SOFC–gas turbine–steam turbine power plants ranging from 1.5 to 10 MWe. *Power Sources* 2008;181(2):313–26.
- [24] Zhang J, Yamanis J. Techno-economical feasibility of highly efficient cost-effective thermoelectric-SOFC hybrid power generation system. United Technologies Research Centre; 2007. DE-FC26-05NT42626, <http://www.osti.gov/scitech/biblio/967360>.
- [25] Braun R. Techno-economic optimal design of solid oxide fuel cell system for micro-combined heat and power application in U.S. *ASME Fuel Cell Sci Technol* 2010;7:031018–21.
- [26] Bejan A, Tsatsaronis G, Moran M. Thermal design and optimization. New York: John Wiley and Sons Inc.; 1996.
- [27] Otomo J, Oishi J, Mitsumori T, Iwasaki H, Yamada K. Evaluation of cost reduction potential for 1 kW class SOFC stack production: implications for SOFC technology scenario. *Hydrogen Energy* 2013;38:14337–47.
- [28] Staffell I, Green R. The cost of domestic fuel cell micro-CHP systems. *Hydrogen Energy* 2013;38:1088–102.
- [29] Hawkes AD, Aguiar P, Hernandez-Aramburo CA, Leach MA, Brandon NP, Green TC, et al. Techno-economic modelling of a solid oxide fuel cell stack for micro combined heat and power. *Power Sources* 2006;156(2):321–33.
- [30] Dickinson J, Jackson T, Matthews M, Cripps A. The economic and environmental optimisation of integrating ground source energy system into building. *Energy* 2009;34(12):2215–22.
- [31] Electricity prices for domestic consumers, from 2007 onwards - bi-annual data (last update: 22-05-2013). Eurostat; 2013. http://appsso.eurostat.ec.europa.eu/nui/show.do?dataset=nrg_pc_204&lang=en [accessed 15.07.13].
- [32] Gas prices for domestic consumers, from 2007 onwards - bi-annual data (last update: 22-05-2013). Eurostat; 2013. http://appsso.eurostat.ec.europa.eu/nui/show.do?dataset=nrg_pc_202&lang=en [accessed 15.07.13].