



Forecasting methods in energy planning models

Kumar Biswajit Debnath*, Monjur Mourshed

School of Engineering, Cardiff University, Cardiff CF24 3AA, United Kingdom

ARTICLE INFO

Keywords:

Forecasting methods
prediction
energy demand
load forecasting
energy planning models

ABSTRACT

Energy planning models (EPMs) play an indispensable role in policy formulation and energy sector development. The forecasting of energy demand and supply is at the heart of an EPM. Different forecasting methods, from statistical to machine learning have been applied in the past. The selection of a forecasting method is mostly based on data availability and the objectives of the tool and planning exercise. We present a systematic and critical review of forecasting methods used in 483 EPMs. The methods were analyzed for forecasting accuracy; applicability for temporal and spatial predictions; and relevance to planning and policy objectives. Fifty different forecasting methods were identified. Artificial neural network (ANN) is the most widely used method, which is applied in 40% of the reviewed EPMs. The other popular methods, in descending order, are: support vector machine (SVM), autoregressive integrated moving average (ARIMA), fuzzy logic (FL), linear regression (LR), genetic algorithm (GA), particle swarm optimization (PSO), grey prediction (GM) and autoregressive moving average (ARMA). Regarding accuracy, computational intelligence (CI) methods demonstrate better performance than that of the statistical ones, in particular for parameters with greater variability in the source data. Moreover, hybrid methods yield better accuracy than that of the stand-alone ones. Statistical methods are used for only short and medium range, while CI methods are preferable for all temporal forecasting ranges (short, medium and long). Based on objective, most EPMs focused on energy demand and load forecasting. In terms, geographical coverage, the highest number of EPMs were developed in China. However, collectively, more models were established for the developed countries than the developing ones. Findings would benefit researchers and professionals in gaining an appreciation of the forecasting methods and enable them to select appropriate method(s) to meet their needs.

1. Introduction

Increasing greenhouse gases (GHGs) emission contribute to global warming, resulting in amplified global temperature and associated vulnerabilities [1]. Mitigating the impacts of climate change requires the reduction or at the very least the stabilization of atmospheric CO₂ concentrations, which can be achieved by decreasing global carbon outflow from energy and land-use sectors, the two major GHG sources. Emissions from land-use have been nearly constant, while the emissions from fossil fuel based energy system climbed up by 29% between 2000 and 2008 [2]. If current GHG concentrations remain constant, the world will experience a few centuries of rising mean temperatures and sea levels [3–5]. Studies suggest that the current energy and transportation systems are likely to be responsible for significant CO₂ discharges over the next fifty years [6], which can increase the global mean temperature by approximately 1.1–1.4 °C between 2010 and 2060 [7]. Future initiatives on energy planning and development should, therefore, focus on decarbonizing the energy generation and demand sectors.

Research indicates that CO₂ emissions are negatively associated with national expenditure on energy research; therefore, the transition away from carbonintensive energy generation for atmospheric CO₂ stabilization will require significant investments in innovative energy research and development [8].

EPMs are essential for assisting stakeholders in making informed decisions for future energy sector development – globally, regionally and nationally. The development of EPMs started in the 1960's [9], but the interest in them increased after the oil crisis in the 1970's that highlighted the effects of dependency on conventional fuel sources on global, regional and national economies, in particular, the role of exogenous political events on the oil market [10]. The crisis acted as a catalyst for the critical assessment of fuel resources, rational use and conservation of energy resources, and long-term energy planning for global, regional, national and sectoral utilization [11]. Also, the Rio Earth Summit in 1992 and the report of the Intergovernmental Panel on Climate Change (IPCC) in 1995 triggered further environmental studies on GHG emissions [12], while cautiously concluding that CO₂ emissions

* Corresponding author.

E-mail address: DebnathK@cardiff.ac.uk (K.B. Debnath).

Table 1
Searched keywords and associated groups.

Model	Objective	Geographical extent	Time horizon
Energy	Forecasting	Global	Short
Electricity	Projection	Regional	Medium
Energy information		Country	Long
Energy economic			
Energy supply and/or demand			
Emission reduction			
Energy planning			

had a noticeable impact on the environment [13]. Intensive discussions and debates followed, legislations were formulated, and GHG emission reduction targets were set; e.g., Kyoto Protocol in 1998. Although separate models for the evaluation, projection, and alleviation of environmental impacts were created, EPMs played a critical role in identifying system boundaries and underlying relationships between the socio-technical parameters of energy, economy and environment.

Different authors reviewed EPMs in previous years. Nguyen (2005) classified EPMs into six categories – energy information systems, macroeconomic, energy demand, energy supply, modular package and integrated models [9]. Pfenninger et al. categorized EPMs into four types – energy system optimization; energy system simulation; power system and electricity market and qualitative and mixed-method scenarios [14]. Most of the reviews focused on classifying the energy planning models as a whole, rather than investigating and categorizing the underlying forecasting methods. Suganthi investigated the models for forecasting energy demand [15], albeit only partially. Moreover, parameters for categorizing forecasting methods are not same as for EPMs. The choice of forecasting method can affect the accuracy and validity of results in an EPM.

Previous studies on forecasting methods of EPMs either divided the topic into its areas of application or the broad categories of underlying techniques. Application areas are always evolving – through the integration of new domains and concepts, as well as by expanding the breadth and depth of a modeled domain. The difficulty arises when previously categorized application areas are not flexible enough to accommodate a new area. For example, behavioral energy conservation is an important environmental psychology aspect of climate and energy debate; and widely considered for the modeling of energy use in buildings and transportation, as well as for national energy demand forecasting and policy making.¹ On the other hand, dividing forecasting methods based on the underlying techniques has similar issues. For example, Weron classified forecasting methods into two broad categories – statistical approaches and artificial intelligence (AI) based techniques [16]. The developments in computing over the past decades have enabled the use of compute-intensive methods for improved accuracy and reduced computation time, thereby enhancing their applicability. AI techniques are now widely used to tune up parameters in statistical models. Moreover, some soft computing or computational intelligence² techniques routinely use advanced statistical concepts. Therefore, categorizing the forecasting methods as either statistical or

¹ Examples of the use of behavioral aspects of public energy conservation in policy making can be found in Japan's Third National Communication under the United Nations Framework Convention on Climate Change (UNFCCC) (<http://unfccc.int/resource/docs/natc/japnc3.pdf>) and Energy Outlook of Vietnam through 2025 (http://open.jicareport.jica.go.jp/pdf/11899796_02.pdf).

² It can be argued that the so called AI methods used in forecasting are in fact, more specifically, computational intelligence (CI) techniques, also known as soft computing in AI. For further information on how computational intelligence branched out from general AI, initially to distinguish neural networks from hard AI but later to incorporate fuzzy systems and evolutionary computation, the reader is referred to the history of IEEE Computational Intelligence Society (CIS) at http://ethw.org/IEEE_Computational_Intelligence_Society_History.

artificial intelligence not only gives an inaccurate account but also hinders the informed comprehension of the strengths and weaknesses of different approaches. The hybridization of methods to suit application areas is characterized by data incompleteness and uncertainty; temporal and spatial variability; and domain features – all of which mandates a new classification scheme.

Existing reviews thus lack a comprehensive coverage regarding scope, accuracy, and applicability. The objective of this review is, therefore, to analyze the methods utilized in different EPMs to investigate their accuracy, objective, temporal and spatial extents with a view to identifying the factors behind the choice of forecasting methods. Findings of this study would benefit researchers in gaining an appreciation of the methods, as well as enable them to select appropriate forecasting methods for future research.

2. Methodology

A state-of-the-art systematic review was undertaken on published electronic resources for the study of underlying forecasting methods in EPMs. A preliminary study was conducted to gather an overview of the topics related to forecasting methods in energy planning. The identified main topics were: energy demand and/or supply model and/or forecasting; energy planning models; emission reduction models; time series analysis; and forecasting. These topics were used to identify relevant keywords, listed in Table 1. Keywords were then utilized to search electronic databases: Google Scholar, ScienceDirect, Scopus, Ei Compendex and Web of Science, for relevant publications on forecasting methods of EPMs.

An advanced search was conducted within the databases by categorizing keywords into four-word groups and by combining them using the Boolean operator 'AND.' The search was conducted in two stages. Firstly, the model, objective and geographical extent keywords were used. Secondly, the model, objectives, methods, and analysis measures were applied. The initial search results at each stage were refined by applying the following inclusion criteria:

- Objective: Energy forecasting
- Language: English
- Sources: Publications from journals related to energy and core forecasting and planning of energy; fossil fuel; renewable energy; carbon emissions.

Abstracts of the selected publications were scrutinized. Articles were chosen for review if the substance was within the scope of the study. A further search was conducted on the recognized authors who had contributed noticeably in related fields. 600 publications were found from the search. The criteria for retention were:

- Studies covering energy demand and/or supply forecasting
- Studies with significant contribution in forecasting of GHG emissions
- Studies on forecasting methods for energy planning
- Key review articles from established authors/institutions in the area of energy forecasting and planning models

Finally, 483 publications and reviews on energy forecasting and planning were retained for analysis and interpretation.

3. Classification

Forecasting involves the predictions of the future based on the analysis of trends of present and past data, comprising three major components: input variables (past and present data), forecasting/estimation methods (analysis of trends) and output variables (future predictions), as shown in Fig. 1. Based on the number of techniques used for trend analysis, the investigated methods can be broadly classified




Fig. 1. Basic forecasting or estimation model structure.

into two main types: stand-alone and hybrid. Stand-alone methods apply a single technique for analyzing trends whereas hybrid methods integrate more than one stand-alone techniques. In most cases, the purpose of hybridization is to rationalize or make reliable forecast output and to yield higher projection accuracy.

Based on the type of techniques, stand-alone methods are divided into three categories: statistical, computational intelligence (CI) and mathematical programming (MP). Hybrid methods are divided into four: statistical-statistical, statistical-CI, CI-CI and statistical-MP methods. Some of the reviewed literature utilized multiple stand-alone and/or hybrid methods for comparison and critique. To obtain a comprehensive picture in this paper, underlying techniques in hybrid methods are also separately accounted for in the stand-alone method categories in Tables 2, 3.

The methods are also analyzed by geographical extent and forecasting time frame. Geographical extent was divided into three categories: global, regional and country. Global refers to the whole world; regional for a part of the world; e.g., Asia, Europe, G-8, and Sub-Saharan Africa; and country for an individual country. Models with geographical extent covering parts of a country are incorporated in the country category for brevity.

The time frame of the forecasted models ranges from hours to 100 years. Grubb [17] suggested five years or less for the short-term, between 3 and 15 years for the medium-term, and ten years or more for the long-term. However, this classification creates confusion for the medium- and long-term projections because of the overlapping time spans. This research, therefore, utilizes the following definitions for time span or modeling horizons: short- ($t < 3$), medium- ($3 \leq t \leq 15$) and long-term ($t > 15$), where t is time span in years.

The statistical and CI & MP based classification is presented in Tables 2 and 3 respectively, illustrating the techniques used, geographical extent and forecasting time frame, as well as the number of studies and references.

It is evident from the analysis of 483 studies that diversity in statistical methods is more prominent than computational intelligence and mathematical programming. 28 different statistical methods have been used, compared to 22 CI and one MP for forecasting. Among the statistical methods in Table 2, autoregressive integrated moving average (ARIMA) (46 models) followed by linear regression (LR) (39 models), autoregressive moving average (ARMA) (22 models) and logistic regression (LoR) (19 models). However, cointegration was widely used (48 models) technique to analyze the relationship among the variables. ARIMA, LR and other statistical methods were utilized to forecast.

With regard to CI techniques, ANN was used in 194 models, followed by SVM (58 models), FL (40 models), GA (39 models), PSO (34 models) and GM (29 models) (Table 3). In respect to geographical extent, global and regional models mostly adopt statistical methods. However, country-based models utilized a wide range of methods (statistical and CI) for forecasting (Tables 2 and 3).

Forecasting models, which adopted metaheuristic methods to

develop a hybrid method, utilized genetic algorithm and particle swarm optimization most of the time. Also, global models utilized metaheuristic methods such as GA, PSO and Artificial bee colony optimization (ABCO). Moreover, country wise forecasting models utilized a wide range of methods both metaheuristic and MP.

In case of the temporal span, statistical methods are suitable for short-term (Table 2), and CI methods are suitable for all temporal (Short, medium and long) forecasting (Table 3).

4. Stand-alone methods

Most of the analyzed models adopted stand-alone methods, which can be divided into three categories- statistical, computational intelligence (CI) and mathematical programming (MP) methods.

4.1. Statistical methods

Statistics methods investigate the accumulation, examination, elucidation, presentation, and association of data [18] and can be divided into several categories from the analyzed models. For example:

4.1.1. Regression analysis

There are different regression methods for forecasting. Among, the regression methods six methods were utilized in the studied models. The methods were: Linear regression (LR), ordinary least squares (OLS), nonlinear regression (NLR), logistic regression (LoR), nonparametric regression (NR), partial least squares regression (PLSR) and stepwise regression (SR).

Thirty-nine reviewed models utilized linear regression (LR) method. LR is applied to model the relationship between two variables by fitting a linear equation to observed data [19]. Among the reviewed models which utilized LR, 89.7% models forecasted energy and electricity demand.

Three forecasting models utilized non-linear regression (NLR). Bilgili et al. forecasted the electricity consumptions of Turkey with NLR [20]. Ghiassi et al. proposed a dynamic artificial neural network (DAN2) model for forecasting nonlinear processes and compared to NLR; the method was effective for forecasting nonlinear processes [21]. Tsekouras et al. developed a nonlinear multivariable regression to midterm energy forecasting of power systems of Greece [22]. Logistic or logit regression (LoR) was applied in 19 reviewed models, of which 68.4% models forecasted energy and electricity demand.

Three models utilized nonparametric regression (NR) method. NR establishes model according to the data from larger sample sizes. Charytoniuk et al. developed a short-time load forecasting model by applying NR [23]. Another study applied NR model to short-term wind power forecasting [24]. Jónsson et al. presented an analysis of how day-ahead electricity spot prices are affected by day-ahead wind power forecasts. The author utilized NR to assess the wind power forecast [25].

Partial least squares regression (PLSR) was applied in two forecasting models. Zhang et al. forecasted China's transport energy demand for 2010, 2015 and 2020 with PLSR method. The results demonstrated transport energy demand for 2020 will reach a level of around 433.13 million tons of coal equivalent (Mtce) and 468.26 Mtce, respectively [26]. Meng et al. analyzed and forecasted China's annual electricity consumption with PLSR. It showed real estate and relative industry electricity consumption was affected by unusual development [27].

Seven models forecasted with stepwise regression (SR) method. Ekonomou utilized SR to estimate energy consumption of Greece for 2005–2015 to compare with the results produced by LR and ANN method [28]. Tso et al. utilized SR method to predict electricity consumption in Hong Kong [29]. Rao et al. utilized SR to select the relevant cross-products to be used in a non-homothetic Translog function to forecast and analysis of demand for petroleum products in India [30].

Table 2
Analysis of stand-alone statistical methods utilized in forecasting models.

Methods	Geographical extend			Time frame of forecasting			Number of models	References
	Global	Region	Country	Short	Medium	Long		
Linear regression (LR)	■	-	■	■	■	■	39	[19,20,28,71–73,115,122,123,129,141,146,164,175,187–211]
Nonlinear regression (NLR)	-	-	■	■	■	■	3	[20–22]
Logistic regression (LoR)	-	■	■	■	■	■	19	[73,74,103,193,212–226]
Nonparametric regression (NR)	-	-	■	■	-	-	3	[23–25]
Partial least squares regression (PLSR)	-	-	■	-	■	-	2	[26,27]
Stepwise regression (SR)	-	-	■	-	■	-	7	[28–31,207,227,228]
Moving average (MA)	-	-	■	-	■	-	4	[32–35]
Autoregressive integrated moving average (ARIMA)	-	■	■	■	■	■	46	[35,36,38,40,41,43,47,62,108,117,126,128,134,136,138,139,141,143,165,229–254]
Seasonal autoregressive integrated moving average (SARIMA)	-	■	■	■	■	■	13	[34,36–46,255]
Autoregressive moving average model with exogenous inputs (ARMAX)	-	-	■	■	■	-	10	[35,48–52,191,256–258]
Autoregressive moving average (ARMA)	-	-	■	■	-	-	22	[48,129,137,140,145,161,180,237,246,259–271]
Vector autoregression (VAR)	■	■	■	-	■	■	13	[53,75,272–282]
Bayesian vector autoregression (BVAR)	-	-	■	-	■	-	4	[53–56]
Structural Time Series Model (STSM)	-	-	■	-	■	■	3	[58,59,283]
VARIMA	-	-	■	■	-	-	1	[57]
Generalized autoregressive conditional heteroskedasticity (GARCH)	-	■	■	■	■	-	14	[49,52,60,136,137,175,251,284–290]
Seasonal exponential form of generalized autoregressive conditional heteroscedasticity (SEGARCH)	-	-	■	■	-	-	1	[61]
Exponential generalized autoregressive conditional heteroscedasticity (EGARCH)	-	-	■	■	-	-	1	[62]
Winters model with exponential form of generalized autoregressive conditional heteroscedasticity (WARCH)	-	-	■	■	-	-	1	[61]
Autoregressive distributed lag (ARDL)	-	■	■	-	■	■	6	[58,59,63–66]
Log-linear analysis (LA)	-	■	■	-	■	■	4	[67–70]
Geometric progression (GP)	-	-	■	-	■	■	3	[71–73]
Transcendental logarithmic (Translog)	-	-	■	-	■	■	2	[30,74]
Polynomial curve model (PCM)	-	-	■	-	■	-	1	[33]
Partial adjustment model (PAM)	-	-	■	■	■	-	4	[63,75,76,240]
Analysis of variance (ANOVA)	-	-	■	-	■	■	7	[32,77,78,291–294]
Unit root test and/or Cointegration	■	■	■	■	■	■	48	[63,66,75,76,240,273,281,283,289,295–333]
Decomposition	-	■	■	■	■	■	16	[39,58,59,334–346]
Total number	3	8	28	18	22	14		
Percentage of all statistical methods (%)	11%	29%	100%	64%	79%	50%		

Table 3
Analysis of stand-alone computational intelligence and mathematical programming methods utilized in forecasting models.

Methods	Geographical extend		Time frame of forecasting			Number of models	References
	Global	Region	Country	Short	Medium		
Computational intelligence (CI) methods							
Support vector machine (SVM)	-	■	■	■	■	■	[28,43,46,85,86,104,108,117,118,126–129,133,134,143,144,166,170,174,184,206,-208,227,228,249,251,258,269–271,290,345,347–370]
Decision tree ^a	-	-	■	■	■	-	[29,89,371,372]
Artificial neural network (ANN)	■	■	■	■	■	■	[20,21,28,29,32,36,37,47,61,69,77,78,83,84,87,90,95,108,115,116,126–128,131,138–143,146–158,160–162,167,168,170–177,180,184,191,205,207,227,228,231,246,251,253,255,256,263,268–271,280,293,294,344,349,352,354,357,360,361,365,367,369,373–478]
Abductive networks	-	-	■	■	-	-	[87,88]
Expert system	-	-	■	■	■	-	[90–96]
Grey prediction (GM)	-	■	■	■	■	■	[43,101,115,145,164,165,167,169,184,230,248,390,479–495]
Fuzzy logic (FL)	-	-	■	■	■	■	[19,45,51,96,97,147,149–160,251,253,255,256,357,376,435,454,458,461,465,477,-496–504]
Genetic algorithm (GA)	■	-	■	■	■	■	[95,96,102–108,119,122,123,126,128,156,162–165,169,171,172,247,253,268,270,-351,357,465,477,505–513]
Artificial bee colony optimization (ABCO)	■	-	■	■	-	■	[116,117,270,469]
Ant colony optimization (ACO)	-	■	■	■	■	■	[95,96,109,110,118–123]
Particle swarm optimization (PSO)	■	-	■	■	■	■	[34,44,46,50,105,106,108–113,115,119,122,123,126,161–163,168,174,253,290,364,368,452,453,461,471,493,504,514,515]
Gravitational search algorithm (GSA)	-	-	■	■	-	■	[85,86,130,131]
Chaotic ant swarm optimization (CAS)	-	-	■	■	■	-	[125,126]
Differential evolution (DE)	-	-	■	■	■	■	[127–129,464]
Harmony search (HS)	-	-	■	-	-	-	[132]
Evolutionary algorithm (EA)	-	-	■	■	-	-	[50]
Memetic algorithms (MA)	-	-	■	■	-	-	[108]
Immune algorithm (IA)	-	-	■	-	■	-	[133]
Simulated annealing algorithms (SA)	-	-	■	■	■	-	[104,108,126,128,134,359]
Firefly algorithm (FA)	-	■	■	■	-	-	[108,270,363,516]
Cuckoo search algorithm (CSA)	-	■	■	■	-	-	[251,474]
Mathematical programming (MP) methods							
Nonlinear programming (NLP)	-	-	■	-	-	■	[103]
Total number	4	4	22	19	13	12	
Percentage of all CI and MP methods (%)	18%	18%	100%	86%	59%	55%	

^a Random forest was included under decision tree as they are collection of decision tree in the modeling.

Aranda et al. utilized SR to select the correct model form to predict the annual energy consumption in the Spanish banking sector [31].

4.1.2. Univariate time series methods

Among the studied models, five univariate time series methods were utilized. The methods were: moving average (MA), autoregressive integrated moving average (ARIMA), seasonal autoregressive integrated moving average (SARIMA), autoregressive moving average model with exogenous inputs (ARMAX) and autoregressive moving average (ARMA).

Four forecasting models utilized moving average (MA). Azadeh et al. forecasted electricity consumption in Iran with moving average (MA) to make the data trend-free to train the ANN. Also forecasted electricity consumption to compare the predicted results [32]. Xu et al. combined two statistical methods to model to forecast natural gas consumption in China from 2009 to 2015. One of the methods was MA [33]. In another study, Zhu et al. developed an improved hybrid model (MA-C-WH) to forecast electricity demand in China, which utilized MA [34]. Li et al. applied single and double MA for forecasting power output of a grid-connected photovoltaic system [35].

The general form of Autoregressive integrated moving average (ARIMA) is ARIMA (p,d,q) where p is the order of the auto-regressive part, d is the order of the differencing, and q is the order of the moving average process. Some ARIMA had the seasonal and non-seasonal part, and denoted as ARIMA (p,d,q) (P,D,Q)_s where P, D, Q is the seasonal part of the model, S the number of periods per season. Among the analyzed models, ARIMA was applied in 46 models (Tables 2 and 4). Among the ARIMA models, 46% forecasted energy and electricity demand.

Seasonal autoregressive integrated moving average (SARIMA) was applied in 13 projection models (Table 2). Zhu et al. developed MA-C-WH model to forecast electricity demand in China and utilized the results from a SARIMA model to compare the accuracy of the proposed model [34]. Cadenas et al. forecasted wind speed with integrated ARIMA and ANN to compare with the results from SARIMA for Oaxaca, Mexico [36]. Jeong et al. applied SARIMA for determining the annual energy cost budget in educational facilities. In this study, models for elementary, middle, and high schools SARIMA (13, 1, 0) (0, 1, 0), SARIMA (6, 1, 1) (0, 1, 0), and SARIMA (6, 1, 1)(0, 1, 0) respectively were developed [37]. Ediger et al. applied SARIMA methods to forecast primary energy demand of Turkey from 2005 to 2020 [38]. Monthly energy forecasting model for Thailand was developed with SARIMA (1, 0,1)(0,1,0)₁₂ [39]. Ediger et al. applied SARIMA to forecast production of fossil fuel sources in Turkey [40]. Forecasting electricity demand with SARIMA (0,1,1)(1,1,1) by Sumer et al. in [41]. Bouzerdoum et al. applied SARIMA for short-term power forecasting of a small-scale grid-connected photovoltaic plant [42]. Guo et al. applied SARIMA for forecasting wind speed in Hexi Corridor of China [43]. Wang et al. developed electricity demand forecasting with SARIMA method for China [44]. Boata et al. developed hourly solar irradiation forecasting model with SARIMA (1,0,1)(1,0,1)₂₄ [45]. Wang et al. applied SARIMA to forecast electric load in [46].

Autoregressive moving average model with exogenous inputs (ARMAX) was utilized in 10 forecasting models (Table 2). Darbellay et al. applied ARMAX to forecast Czech electricity demand [47]. Li et al. developed a forecasting model for the power output of a grid-connected photovoltaic system with ARMAX [35]. González et al. applied SARMAX for forecasting power prices [48]. Bakhat et al. applied ARMAX for estimation of tourism-induced electricity consumption in Balearics Islands, Spain [49]. For short-term load forecasting, Wang et al. utilized ARMAX based on an evolutionary algorithm and particle swarm optimization [50]. Lira et al. utilized ARMAX for short-term electricity prices forecasting of Colombia [51]. Hickey et al. developed four ARMAX–GARCH models for forecasting hourly electricity prices [52].

Autoregressive moving average (ARMA) is a statistical method

Table 4

ARIMA model objectives and structures.

Objective	Year	ARIMA Structure		Ref.
		p,d,q	(p,d,q) (P,D,Q) _s	
Electricity load	2005	2,2,1	–	[134]
Electricity load	2013	1,1,1	–	[86]
Electricity demand	2003	0,1,0	–	[167]
Wind speed	2010	1,0,0; 2,0,0	–	[138]
Electricity demand	2006	0,1,1; 0,0,2; 3,2,0	(0,1,1) ₁₂	[231]
Electricity demand	2008	–	(0,1,1) (0,1,1) ₁₂	[139]
Wind speed	2007	–	(0,1,1) (0,1,1) ₁₂	[36]
Electricity demand	1997	–	(1,1,0) (1,1,0) ₁₂	[234]
Electricity load	2011	1,1,1	–	[117]
Electricity demand	2011	0,2,2; 1,2,1; 1,1,0; 0,2,0	–	[141]
Energy demand	1999	1,1,1; 1,2,1	–	[377]
Global solar radiation	2000	–	(1,0,1) (0,1,1) (0,1,1)	[152]
Electricity demand	1999	–	(0,1,1) (0,1,1)	[235]
Electricity demand	1999	–	(1,1,0) (0,1,1)	[235]
Black-coal production	1999	–	(1,0,1) (0,1,1)	[235]
Antracite production	1999	–	(0,1,1) (0,1,1)	[235]
Electricity generation	1999	–	(0,1,3) (1,1,0) (1,0,0) (1,1,0)	[235]
Solar radiation	2009	–	(1,0,0) (1,1,0)	[243]
Electricity demand	2015	1,1,1	–	[128]
Electricity price	2002	2,1,1	–	[232]
Natural gas demand	2010	36,1,0	–	[233]
Electricity demand	2007	13,2,0	–	[240]
Power output of a grid connected photovoltaic system	2014	1,1,1	–	[35]
Load forecasting	2009	2,2,1	–	[126]
Electricity demand	2006	0,1,0	–	[248]
CO ₂ emissions, energy demand and economic growth	2012	–	–	[479]
Electricity price	2010	–	–	[136]
Energy demand	2007	–	–	[38]
Electricity price	2008	–	–	[62]
CO ₂ emissions, energy demand, and economic growth	2011	–	–	[230]
Electricity load	2001	–	–	[238]
Electricity price	2003	–	–	[229]
Fossil fuel production	2006	–	–	[40]
Electricity demand	2001	–	–	[236]
Electricity load	1987	–	–	[237]
Electricity demand	1993	–	–	[239]
Electricity load	1995	–	–	[241]
Electricity price	2005	–	–	[242]
Electricity demand	2009	–	–	[41]
Wind speed	2009	–	–	[244]
Natural gas demand	1991	–	–	[245]
Electricity demand	2012	–	–	[165]
Wind speed	2011	–	–	[43]
Wind speed and electricity generation	2012	–	–	[143]

consist of two polynomials- autoregressive (AR) and moving average (MA). Among the reviewed models, 22 utilized ARMA (Table 2), of which 32% and 27% were utilized for energy & electricity demand and load forecasting respectively.

4.1.3. Multivariate time series methods

Vector autoregression (VAR) was applied in 13 reviewed models (Table 2). Among these 13 models, 77% models forecasted energy and

electricity demand. Bayesian vector autoregression (BVAR) was applied in four reviewed models (Table 2). Chandramowli et al. forecasted New Jersey's electricity demand with BVAR [53]. To forecast energy consumption in China from 2004 to 2010, Crompton et al. applied BVAR and concluded energy demand would rise at an annual average rate of 3.8% [54]. Energy consumption and projected growth were modeled with BVAR for selected Caribbean countries in [55]. The Bayesian hierarchical model was developed for one-hour-ahead wind Speed Prediction in [56]. Multivariate VARIMA (0,1,1) model was applied to model and forecast fossil fuels, CO₂ and electricity prices and their volatilities. VARIMA approach gives better results in the case of electricity prices. However, the time span of forecasting tends to be short [57].

Structural time series model (STSM) was utilized by Dilaver et al. to predicted that Turkish industrial electricity demand would be somewhere between 97 and 148 TWh by 2020 industrial electricity demand [58]. In another study, Dilaver et al. predicted Turkish aggregate electricity demand would be somewhere between 259 TWh and 368 TWh in 2020 by utilizing STSM [59].

4.1.4. Autoregressive conditional heteroscedasticity (ARCH) methods

Generalized autoregressive conditional heteroskedasticity (GARCH) was applied in fourteen models. GARCH can be both univariate and multivariate [60].

Seasonal generalized autoregressive conditional heteroscedasticity (SEGARCH) and Winters model with an exponential form of generalized autoregressive conditional heteroscedasticity (WARCH) were applied to forecast energy consumption in Taiwan by developing nonlinear hybrid models with ANN [61]. Exponential generalized autoregressive conditional heteroscedasticity (EGARCH) method was utilized by Bowden et al. for short-term forecasting of electricity prices [62].

4.1.5. Others

Six analyzed model utilized autoregressive distributed lag (ARDL) (Table 2). Dilaver et al. forecasted industrial electricity demand [58] and aggregate electricity demand [59] in Turkey with ARDL. In another study, Dilaver et al. predicted Turkish aggregate electricity demand would be somewhere between 259 TWh and 368 TWh in 2020 by utilizing ARDL. Adom et al. utilized ARDL to forecast electricity demand in Ghana to be within 20,453 and 34,867 GWh by the year 2020 for analyzed three scenarios [63]. Kim et al. forecasted energy demand of South Korea for 2000–2005 after reviewing the 1990s [64]. Zachariadis T. forecasted electricity consumption in Cyprus with ARDL [65]. Vita et al. developed ARDL bounds testing approach to estimate the long-run elasticities of the Namibian energy demand [66].

Among the reviewed models, four models applied log-linear analysis (LA) (Table 2). Parikh et al. used the LA to project the demand for petroleum projects and natural gas in India. The study projected the demand of petroleum products to be 147 and 162MT in the business as usual scenario (BAU) of 6% and optimistic scenario (OS) of 8% GDP growth, respectively for 2011–2012 [67]. In another study, Pilli-Sihvola utilized the log-linear econometric model to project and examine the impact of gradually warming climate on the heating and cooling demand in five European countries from 2008–2050 [68]. Limanond et al. project transport energy consumption in Thailand from 2010 to 2030 with LA [69]. Wadud et al. projected natural gas demand in Bangladesh from 2009 to 2025 with log-linear Cobb–Douglas method [70].

Geometric progression (GP) was utilized in three studied models (Table 2). Mackay et al. forecasted crude oil and natural gas supplies and demands from 1995 to 2010 for France [71] and Denmark [72] by utilizing geometric progression method. In a separate study, Mackay et al. forecasted liquid fossil fuel supplies and demands for the UK with geometric progression method [73].

Transcendental logarithmic (Translog) was applied in two forecasting models (Table 2). Rao et al. developed a translog model on a non-homothetic translog function to forecast and analyze the demand

for petroleum products in India [30]. Furtado et al. forecasted petroleum consumption in Brazil up to 2000 with translog model along with logistic and learning model. The study demonstrated that translog model performed better than logistic and learning model [74].

Polynomial curve model (PCM) is one of the trend extrapolation methods best modeled with polynomial equations. Xu et al. combined two statistical methods to forecast natural gas consumption in China from 2009 to 2015; one of the methods was PCM [33].

Four reviewed models utilized partial adjustment model (PAM) for forecasting (Table 2). Nasr et al. utilized PAM to develop an econometric model to estimate electricity consumption of post-war Lebanon [75]. Adom et al. identified the factors that affect aggregate electricity demand in Ghana and forecasted electrical consumption from 2012 to 2020 with PAM and ARDL [63]. To analyze the demand for natural gas in Kuwait, PAM was utilized in [76].

Seven models utilized analysis of variance (ANOVA) (Table 2). ANOVA was applied to compare the selected ANN, regression and actual data of forecasting electricity consumption [32,77]. ANOVA F-test was applied for ANN, simulated-based ANN, time series and actual test data for forecasting electrical energy consumption in Iran [78].

Cointegration implies restrictions on multivariate time series and is widely believed that it can produce better long-horizon forecasting [79]. Unit root test and/or Cointegration was utilized in 48 models (Table 2). The major objective of applying cointegration method was to find the relations among the variables of a model. Nasr et al. utilized cointegration method to develop an econometric model to estimate electricity consumption of post-war Lebanon [75]. Decomposition was utilized in 16 analyzed models (Table 2).

4.2. Computational intelligence (CI) methods

There were 22 methods utilized in the analyzed models. The real-life problems have nonlinear characteristics while forecasting, especially for energy planning. Computational methods were used for prediction problems where mathematical formulae and prior data on the relationship between inputs and outputs are unknown [80]. The applied CI methods can be divided into four categories.

4.2.1. Machine learning methods

Artificial Neural Network (ANN) was highly utilized method for various objectives. Inspired by the human brain, ANN can learn and generalize from samples and analyses unpretentious useful connections among the information regardless of the possibility that the fundamental connections are obscure or difficult to portray [81]. A schematic diagram of feed-forward neural network architecture is shown in Fig. 2. ANN has three layers: input, hidden and output. In Fig. 2, only one hidden layer is shown, and the number can be more than that depending on the complexity of the analyzed problem. Each neuron is connected to every other neuron of the previous layer through adaptable synaptic weight. A training process is carried out to train ANN by modifying the connection weights, and weights are adjusted to produce the desired outputs as shown in Fig. 3. Description of basic ANN method can be found in [82].

Among the reviewed models, 194 models applied ANN or different form of NN. The detailed analysis of ANN can be found in Table 5, which is demonstrating layer number, neuron number in different layers and neuron composition of different NN models, which differs depending on the objective. According to reviewed literature, NN structure with two hidden layers produced best results for the monthly load forecasting, the peak load forecasting and the daily total load forecasting modules [83]. However, one hidden layer is sufficient for most forecasting problems according to Zhang et al. [81]. In another study, the performance of the hierarchical model on long-term peak-load forecasts outperformed the multilayer perceptron [84]. Analysis of reviewed models revealed that 83% models utilized three layer neuron structure with one hidden layer. Only 6% and 17% models used two




Fig. 2. ANN schematic diagram.

and four neuron layers respectively. 49%, 38%, 78% and 11% of the neuron structures had less than five neurons respectively in the first, second, third and fourth layer. In the case of the first and second layer, 26% and 43% of the neuron structures respectively had neuron numbers between 5 and 10. Moreover, 23% and 18% neuron structures had more than ten neurons in the first and second layers respectively. Only 8% neuron structures had more than ten neurons in the third layer, which is only 1% in fourth layer (Table 5).

Support vector machine (SVM) was utilized in 58 forecasting models (Table 3). Yuan et al. developed a short-term wind power prediction model with least squares support vector machine (LSSVM) because the kernel function and the related parameters of the LSSVM influence the greater accuracy of the prediction [85]. Some of the models utilized Support vector regression (SVR), which is SVM applied to the case of regression. Ju et al. utilized SVR and seasonal SVR forecast electricity load in Taiwan [86]. Among the reviewed models, 41.4%, 22.4%, and 20.7% forecasted electric load, renewable energy, and energy & electricity demand.

Abductive networks is a machine learning method. It was found to be applied in two forecasting models (Table 3). Abdel-Aal, R.E. utilized AIM (abductive inductive mechanism) and GMDH (group method of data handling) approach for forecasting monthly energy demand. AIM is a supervised inductive machine-learning tool. It automatically develops abductive network models from a database of input and output

variables. GMDH is a learning algorithm and formalized paradigm for iterated (multi-phase) polynomial regression [87]. In another study, Abdel-Aal et al. utilized AIM monthly electric energy consumption in eastern Saudi Arabia and demonstrated that AIM performed better than that of regression method [88].

Decision tree develops an empirical tree which represents a segmentation of the data and able to classify and predict categorical variables. The segment is developed by applying a series of simple rules/logic. The advantage of the decision tree is that it produces a model which have segments of the system with interpretable rules or logic statements [29]. However, it performs poorly with nonlinear and noisy data [80]. Tso et al. utilized decision tree method to predict electricity consumption in Hong Kong [29]. Yu et al. developed a building energy demand predictive model with a decision tree and demonstrated high accuracy with 93% for training data and 92% for test data [89].

4.2.2. Knowledge-based methods

Expert systems were applied in seven models (Table 3). Most of the models utilized expert system for short-term load forecasting [90–94]. Ghanbari et al. applied cooperative ant colony optimization-genetic algorithm (COR-ACO-GA) for energy demand forecasting with knowledge-based expert systems, which yielded better accuracy [95]. In another study, Ghanbari et al. integrated ant colony optimization (ACO),




Fig. 3. ANN process; adopted from [82].

Table 5
ANN model objectives and structures.

Forecasted variable	Year	No. of layers			No. of neurons in layers												Neuron composition	Ref.
		2	3	4	1 st			2 nd			3 rd			4 th				
					< 5	5–10	> 10	< 5	5–10	> 10	< 5	5–10	> 10	< 5	5–10	> 10		
Electricity demand	2006	–	■	–	–	■	–	–	–	■	–	–	■	–	–	–	5–5–1	[191]
						■	–	–	–	–	–	–	–	–	–	–	5–6–1	
Electricity demand	2012	–	■	–	■	–	–	–	–	■	–	–	■	–	–	–	4–8–2	[20]
Energy demand	2010	–	–	■	■	–	–	–	–	■	–	–	■	■	–	–	4–20–17–1	[28]
Electricity load	2008	–	■	–	–	■	–	–	–	–	■	–	–	–	–	–	8–36–1	[146]
					–	■	–	–	–	■	–	–	■	–	–	–	9–10–1	
					–	■	–	–	–	–	■	–	–	–	–	–	10–31–1	
					–	■	–	–	–	■	–	–	–	–	–	–	8–17–1	
					–	■	–	–	■	–	■	–	–	–	–	–	9–2–1	
Electricity demand	2007	–	–	■	–	–	■	–	–	–	■	–	–	■	–	–	12–16–6–1	[32]
Energy demand	2011	–	■	■	–	■	–	–	–	■	–	–	–	–	–	–	5–5–1	[69]
					–	■	–	–	–	■	–	–	–	–	–	–	5–10–1	
					–	■	–	–	–	–	–	■	–	–	–	–	5–5–5–1	
Energy demand	2008	–	■	–	–	–	■	■	–	■	–	–	–	–	–	–	12–4–1	[87]
					–	–	■	■	–	■	–	–	–	–	–	–	12–5–1	
					–	–	■	■	–	–	–	–	–	–	–	–	12–6–1	
					■	–	–	–	■	–	■	–	–	–	–	–	3–5–1	
Energy demand	2009	–	■	–	■	–	–	■	–	–	–	–	–	–	–	–	2–3–1	[61]
					■	–	–	■	–	–	–	–	–	–	–	–	2–4–1	
Solar radiation	1998	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	4–10–1	[176]
Wind speed	2010	■	■	–	■	–	–	■	–	–	–	–	–	–	–	–	3–1	[138]
					■	–	–	■	–	–	–	–	–	–	–	–	2–1	
					■	–	–	■	–	–	■	–	–	–	–	–	3–3–1	
					■	–	–	■	–	–	■	–	–	–	–	–	3–2–1	
Electricity demand	2000	–	■	–	–	■	–	–	■	–	■	–	–	–	–	–	6–6–1	[47]
Wind speed	2007	■	–	–	■	–	–	■	–	–	–	–	–	–	–	–	3–1	[36]
Electricity demand	2011	–	■	–	–	■	–	–	■	–	■	–	–	–	–	–	5–12–1	[77]
Electricity demand	2013	–	■	–	–	–	■	–	–	–	–	–	■	–	–	–	48–97–48	[344]
Electricity demand	2012	–	■	–	■	–	–	■	–	–	■	–	–	–	–	–	1–2–1	[184]
Time-series forecasting	2010	–	■	–	–	■	–	■	–	–	■	–	–	–	–	–	8–3–1	[373]
					–	■	–	■	–	–	■	–	–	–	–	–	8–4–1	
					–	–	■	■	–	–	■	–	–	–	–	–	12–4–1	
					■	–	–	■	–	–	■	–	–	–	–	–	4–4–1	
					–	■	–	–	■	–	–	–	–	–	–	–	7–5–1	
Electricity demand	2007	–	■	■	■	–	–	■	–	–	■	–	–	–	–	–	2–2–1	[171]
					■	–	–	–	■	–	–	■	–	■	–	–	2–10–10–1	
					■	–	–	–	–	–	–	■	■	–	–	–	2–20–20–1	
Electricity demand	2008	–	■	–	■	–	–	■	–	–	■	–	–	–	–	–	3–2–1	[78]
Electricity demand	2008	–	–	■	■	–	–	■	–	–	■	–	–	■	–	–	5–3–2–1	[293]
Electricity load	2003	–	■	–	■	–	–	■	–	–	■	–	–	–	–	–	3–2–1	[375]
Electricity load	2005	–	–	■	–	■	–	–	■	–	–	■	–	■	–	–	6–5–8–1	[83]
					–	■	–	–	–	■	–	–	■	–	–	–	9–5–8–1	
Energy demand	2009	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	4–5–1	[294]
					■	–	–	–	■	–	■	–	–	–	–	–	4–4–1	
					■	–	–	–	■	–	■	–	–	–	–	–	4–3–1	
					■	–	–	–	■	–	■	–	–	–	–	–	4–2–1	
Electricity demand	2011	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	4–10–1	[141]
					■	–	–	–	–	■	–	–	–	–	–	–	4–6–1	
					■	–	–	–	■	–	■	–	–	–	–	–	4–8–1	
					■	–	–	–	–	■	–	–	–	–	–	–	4–6–1	
					■	–	–	–	–	■	–	–	–	–	–	–	4–5–1	
Energy demand	1999	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	2–7–1	[377]
					■	–	–	–	■	–	■	–	–	–	–	–	3–7–1	
					■	–	–	–	■	–	■	–	–	–	–	–	4–7–1	
					–	■	–	–	–	■	–	–	–	–	–	–	5–7–1	
Electricity demand	2007	–	■	–	■	–	–	■	–	–	■	–	–	–	–	–	4–2–4	[379]
Energy demand	2005	–	–	■	–	■	–	■	–	–	■	–	–	■	–	–	5–4–4–1	[380]
					–	■	–	■	–	–	■	–	–	■	–	–	7–4–4–1	
Energy demand	2002	–	■	–	–	–	■	■	–	■	–	–	–	–	–	–	55–27–1	[385]
					–	–	■	■	–	■	–	–	–	–	–	–	55–02–1	
Electricity load	1994	–	■	–	–	–	■	–	–	■	–	–	■	–	–	–	77–24–24	[397]
Electricity load	1996	–	■	–	–	–	■	–	–	■	–	–	■	–	–	–	63–24–24	[402]
Electricity load	1993	–	■	–	–	–	■	–	–	■	–	–	–	–	–	–	29–8–1	[396]
					–	–	■	–	–	■	–	–	–	–	–	–	22–5–1	
					–	–	■	–	–	■	–	–	–	–	–	–	39–10–24	
Electricity load	1992	–	■	–	–	■	–	–	■	–	■	–	–	–	–	–	5–8–1	[394]
Electricity load	1996	–	■	–	–	–	■	–	–	■	–	–	■	–	–	–	81–81–24	[403]
Electricity load	1998	–	■	–	–	–	■	–	–	■	–	–	–	–	–	–	15–(7–12) ⁺ –1	[404]
					–	–	■	–	–	–	■	–	–	–	–	–	7–(10–16) [†] –1	
Electricity load	2006	–	■	–	–	–	■	–	–	■	–	–	–	–	–	–	32–65–1	[409]

(continued on next page)

Table 5 (continued)

Forecasted variable	Year	No. of layers			No. of neurons in layers												Neuron composition	Ref.
		2	3	4	1 st			2 nd			3 rd			4 th				
					< 5	5–10	> 10	< 5	5–10	> 10	< 5	5–10	> 10	< 5	5–10	> 10		
Electricity load	2008	–	■	–	■	–	–	■	–	–	■	–	–	–	–	–	4–3–1	[411]
Electricity price	2007	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	5–7–1	[414]
Electricity load	2009	–	–	■	–	–	■	–	–	■	–	–	■	–	–	■	19–20–15–24	[417]
Electricity demand	1999	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	3–5–1	[420]
Electricity demand	2015	–	■	–	–	■	–	–	■	–	■	–	–	–	–	–	5–3–1	[162]
Solar energy potential	2005	–	■	–	–	■	–	–	■	–	■	–	–	–	–	–	6–6–1	[427]
Electricity demand	2001	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	2–6–1	[433]
					■	–	–	–	■	–	■	–	–	–	–	–	3–9–1	
					■	–	–	–	–	■	–	–	–	–	–	–	3–5–1	
					■	–	–	–	■	–	■	–	–	–	–	–	1–3–1	
Wind speed	2005	–	■	–	–	–	■	–	–	■	■	–	–	–	–	–	14–15–1	[437]
Wind speed	2012	–	■	–	–	■	–	–	■	–	■	–	–	–	–	–	5–10–1	[438]
Wind speed	2009	■	■	–	■	–	–	■	–	–	–	–	–	–	–	–	3–1	[441]
					■	–	–	–	■	–	–	–	–	–	–	–	2–1	
					■	–	–	–	■	–	■	–	–	–	–	–	3–3–1	
					■	–	–	–	■	–	■	–	–	–	–	–	3–2–1	
Electricity price	1999	–	■	–	–	–	■	–	–	■	■	–	–	–	–	–	15–15–1	[440]
Electricity demand	2013	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	4–6–1	[95]
Natural gas demand	2013	–	■	–	■	–	–	–	–	■	■	–	–	–	–	–	3–5–1	[95]
Oil products demand	2013	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	2–3–1	[95]
Energy demand	2009	–	■	–	–	■	–	–	■	–	■	–	–	–	–	–	7–8–1	[442]
Electricity load	2008	–	–	■	–	–	■	–	–	■	–	■	–	■	–	–	11–5–5–1	[450]
Electricity demand	1999	–	■	–	■	–	–	–	■	–	■	–	–	–	–	–	3–2–1	[160]
					■	–	–	–	■	–	■	–	–	–	–	–	3–1–1	
Electricity demand	2015	–	■	–	–	–	■	–	–	■	■	–	–	–	–	–	12–4–1	[128]
Total number		3	44	9	48	25	22	37	42	17	76	6	8	11	0	1		
%		6%	83%	17%	49%	26%	23%	38%	43%	18%	78%	6%	8%	11%	0%	1%		

* Number of hidden layer neurons form week 1–21 ranged from 7 to 12 for feedforward networks.

† Number of hidden layer neurons form week 1–21 ranged from 10 to 16 for recurrent networks.

genetic algorithm (GA) and fuzzy logic to develop a load forecasting expert system [96].

4.2.3. Uncertainty methods

Fuzzy logic was applied in 40 models (Table 3). In the analyzed models, the fuzzy method was proved to be efficient with the incomplete or limited dataset. The theory of fuzzy sets is the foundation of the fuzzy logic. The basic description of the method can be found in [97].

Grey prediction (GM) belongs to the family of the grey system among which the GM (1, 1) model is the most frequently used. GM methods adopt essential part of the grey theory (GT) which deals with systems with uncertain and deficient data [98,99]. The real world systems are modeled with the assumptions based on the inadequate information [100]. GM method has been successfully adopted for forecasting models in different disciplines. Among the reviewed models, twenty-nine models applied GM. The basic description of the method can be found in [101].

4.2.4. Metaheuristic methods

Evolutionary methods are a subset of metaheuristic methods which uses mechanisms inspired by natural biological evolution, such as reproduction, mutation, recombination, and selection. There were several types of metaheuristic methods applied in forecasting models-

Genetic algorithm (GA) was utilized in thirty-nine forecasting models. The basic description of the method can be found in [102]. Forouzanfar et al. forecasted natural gas consumption for residential and commercial sectors in Iran with LoR. However, to make the process simpler, two different methods are proposed to estimate the logistic parameters, of which one was GA based [103]. Zhang et al. utilized stimulated annealing algorithms with chaotic GA to develop a hybrid method to assist an SVR model in improving load forecasting performance [104]. Assareh et al. applied GA for forecasting energy demand [105] and oil demand [106] in Iran based on

population, GDP, import, and export. Chaturvedi et al. applied GA for electric load forecasting [107]. The objective of the models, the purpose of GA in that model and the publishing year can be found in Table 6. Among the reviewed models, 27% utilized GA for parameter optimization in the hybrid methods.

An evolutionary algorithm (EA) was utilized in only one forecasting model. Wang et al. utilized a hybrid optimization method based on evolution algorithm and particle swarm optimization to improve the accuracy of forecasting ARMAX model [50].

Memetic algorithm (MA) was applied in one forecasting model. For forecasting electricity load, Hu et al. applied firefly algorithm (FA) based memetic algorithm (FA-MA) to determine the parameters of SVR model appropriately [108].

Particle swarm optimization (PSO) was applied in 34 models (Table 3). Zhu et al. developed an improved hybrid model (MA-C-WH), which utilized MA and adaptive particle swarm optimization (APSO) algorithm to forecast electricity demand in China. APSO was utilized to determine weight coefficients of the MA-C forecasting model, and the objective function of this optimization problem was to minimize the MAPE [34]. Kiran et al. applied PSO to develop an ACO-PSO hybrid method to forecast energy demand of Turkey [109]. The proposed ACO-PSO method by Kiran et al. was applied for to forecast the wind power output of Binaloud wind farm in Iran in [110]. Assareh et al. applied PSO for forecasting energy demand [105] and oil demand [106] in Iran based on based on population, GDP, import, and export. AlRashidi et al. constructed long-term electric load forecasting model with PSO [111]. Also for modeling and forecasting long-term natural gas consumption in Iran PSO was utilized [112]. Abdelfatah et al. constructed a global CO₂ emissions forecasting model with PSO [113]. The objective of the models, the purpose of PSO in that model and the publishing year can be found in Table 7. Among the reviewed models, 33% utilized PSO for parameter optimization in the hybrid methods. The basic description of the method can be found in [114,115].

Table 6
The purpose of GA in the reviewed hybrid models.

Forecasted variable	Purpose of GA				Year	Ref.	
	Parameter tuning	Parameter optimization	Model structure optimization	Coefficients optimization			
Electricity demand	■	-	-	■	-	2007	[171]
Electricity load	-	-	■	-	-	2009	[173]
Hydro energy potential	-	-	■	-	■	2010	[172]
Electricity demand	-	■	■	-	■	2015	[162]
Electricity demand	-	-	■	-	-	2015	[128]
Electricity load	■	-	-	-	-	2013	[108]
Energy demand	-	-	-	-	-	2013	[95]
Electricity load	-	-	-	-	■	2011	[96]
Electricity load	-	■	-	-	■	2009	[126]
NO _x Emission	-	-	-	-	■	2013	[119]
Energy demand	-	-	-	■	-	2012	[122]
Energy demand	-	-	-	■	-	2012	[123]
Energy demand	-	■	-	-	-	2012	[163]
Energy demand	-	-	-	-	-	2011	[164]
Energy demand	-	-	-	-	■	2012	[165]
Energy distribution ^a	-	-	-	-	-	2000	[505]
Energy distribution ^a	-	-	-	-	-	2006	[506]
Energy demand	-	■	■	-	-	2004	[507]
Electricity demand	-	-	-	-	-	2005	[512]
Electricity demand	-	■	-	-	-	2005	[508]
Petroleum exergy	-	-	-	-	■	2004	[511]
production & demand	-	-	-	-	-	-	-
Transport energy demand	-	-	-	-	■	2005	[509]
Oil demand	-	■	-	-	-	2006	[510]
Electricity demand	-	■	-	■	-	2007	[247]
Natural gas demand	-	■	-	-	-	2009	[169]
Global CO ₂ emission	-	-	-	-	-	2012	[513]
PV power generation	-	■	-	-	-	2015	[268]
Total number	2	9	5	4	7	1	2
%	6%	26%	15%	12%	21%	3%	6%

^a Transmission network expansion planning (TNEP), Power generation expansion planning (PGEPP).

Table 7
The purpose of PSO in the reviewed hybrid models.

Forecasted variable	Purpose of PSO							Year	Ref.
	Parameter tuning	Parameter optimization	Model structure optimization	Coefficients optimization	Weighting factors value	Scenario optimization	Improve performance		
Electricity load	–	–	–	–	–	–	–	2009	[115]
Electricity demand	–	■	–	–	■	–	–	2015	[162]
Electricity load	–	–	–	–	■	–	–	2009	[168]
Electricity demand	–	■	–	–	–	–	–	2012	[44]
Electricity load	–	–	–	–	–	–	■	2008	[50]
Electricity load	■	–	–	–	–	–	–	2013	[108]
Electricity load	–	■	–	–	–	–	–	2009	[126]
NO _x emission	–	–	–	–	■	–	–	2013	[119]
Energy demand	–	■	–	–	–	–	–	2014	[174]
Energy demand	–	–	–	■	–	–	–	2012	[122]
Energy demand	–	–	–	■	–	–	–	2012	[123]
Energy demand	–	■	–	–	–	–	–	2012	[163]
Economic emissions	–	–	–	–	–	■	–	2013	[514]
Electricity load	–	–	–	–	■	–	–	2010	[46]
Electricity demand	–	–	–	–	–	–	■	2008	[161]
Electricity consumption	–	–	■	–	–	–	–	2011	[452]
Energy demand	–	–	–	–	■	–	–	2014	[515]
Energy demand	–	■	■	–	–	–	–	2012	[453]
Wind power	■	–	–	–	–	–	–	2015	[461]
Electricity load	–	■	–	–	–	–	–	2014	[493]
Total number of models	2	7	2	2	5	1	2		
%	10%	33%	10%	10%	24%	5%	10%		

Artificial bee colony optimization (ABCO) was applied in four forecasting models among the reviewed models (Table 3). For forecasting world CO₂ emissions, BCO was utilized for finding optimal values of weighting factors for forecasting [116]. Chaotic artificial bee colony algorithm was applied for electric load forecasting to determine suitable values of its three parameters for forecasting [117].

Ant colony optimization (ACO) was utilized in ten forecasting models (Table 3). For energy demand forecasting, Ghanbari et al. applied Cooperative Ant Colony Optimization (COR-ACO) to learn fuzzy linguistic rules (degree of cooperation between database and rule base), which would yield better accuracy [95]. In another study, Ghanbari et al. applied ACO-GA to generate optimal knowledge base (KB) for an expert system to forecast load [96]. Niu et al. applied ACO with SVM model to forecast short-term power load, where ACO to pre-process the data which influence uncertain factors in forecasting [118]. A NO_x emission forecasting model for Iran utilized ACO to estimate optimal values of weighting factors regarding actual data in [119]. To estimate energy demand of Turkey, ACO was applied in [120]. In another study, to forecast energy demand of Turkey, ACO was applied to develop ACO-PSO hybrid method [109]. For estimating the net electrical energy generation and demand of Turkey, ACO was applied based on the GDP, population, import and export [121]. ACO based hybrid method was applied for to forecast the wind power output of Binaloud wind farm in Iran in [110]. Yu et al. applied ACO to forecast energy demand of China [122] and primary energy demand of China [123].

Chaotic ant swarm optimization (CAS) is deterministic chaotic optimization method inspired by behaviors of real ants [124], which was utilized by two models (Table 3). Hong et al. for electric load forecasting. In the proposed model CAS was applied to improve the forecasting performance of SVR by searching its suitable parameters combination [125]. For electric load forecasting with SVR model, Hong W.-C. applied CAS to determine suitable parameter combination for the model [126].

Differential evolution (DE) was applied in three of the analyzed models (Table 3). Wang et al. developed a load forecasting model with DE and SVR [127]. In another study, adaptive differential evolution (ADE) was applied with BPNN for developing a method for electricity

demand forecasting in [128]. For short-term load forecasting, Xiaobo et al. developed a GRA-DE-SVR model, where DE to optimize parameters of SVR model [129].

Gravitational search algorithm (GSA) was applied assist to develop three demand estimation models to forecast oil consumption based on socio-economic indicators in [130]. GSA was utilized to forecast electricity load in Taiwan to assist the seasonal SVR model in [86]. GSA was applied to optimize the parameters of the LSSVM model developed by Yuan et al. to short-term wind power prediction model [85]. Gavrilas et al. proposed a model of electric load forecasting with GSA combined with regression method and Kohonen neural networks [131].

Harmony search (HS) was utilized to develop HArmony Search Transport Energy Demand Estimation (HASTEDE) model, in a study conducted by Ceylan et al. to project the transport sector energy consumption in Turkey. The results demonstrated overestimation of transport sector energy consumption by about 26%, and linear and exponential forms underestimate by about 21%, compared to Ministry of Energy and Natural Resources projections. The study pointed out the under, and overestimation might be the outcome of the choice of modeling parameters and procedures [132].

Immune algorithm (IA) was applied for electric load forecasting model, where IA determined the parameter selection of SVR model [133].

Simulated annealing algorithms (SA) is an evolutionary method was applied in six models (Table 3). Zhang et al. utilized SA with chaotic GA to develop a hybrid method to assist an SVR model in improving load forecasting performance [104]. Pai et al. utilized SA algorithms were employed to choose the parameters of an SVM model to forecast electricity load in Taiwan [134]. Hong, W.-C. developed SVM-SA model for load forecasting, where SA was applied to determining appropriate parameter combination for SVR model [126].

Moreover, Firefly algorithm (FA) and Cuckoo search algorithm (CSA) are two metaheuristic methods utilized in four and two forecasting models respectively to develop a hybrid methodology in recent times (Table 3).

4.3. Mathematical programming (MP)

Mathematical programming or mathematical optimization prescribes best solution/s from a set of available alternatives under some conditions. Among the analyzed models, one mathematical programming methods were found- Nonlinear programming (NLP). Forouzanfar et al. forecasted natural gas consumption for residential and commercial sectors in Iran with LoR. However, to make the process simpler, two different methods are proposed to estimate the logistic parameters, of which one was GA based [103].

5. Hybrid methods

In some models, for specific reasons (i.e., parameter tuning, elevating accuracy) different stand-alone methods were combined to construct hybrid methods. Hybrid methods were utilized to develop the assumptions and parameters in some forecasting models [135]. The hybrid methods found in analyzed models can be divided into following four categories:

5.1. Statistical-statistical methods

Xu et al. combined MA and PCM to develop a Polynomial Curve and Moving Average Combination Projection (PCMACP) model to forecast natural gas consumption in China from 2009 to 2015. The model demonstrated, the average annual growth rate will increase, and the natural gas consumption will reach 171,600 million cubic meters in 2015 in China. [33]. To estimate the long-run elasticities of the Namibian energy demand, Vita et al. applied ARDL bounds testing approach to cointegration [66].

Tan et al. developed a day-ahead electricity price forecasting model by combining Wavelet (WT)–GARCH–ARIMA [136]. Bowden et al. applied ARIMA-EGARCH-M for short-term forecasting of electricity prices [62]. Hickey et al. developed four ARMAX–GARCH models for forecasting hourly electricity prices. The four models were- GARCH (1,1), EGARCH (1,1), APARCH (1,1) and CGARCH (1,1) power ARCH (PARCH), where EGARCH is exponential GARCH; APARCH is asymmetric power ARCH, and CGARCH is Component GARCH [52]. Liu et al. developed ARMA-GARCH models (ARMA-SGARCH, ARMA-QGARCH, ARMA-GJRGARCH, ARMA-EGARCH, and ARMA-NGARCH) and their form of ARMA–GARCH-in-mean to forecast short-term electricity prices [137].

5.2. Statistical-CI methods

Pao developed nonlinear hybrid models with SEGARCH and WARCH with ANN to forecast energy consumption in Taiwan [61]. For wind speed forecasting Cadenas et al. developed a ARIMA-ANN model [138]. González-Romera et al. developed a hybrid method where the periodic behavior was forecasted with a Fourier series while the trend was predicted with a neural network [139]. For forecasting symbolic interval time series, Maia et al. developed an ARMA-ANN model, where it performed better than that of ARMA [140]. Kandanand, K. developed prediction models of the electricity demand in Thailand with ANN, MLR and ARIMA methods to develop ANN-MLR and ANN-ARIMA hybrid methods [141]. ANN model using statistical feature parameters (ANN-SFP) and historical data series (ANN-HDS) was applied for short-term solar irradiance forecasting (STSIF) [142]. Shi et al. applied ARIMA with ANN and SVM to develop two hybrid models of ARIMA-ANN and ARIMA-SVM for forecasting of wind speed and wind power generation [143]. Bouzerdoum et al. developed SARIMA-SVM model for short-term power forecasting of a small-scale grid-connected photovoltaic plant [42]. Guo et al. developed a hybrid Seasonal Auto-Regression Integrated Moving Average and Least Square Support Vector Machine (SARIMA-LSSVM) model for forecasting wind speed in Hexi Corridor of China [43]. Wang et al. applied PSO optimal Fourier

approach on residual modification of SARIMA to develop F-S-SARIMA model to forecast electricity demand for China [44]. Wang et al. developed a combined model to forecast electric load. For the model SARIMA, seasonal exponential smoothing (S-ESM) and Weighted SVM (W-SVM) was constructed by linear combination and APSO was utilized for determining weight coefficients of combined forecasting model [46]. Wang et al. applied seasonal decomposition with LSSVR for hydropower consumption forecasting in China [144].

Song et al. applied fuzzy regression analysis in the short-term load forecasting problem [19]. Xu et al. applied GM (1,1) with ARMA to develop GM-ARMA model to forecast energy consumption for Guangdong Province of China [145]. Amin-Naseri et al. developed a model for daily electrical peak load forecasting (PLF) with feed-forward neural network (FFNN) method, where the Davies–Bouldin validity index was introduced to determine the best clusters [146]. Forouzanfar et al. forecasted natural gas consumption for residential and commercial sectors in Iran by utilization of LoR. However, GA based approach was proposed to estimate the logistic parameters, to make process simpler [103]. Zhu et al. developed an improved hybrid model (MA-C-WH), which utilized MA and adaptive particle swarm optimization algorithm to forecast electricity demand in China [34]. An electric load forecasting model was developed with regression method combined with GSA or Kohonen neural networks [131]. GSA was applied to estimate optimal weighting factors for three demand estimation models to forecast oil consumption based on socio-economic indicators up to 2030 [130].

5.3. CI-CI methods

To forecast solar radiation, Chen et al. developed a fuzzy neural network (FNN) model with ANN and fuzzy logic [147]. The fuzzy neural network was applied for day-ahead price forecasting of electricity markets in [148]. Bazmi et al. utilized adaptive neuro-fuzzy network (ANFIS) for electricity demand forecasting for the state of Johor, Malaysia [149]. In another study, Zahedi et al. applied neuro-fuzzy network for electricity demand forecasting for Ontario province, Canada [150]. Esen et al. utilized the neuro-fuzzy network for forecasting performances of ground-coupled heat pump system [151]. Forecasting model of mean hourly global solar radiation was developed with ANFIS [152]. Akdemir et al. utilized ANFIS for long-term load forecasting [153]. Chen et al. applied a collaborative principal component analysis and fuzzy feed-forward neural network (PCA-FFNN) approach for long-term load forecasting [154]. In another study Chen, T. applied a collaborative fuzzy-neural approach for long-term load forecasting [155]. Chang et al. applied weighted evolving fuzzy neural network for monthly electricity demand forecasting in Taiwan [156]. FNN was also applied for short-term load forecasting in [157–159]. Padmakumari et al. applied FNN for long-term land use based distribution load forecasting [160].

In case of metaheuristic methods, genetic algorithm (GA), Particle swarm optimization (PSO) and Ant colony optimization (ACO) were mostly utilized methods. El-Telbany et al. applied PSO and BP algorithm to train NN model to forecast electricity demand in Jordan [161]. Ghanbari et al. applied cooperative ant colony optimization-genetic algorithm (COR-ACO-GA) for energy demand forecasting with knowledge-based expert systems, which yielded better accuracy than ANFIS and ANN [95]. Ghanbari et al. integrated ACO, GA and fuzzy logic to develop a hybrid method to construct a load forecasting expert system for Iran in [96]. Niu et al. developed ACO-SVM model for forecasting short-term power load [118]. A NO_x emission forecasting model for Iran, where GA, PSO, and ACO were applied to estimate optimal values of weighting factors regarding actual data in [119]. In another study, to forecast energy demand of Turkey, ACO-PSO based hybrid method was applied [109]. Hybrid ACO-PSO method was applied for to forecast the wind power output of Binaloud wind farm in Iran in [110]. To forecast Annual electricity demand, Yu et al. utilized GA to optimizes the

structure and PSO-GA to the parameters of the basis and weights of the Radial Basis Function (RBF) neural network [162]. Yu et al. applied PSO-GA approach for forecasting energy demand of China [122] and primary energy demand of China [123]. In another study, Yu et al. utilized improved PSO-GA to forecast energy demand for China [163]. Lee et al. constructed a GP-based GM(1, 1) model [164] and hybrid dynamic GPGM model [165] to predict energy consumption.

Hu et al. applied firefly algorithm (FA) based memetic algorithm (FA-MA) to appropriately determine the parameters of SVR model for load forecasting [108]. Hong, W.-C. developed IA-SVR model for electric load forecasting [133]. Fan et al. integrated two machine learning techniques: Bayesian clustering by dynamics (BCD) and SVR to forecast the electricity load [166].

Hsu et al. developed an improved GM (1, 1) model that combines residual modification with ANN sign estimations [167]. For predicting hourly load demand Bashir et al. applied ANNs and utilized PSO algorithm to adjust the network's weights in the training phase of the ANNs [168]. Xie et al. constructed improved natural gas consumption GM (1, 1) model by applying GM for optimizing parameters [169].

Zhang et al. utilized SA with chaotic GA to develop a chaotic genetic algorithm-simulated annealing algorithm (CGASA), with an SVR model to improve load forecasting. The proposed CGASA was utilized for the internal randomness of chaotic iterations to overcome premature local optimum, which yielded better accuracy [104]. SA algorithms were employed to choose the parameters of an SVM model to develop SVM-SA method to forecast electricity load in Taiwan in [134]. Ko et al. combined SVR, radial basis function neural network (RBFNN), and dual extended Kalman filter (DEKF) to develop an SVR-DEKF-RBFNN model for short-term load forecasting [170]. To forecast electric load, CAS was applied to improve the forecasting performance of SVR by searching its suitable parameters combination in [125]. Azadeh et al. developed electrical energy consumption forecasting models with GM-ANN method, where GA tuned parameters and the best coefficients with minimum error were identified for ANN [171]. Cinar et al. applied GA to determine the hidden layer neuron numbers for GA-FFBPNN model to forecast the hydro energy potential of Turkey [172]. Xiaobo et al. developed a GRA-DE-SVR model for short-term load forecasting with DE and SVR [129].

For forecasting world CO₂ emissions, BCO was utilized for finding optimal values of weighting factors for forecasting with ANN [116]. In another study, chaotic artificial bee colony algorithm was applied to determine suitable values of its three parameters for electric load forecasting [117]. Continue genetic algorithm was applied to determine the number of neurons in the hidden layer and connecting weights for ANN model to forecast short-term electricity load [173]. For accurate forecasting of electric load, Hong W.-C. applied CAS, CGA, CPSO, and SA with SVR model, to determine suitable parameter combination for the model [126].

GSA was utilized to assist the seasonal SVR model to develop SVRGSA and SSVRGSA for forecasting electricity load in Taiwan in [86]. Yuan et al. developed an LSSVM-GSA model to short-term wind power prediction model where GSA was applied to optimize the parameters of the LSSVM [85]. Niu et al. applied particle swarm optimization (PSO) as a training algorithm to obtain the weights of the forecasting methods (i.e., a method of proportional (MP), LR, GM, and BPNN) [115]. Wang et al. developed a load forecasting model with DE and SVR, where DE algorithm was used to choose the appropriate parameters for the SVR model [127]. Wang et al. applied ADE-BPNN forecasting method for developing prediction for electricity demand compared with different methods (i.e., ARIMA, BPNN, GA-BPNN, DE-BPNN, SSVRCGASA, and TF-e-SVR-SA) [128]. Cao et al. applied quantum-behaved particle swarm optimization (QPSO) to optimize the parameters for the SVR model and developed an SVR-QPSO model to forecast the energy demand of China [174].

5.4. Statistical-MP methods

Forouzanfar et al. forecasted natural gas consumption for residential and commercial sectors in Iran by utilization of LoR. However, NLP and GA based approach were proposed to estimate the logistic parameters, to make the process simpler [103].

6. Discussion

6.1. Accuracy

An accurate forecasting of energy (demand and supply) and relevant parameters is critical to making informed decisions on energy infrastructure for power generation and distribution. Forecasting accuracy is determined using different performance evaluation measures. Root mean square error (RMSE), mean absolute error (MAE) and mean absolute percentage forecast error (MAPE) were mostly utilized [61,115,134,147,175–177]. Among other methods, mean absolute deviation (MAD), normalized root-mean-square error measure (NRMSE), standard error of prediction (SEP) and absolute relative error (ARE) were also applied [44,134,145,175]. The accuracy evaluation methods were different in various models. The different choice of accuracy methods made is hard to categorize the methods from best to worst because the methods were not evaluated with same data or for the similar aim. Under this circumstances, this study focused on the accuracy results of the reviewed models and their comparisons to find out which model performs better in specific objective (Table 8).

This study found that combination of statistical methods performs better than that of stand-alone statistical methods and [188] [61,183] [184] [184] [60,62,136,189] [190] [175] in most of the cases, CI methods outperformed statistical methods [191]. Moreover, hybrid methods performed superiorly in accuracy to CI methods (Table 8). In case of forecasting nonlinear and discontinuous data, machine learning methods performed better than that of statistical methods [81,167,178]. When the relationship between the variables is not known, or complex machine learning methods can forecast the data, which is difficult to handle statistically [179]. In some studies, authors combined machine learning methods with statistical methods to increase the accuracy [88,139,143,151,180]. However, machine learning methods tend to be complex in learning and application, while statistical methods are easy to adopt [181]. Some authors noted the learning complexity of methods influence the choice of forecasting techniques [103]. Data availability also affects the choice of forecasting method. ANN is a data-driven method and requires a large amount of data for higher forecasting accuracy [182]. In case of incomplete data sets, fuzzy logic is better. However, the accuracy level is not always satisfactory [182]. Grey prediction is another useful method while working with uncertainty problems with the small sample; incomplete and discrete data [183,184]. Significant numbers of authors advocated the utilization of hybridization methods to enhance the accuracy of the forecasting models. On the other hand, it would add more complexity in the model structure.

6.2. Time analysis

Based on the analysis of the previous EPMs, the research on forecasting models started in 1985, after the oil shock/crisis of 1970's (Fig. 4). At the starting period, the number of models was low. After the United Nations Framework Convention on Climate Change (UNFCCC) committed State Parties to reduce GHG gas emission created by anthropogenic CO₂ emission systems, the development of forecasting EPMs started to rise from 1995 because energy sector has been one of the highest global emissions sources.

The number of models started to increase from 2005 when the Kyoto Protocol was entered into force in 2005. The number of models published escalated from 12 to 25 within 2004–2005. In the last 12

Table 8
Method-wise accuracy of the selected reviewed models.

Forecasting objective	Methods	Accuracy ^a							Best method	Ref.
		MAPE (%)	MAE (-)	RMSE (-)	MAD (-)	NRMSE (-)	SEP (-)	ARE (%)		
Electricity price	WT–GARCH–ARIMA	1.61	-	-	-	-	-	-	WT–GARCH–ARIMA	[136]
	ARIMA	10.61	-	-	-	-	-	-		
	ARIMA–GARCH	8.65	-	-	-	-	-	-		
	WT–ARIMA	6.37	-	-	-	-	-	-		
Electricity consumption	AR (1) + HPF	-	4.64[†]	-	-	-	-	-	AR (1) + HPF	[236]
	AR (1)	-	7.23 [†]	-	-	-	-	-		
	ARIMA	-	6.11 [†]	-	-	-	-	-		
	ARMAX	38.88	-	104.77	77.27	-	-	-	ARMAX	[35]
Power from PV system	ARIMA	76.66	-	172.96	140.9	-	-	-		
	Single moving average	82.09	-	190.59	153.8	-	-	-		
	Double moving average	88.10	-	180.25	152.0	-	-	-		
	Single exponential smoothing	72.93	-	180.95	141.5	-	-	-		
	Double exponential smoothing	72.85	-	181.04	141.5	-	-	-	ANN	[191]
	Holte Winter's additive	72.36	-	185.10	144.6	-	-	-		
	Holte Winter's multiplicative	75.94	-	185.43	146.5	-	-	-		
	LR	8.60	1341.57	1508.96	-	-	-	-		
	RSREG ^b	9.51	1489.72	1701.90	-	-	-	-		
	ARMAX	4.83	764.90	931.13	-	-	-	-		
Electricity consumption (48 historical data)	ANN	3.19	460.74	635.38	-	-	-	-	ANN	[191]
	LR	8.84	1376.26	1542.43	-	-	-	-		
	RSREG ^b	7.58	1171.78	1295.43	-	-	-	-		
	ARMAX	8.88	1386.99	1566.34	-	-	-	-		
Electricity consumption (132 historical data)	ANN	4.02	598.65	709.25	-	-	-	-	ANN	[414]
	WARCH	2.90	-	-	-	-	-	-		
	SEGARCH	3.65	-	-	-	-	-	-		
	WARCH-ANN	2.56	-	-	-	-	-	-		
Energy consumption	SEGARCH-ANN	2.98	-	-	-	-	-	-	WARCH-ANN	[414]
	PSO (training)	2.42	-	-	-	-	-	-		
	PSO (test set)	2.52	-	-	-	-	-	-		
	BP algorithm (training)	3.2	-	-	-	-	-	-		
Electricity demand	BP algorithm (test set)	2.82	-	-	-	-	-	-	PSO	[161]
	ARMA (training)	3.98	-	-	-	-	-	-		
	ARMA (test set)	3.93	-	-	-	-	-	-		
	GPGM (1, 1) (training)	2.59	-	-	-	-	-	-		
Energy consumption	GPGM (1, 1) (test set)	20.23	-	-	-	-	-	-	GPGM (1, 1)	[164]
	GM(1,1) (training)	4.13	-	-	-	-	-	-		
	GM(1,1) (test set)	26.21	-	-	-	-	-	-		
	LR (training)	4.20	-	-	-	-	-	-		
Energy consumption	LR (test set)	27.76	-	-	-	-	-	-	Hybrid dynamic GM	[165]
	Hybrid dynamic GM	0.40	874.19	1383.11	-	-	-	-		
	GM (1,1)	16.94	26945.07	30384.99	-	-	-	-		
	NDGM(1,1)	33.33	73052.8	93230.75	-	-	-	-		
Mid-term load forecasting	ARIMA	17.99	41890.49	59271.76	-	-	-	-	DLS-SVM	[350]
	GP	5.12	10631.51	13325.14	-	-	-	-		
	Hybrid GM(1,1)	4.93	9949.13	12054.78	-	-	-	-		
	DLS-SVM	1.082	-	-	-	-	-	-		
Solar radiation	LS-SMV	1.101	-	-	-	-	-	-	FNN	[356] [355] [147] [517]
	SMV	2.149	-	-	-	-	-	-		
	FNN	6.03–9.65	-	-	-	-	-	-		
	ARIMA and descriptive statistics	Around 30	-	-	-	-	-	-		
Power demand	Fuzzy logic	13.9 -20.2	-	-	-	-	-	-	Improved GM (1,1)	[147] [167]
	ANN	10.9-20.3	-	-	-	-	-	-		
	GM (1,1)	3.88	-	-	-	-	-	-		
	Improved GM (1,1)	1.29	-	-	-	-	-	-		
CO ₂ emission	ARIMA	2.27	-	-	-	-	-	-	GP (4 year)	[230]
	ARIMA	2.75	9.81	11.25	-	-	-	-		
	GP (4 year)	2.46	8.78	11.25	-	-	-	-		
	GP (5 year)	4.22	15.27	17.60	-	-	-	-		
Energy consumption	GP (6 year)	2.60	9.29	11.75	-	-	-	-	ARIMA	[230]
	ARIMA	1.75	158.11	174.36	-	-	-	-		
	GP (4 year)	4.40	427.07	627.61	-	-	-	-		
	GP (5 year)	3.32	320.06	455.69	-	-	-	-		
Economic growth (GDP)	GP (6 year)	2.45	231.23	304.28	-	-	-	-	GP (4 year)	[230]
	ARIMA	4.17	32.06	41.49	-	-	-	-		
	GP (4 year)	1.81	13.69	19.15	-	-	-	-		
	GP (5 year)	3.41	26.17	36.90	-	-	-	-		
	GP (6 year)	5.44	41.45	55.84	-	-	-	-		

(continued on next page)

Table 8 (continued)

Forecasting objective	Methods	Accuracy ^a							Best method	Ref.
		MAPE (%)	MAE (-)	RMSE (-)	MAD (-)	NRMSE (-)	SEP (-)	ARE (%)		
Energy consumption	GM	-	-	-	-	-	-	7.17	GM-ARMA	[145]
	ARMA	-	-	-	-	-	-	7.62		
	GM-ARMA	-	-	-	-	-	-	4.39		
Wind speed	SARIMA-LSSVM	6.76	-	-	-	-	-	-	SARIMA-LSSVM	[43]
	ARIMA	18.08	-	-	-	-	-	-		
	SARIMA	11.08	-	-	-	-	-	-		
	LSSVM	8.83	-	-	-	-	-	-		
	GM	8.93	-	-	-	-	-	-		
	ARIMA-SVM	14.81	-	-	-	-	-	-		
Electric load	ARIMA	6.044	-	-	-	-	-	-	SSVRCGA	[351]
	SVRCGA	3.382	-	-	-	-	-	-		
	SSVRCGA	2.695	-	-	-	-	-	-		
Electric load	SVRCPSO	1.61	-	-	-	-	-	-	SVRCPSO	[126]
	SVRPSO	3.14	-	-	-	-	-	-		
	SVMSA	1.76	-	-	-	-	-	-		
	ARIMA	10.31	-	-	-	-	-	-		
Electricity demand	SARIMA	6.08	-	-	-	-	-	-	MA-C-WH	[34]
	MA-C-H	3.86	-	-	-	-	-	-		
	MA-C-WH	3.69	-	-	-	-	-	-		
Electric load	SSVRCGASA	3.73	-	-	-	-	-	-	SSVRCGASA	[104]
	TF-e-SVR-SA	3.799	-	-	-	-	-	-		
	ARIMA	6.04	-	-	-	-	-	-		
Electric load (Eastern regional)	SVRCAS	2.23	-	-	-	-	-	-	SVRCPSO	[125]
	SVRCPSO	2.19	-	-	-	-	-	-		
	SVRCGA	2.57	-	-	-	-	-	-		
	Regression	4.1	-	-	-	-	-	-		
Electric load	ANN	3.6	-	-	-	-	-	-	SRSVRCABC	[117]
	ARIMA	6.04	-	-	-	-	-	-		
	TF-e-SVR-SA	3.80	-	-	-	-	-	-		
	SSVRCABC	3.06	-	-	-	-	-	-		
	SRSVRCABC	2.39	-	-	-	-	-	-		
Electric load	ARIMA	10.31	-	-	13788	0.105997	-	-	SVMSA	[134]
	GRNN	5.18	-	-	6758	0.054732	-	-		
	SVMSA	1.76	-	-	2,448	0.026357	-	-		
Electric load	SSVRGSA	2.587	-	-	-	-	-	-	SSVRGSA	[86]
	ARIMA	6.044	-	-	-	-	-	-		
	SVRGSA	3.199	-	-	-	-	-	-		
	TF-e-SVR-SA	3.799	-	-	-	-	-	-		
Electricity demand	ADE-BPNN	1.725	3.0623	3.9925	-	-	-	-	ADE-BPNN	[128]
	ARIMA	6.044	10.6641	12.3787	-	-	-	-		
	BPNN	3.341	5.9958	6.9870	-	-	-	-		
	GA-BPNN	3.168	5.5618	6.9285	-	-	-	-		
	DE-BPNN	3.080	5.4004	6.8622	-	-	-	-		
	SSVRCGASA	1.901	3.4347	4.1822	-	-	-	-		
	TF-e-SVR-SA	3.799	6.9694	8.6167	-	-	-	-		
Electric load	SVM	-	-	12.37 [†]	-	-	-	-	GRA-DE-SVR	[129]
	GRA-DE-SVR	-	-	10.85[†]	-	-	-	-		
	ARMA	-	-	10.93 [†]	-	-	-	-		
	LR	-	-	11.99 [†]	-	-	-	-		
	PCMACP	-3.42	-	-	-	-	-	-		
Natural gas consumption	Polynomial Curve (2nd order)	-10.75	-	-	-	-	-	-	PCMACP	[33]
	BP neural network	-10.68	-	-	-	-	-	-		
	GM	-39.61	-	-	-	-	-	-		
	WARCH-ANN	2.56	404184.2	531545.14	-	-	-	-		
	WARCH	2.90	474189.2	643744.33	-	-	-	-		
Petroleum consumption	SEGARCH	3.65	606629.3	824500.08	-	-	-	-	WARCH-ANN	[61]
	SEGARCH-ANN	2.98	464632.4	596013.96	-	-	-	-		
	WARCH-ANN	3.51	112542.5	134832.21	-	-	-	-		
	WARCH	4.08	134300.1	165753.68	-	-	-	-		
	SEGARCH	4.88	167031.1	204369.84	-	-	-	-		
Electricity demand	SEGARCH-ANN	3.71	122320.1	148234.91	-	-	-	-	F-S-SARIMA	[44]
	F-S-SARIMA^c	2.19	-	4.91	-	-	2.65	-		
	SARIMA	3.28	-	6.67	-	-	3.74	-		
	F-SARIMA	2.75	-	6.57	-	-	3.68	-		
	S-SARIMA	2.91	-	6.25	-	-	3.37	-		

(continued on next page)

Table 8 (continued)

Forecasting objective	Methods	Accuracy ^a							Best method	Ref.
		MAPE (%)	MAE (-)	RMSE (-)	MAD (-)	NRMSE (-)	SEP (-)	ARE (%)		
Electricity demand	COR-ACO-GA	-	-	1292.381	-	-	-	-	COR-ACO-GA	[95]
	ANFIS	-	-	4563.398	-	-	-	-		
	ANN	-	-	6323.944	-	-	-	-		
Natural gas demand	COR-ACO-GA	-	-	648.31	-	-	-	-		
	ANFIS	-	-	1206.816	-	-	-	-		
	ANN	-	-	2178.246	-	-	-	-		
Oil products demand	COR-ACO-GA	-	-	3.750578	-	-	-	-		
	ANFIS	-	-	8.795963	-	-	-	-		
	ANN	-	-	11.05846	-	-	-	-		
Electricity price	BPANN	29.46	8.5021	-	-	-	-	-	DCANN	[251]
	FNN	22.03	6.8929	-	-	-	-	-		
	LSSVM	9.50	4.4632	-	-	-	-	-		
	ARFIMA	35.08	8.8737	-	-	-	-	-		
	GARCH	25.11	7.2425	-	-	-	-	-		
	DCANN	8.87	4.2611	-	-	-	-	-		
Electric load	ARMA	2.3688	34.0608	2.9198	-	-	-	-	SVR-MFA	[270]
	ANN	1.9569	28.8032	2.6396	-	-	-	-		
	SVR-GA	1.8501	27.3499	2.1943	-	-	-	-		
	SVR-HBMO	1.8375	26.5383	2.0007	-	-	-	-		
	SVR-FA	1.8051	26.1718	2.5667	-	-	-	-		
	SVR-PSO	1.7381	24.0145	2.1399	-	-	-	-		
	SVR-MFA	1.6909	22.5423	2.0604	-	-	-	-		
	SC-SVR	2.36	3913.88	-	-	-	-	-	SC-SVR	[369]
Energy demand	LSSVR	4.77	8285.22	-	-	-	-	-		
	BPNN	3.61	4549.69	-	-	-	-	-	FNF-SVRLP	[271]
Energy demand	ARMA	6.1	13.6	-	-	-	-	-		
	ANN	5.3	11.9	-	-	-	-	-		
	SVRLP	4.4	10.4	-	-	-	-	-		
	FNF-SVRLP	3.8	9.2	-	-	-	-	-		

^a Accuracy metrics: Mean absolute percentage forecast error (MAPE), mean absolute error (MAE), root mean square error (RMSE), mean absolute deviation (MAD), normalized root-mean-square error measure (NRMSE), standard error of prediction (SEP) and absolute relative error (ARE).

^b Response surface regression model (RSREG).

^c PSO optimal Fourier approach on residual modification of SARIMA was applied.

[†] The values in the study was reported in percentage (%).

years, 76% EPMs were developed (Fig. 4). The highest number of models (46) was developed in 2010. However, the number of EPMs reduced to 34 in 2011 & 2012. In 2013 and 2014, the published model number reduced to 20 and 24 respectively. The EPM number elevated to 27 in 2015. Up to June 2017, six models were published with the objective of forecasting in energy planning sector.

Among the forecasting methods, statistical methods were the first to rise in use from 2005. Before 1990, statistical methods were mostly utilized (Fig. 5). After 1990's use of machine learning methods started to rise. From 2007, the use of machine learning methods augmented significantly as well as with statistical methods. After 2009 the

integration of metaheuristic methods in forecasting started to grow. In 2015, 56 models utilized CI methods which is four times more than that of the statistical ones (14 models). The CI method use is demonstrating an exponential growth in past 12 years, where statistical methods are showing a gradual descend since 2010 (Fig. 5). A major cause of the growth may be the better accuracy of the CI methods (Table 8) and higher speed in computational capabilities [185].

6.3. Geographical analysis

Continent-wise, all the continents with human habitation developed




Fig. 4. Publishing year of the studied models.




Fig. 5. Publishing year of the models with methods utilized in energy planning models.

EPMs. According to United Nations, there 269 countries in the world [186]. Among these countries, forecasting models were developed for only 59 countries. Among all the countries, the highest number of forecasting models were developed in China. Total 122 models were developed in China with 27 of the 50 analyzed methods of this study.

In Europe, there are 53 countries [186], but only 18 countries developed energy planning forecasting models. The countries were- UK, Ireland, France, Netherlands, Denmark, Germany, Spain, Portugal, Italy, Croatia, Romania, Russia, Czech Republic, Hungary, Poland, Cyprus, Greece, and Turkey. However, most of the models were developed in the UK, Turkey, Spain, and Greece (Fig. 6).

There are 41 countries in North America [186]. However, only six countries (Haiti, Jamaica, Trinidad and Tobago, Mexico, USA and Canada) developed models for energy forecasting. Most of the models among these countries were developed in the USA (Fig. 6).

The continent of Oceania contains 25 countries [186], of which only Australia and New Zealand developed models. In this region other 23 countries of Melanesia, Micronesia and Polynesia are considered developing regions [186]. This concludes the fact that in this continent only developed countries established energy forecasting models.

In Asia, Japan, China, Hong Kong, Taiwan, South Korea, Jordan, Lebanon, Oman, Saudi Arabia, Kuwait, Iran, Pakistan, India, Bangladesh, Sri Lanka, Nepal, Indonesia, Singapore, Philippines, Malaysia, and Thailand developed forecasting models for energy planning. Therefore, 21 countries among 50 countries [186] of the continents developed forecasting models. In Asia, the only developed economy is established in Japan. Along with Japan, other developing countries also established some models. In Asia, China, Taiwan, Iran, and India developed a higher number of forecasting models.

Africa has 58 countries, of which only five countries developed forecasting models. Namibia, Ghana, Algeria, Tunisia and South Africa established 2, 4, 2, 1 and five models respectively.

Among 14 countries of South America, Ecuador, Peru, Chile, Venezuela, Columbia, Argentina and Brazil adopted forecasting model for energy planning. Brazil developed the most number of models.

Among the studied 483 models, twelve models were developed for global forecasting (Table 2). LR, ANN, GA, ABCO, and PSO were utilized for forecasting for global geographical extent (Fig. 6).

However, 30 models were established for regional geographical extent. The regions considered were- OECD countries, G-7 countries, Europe, CIS Countries, GCC countries, BRIC country, Middle East, North America, South America, Asia and developing countries. Among the 30 models, eight models were developed for Europe. From the analysis of the geographical extent, it is evident that developed economies have more EPMS than that of developing and least developed ones (Fig. 6). Statistical methods are utilized for developed, developing and least developed contexts. However, CI methods are widely used in developed contexts (Fig. 6).

6.4. Objective based analysis

The studied EPMS had different objectives. From the analysis of 483 models, 11 objectives were identified (Table 9). These were energy and electricity demand, energy supply, renewable energy, GHG emissions, energy economic, socio-economic, energy and electricity price, load forecasting, planning and policy analysis, performance analysis and model development. Among the 28 statistical forecasting methods, ARIMA was used for nine objectives, while LR complied with seven




Fig. 6. Country wise number of models utilizing different forecasting methods.

objectives, followed by ARMA (6 objectives) (Table 9). Among the 28 statistical methods, 23 were utilized for energy and electricity demand forecasting in 53.9% of the reviewed 483 models (Table 9).

Among the CI and MP methods, ANN was utilized for nine objectives, followed by GM for seven objectives. FL, SMV, PSO, and ACO were utilized for six objectives each. Moreover, GA was utilized for achieving five of the objectives (Table 10). Among the 22 CI and MP methods, 13 and 18 methods were utilized for energy and electricity demand, and electric load forecasting respectively. In the reviewed 483 models, 73%, 38%, 18% and 13% of the model objectives were energy and electricity demand, electric load, renewable energy, and energy & electricity price forecasting respectively. For energy and electricity demand forecasting, statistical methods were used in 18% more models than that of CI and MP. However, CI methods were utilized in 28% and

4% more in electric load and renewable energy forecasting models respectively than that of statistical ones (Fig. 7).

Among the 50 analyzed methods, a maximum number of methods (23 statistical, 12 CI and one MP) were utilized to develop energy and electricity demand forecasting models. Second highest number of methods (8 statistical and 18 CI) were utilized to forecast electric load. Third highest number of methods (7 statistical and 9 CI) were used for renewable energy forecasting (Tables 9 and 10).

7. Conclusion

Energy planning models assist stakeholders to assess the impact of current and future energy policies. The accuracy of EPMs depends on applying appropriate forecasting methods for demand and supply sector

Table 9
Statistical method-wise objective of the reviewed models.

Objectives Methods	Energy Demand	Energy Supply	Renewable energy	GHG emissions	Energy economic	Socio economic	Energy and electricity price	Load forecasting	Planning and/or Policy analysis	Performance	Model development	Total %
LR	■	■	-	■	■	-	■	■	-	-	■	7 9.0%
NLR	■	■	-	■	■	-	-	-	-	-	■	5 6.4%
LoR	■	■	■	■	-	-	-	-	-	-	-	4 5.1%
NR	-	-	■	-	-	-	-	■	-	-	-	2 2.6%
PLSR	■	-	-	-	-	-	-	-	-	-	-	1 1.3%
GP	■	-	-	-	-	-	-	-	-	-	-	1 1.3%
Log linear analysis	■	-	-	-	■	-	-	-	-	-	-	2 2.6%
Translog	■	-	-	-	-	-	-	-	-	-	-	1 1.3%
Polynomial curve model	■	-	-	-	-	-	-	-	-	-	-	1 1.3%
MA	■	-	-	-	-	-	-	-	-	-	-	1 1.3%
ARIMA	■	■	■	■	■	■	■	■	-	-	■	9 11.5%
SARIMA	■	■	■	-	■	-	-	■	-	-	-	5 6.4%
ARMAX	-	-	■	-	-	-	■	■	-	-	-	3 3.8%
ARMA	■	-	■	■	-	-	■	■	-	-	■	6 7.7%
ANOVA	■	-	-	■	-	-	-	-	-	-	-	2 2.6%
SR	■	■	-	-	-	-	-	-	-	-	-	2 2.6%
VAR	■	-	-	-	-	-	■	-	-	-	-	2 2.6%
ARDL	■	-	-	-	-	-	■	-	-	-	-	3 3.8%
PAM	■	-	-	-	-	■	■	-	-	-	-	1 1.3%
GARCH	■	-	-	-	-	-	■	-	-	-	-	3 3.8%
SEGARCH	■	-	-	-	■	-	-	-	-	-	-	1 1.3%
EGARCH	-	-	-	-	-	-	■	-	-	-	-	1 1.3%
WARCH	■	-	-	-	-	-	-	-	-	-	-	1 1.3%
Decomposition	■	■	-	■	-	-	■	■	-	-	■	6 7.7%
Unit root test and/or Cointegration	■	-	-	■	■	■	■	-	-	-	-	5 6.4%
BVAR	■	-	■	-	-	-	-	■	-	-	-	3 3.8%
Number of methods	23	7	7	8	7	3	10	8	0	0	5	
Number of models	186	11	29	29	14	15	32	23	0	0	6	
Percentage of model (%)	53.9%	3.2%	8.4%	8.4%	4.1%	4.3%	9.3%	6.7%	0.0%	0.0%	1.7%	

Table 10
CI and mathematical method-wise objective of the reviewed models.

Objectives Methods	Energy Demand	Energy Supply	Renewable energy	GHG emissions	Energy economic	Socio economic	Energy and electricity price	Load forecasting	Planning and/or Policy analysis	Performance	Model development	Total	%
SVM	■	–	■	–	■	–	■	■	–	–	■	6	8.8%
Decision tree	■	–	■	–	–	–	–	■	–	–	–	3	4.4%
ANN	■	■	■	■	■	–	■	■	–	■	■	9	13.2%
Abductive net- works	■	–	–	–	–	–	–	–	–	–	–	1	1.5%
Grey predic- tion	■	■	■	■	–	■	■	■	–	–	–	7	10.3%
Fuzzy logic	■	–	■	–	–	–	■	■	■	■	–	6	8.8%
Expert system	■	–	–	–	–	–	–	■	–	–	–	2	2.9%
GA	■	–	–	■	–	–	–	■	■	–	■	5	7.4%
ABCO	–	–	–	■	–	–	–	■	–	–	–	2	2.9%
ACO	■	■	■	■	–	–	–	■	■	–	–	6	8.8%
PSO	■	–	■	■	–	–	■	■	■	–	–	6	8.8%
GSA	■	–	■	–	–	–	–	■	–	–	–	3	4.4%
CAS	–	–	–	–	–	–	–	■	–	–	–	1	1.5%
DE	–	–	–	–	–	–	–	■	–	–	■	2	2.9%
HS	■	–	–	–	–	–	–	–	–	–	–	1	1.5%
EA	–	–	–	–	–	–	–	■	–	–	–	1	1.5%
MA	–	–	–	–	–	–	–	■	–	–	–	1	1.5%
IA	–	–	–	–	–	–	–	■	–	–	–	1	1.5%
SA	–	–	■	–	–	–	–	■	–	–	–	2	2.9%
FA	–	–	–	–	–	–	–	■	–	–	–	1	1.5%
CSA	–	–	–	–	–	–	■	–	–	–	–	1	1.5%
NLP	■	–	–	–	–	–	–	–	–	–	–	1	1.5%
Number of methods	13	3	9	6	2	1	6	18	4	2	4		
Number of models	169	5	59	17	5	1	29	162	4	3	12		
Percentage of model (%)	36.3%	1.1%	12.7%	3.6%	1.1%	0.2%	6.2%	34.8%	0.9%	0.6%	2.6%		




Fig. 7. Objectives of the models.

projections. Among all the forecasting methods, choice of appropriate one depends on different factors. The complexity and nature, as well as, the objective of the research problem are one of the critical determinants of method choice. Other important factors of forecasting method selection can be accuracy and estimation adaptability with incomplete data-set.

The review of 483 EPMS, revealed the use of fifty different methods

between 1985 and June 2017. Among the 50 identified methods, statistical, computational intelligence (CI) and mathematical programming (MP) methods were 28, 21 and one respectively. Among CI methods, ANN was utilized in 194 EPMS, followed by SVM (58 models), FL (40 models), GA (39 models), PSO (34 models) and GM (29 models). In the case of statistical methods, ARIMA, LR, and ARMA were utilized in 46, 39 and 22 EPMS respectively for forecasting. Evidently, CI

methods were widely utilized than that of statistical ones for electric load and renewable energy forecasting. However, statistical methods were used in 18% more models than that of CI and MP for energy and electricity demand forecasting. The accuracy of CI methods for forecasting was better than that of statistical ones. A significant number of forecasting models utilized multiple stand-alone methods to develop a hybrid approach because they yielded higher accuracy than that of stand-alone ones. In case of incomplete data-set, some CI methods such as fuzzy logic and grey prediction outperformed other stand-alone ones.

The analysis of the studied model objectives showed that most of the forecasting methods were applied to forecast energy demand and electrical load. The development of the forecasting models started from 1985, it spiked after 2005, and it is continuing. Most numbers of models were developed in 2010. In case of the geographical extent, although most of the models were established for developed countries, some of the developing countries also established forecasting models. The highest number of models were developed for China.

References

- [1] Solomon S, et al. Irreversible climate change due to carbon dioxide emissions. *Proc Natl Acad Sci* 2009;106(6):1704–9.
- [2] Le Quéré C, et al. Trends in the sources and sinks of carbon dioxide. *Nat Geosci* 2009;2(12):831–6.
- [3] Ramanathan V, Feng Y. On avoiding dangerous anthropogenic interference with the climate system: Formidable challenges ahead. *Proc Natl Acad Sci* 2008;105(38):14245–50.
- [4] Wigley TM. The climate change commitment. *Science* 2005;307(5716):1766–9.
- [5] Friedlingstein P, Solomon S. Contributions of past and present human generations to committed warming caused by carbon dioxide. *Proc Natl Acad Sci USA* 2005;102(31):10832–6.
- [6] Ha-Duong M, Grubb MJ, Hourcade J-C. Influence of socioeconomic inertia and uncertainty on optimal CO₂-emission abatement. *Nature* 1997;390(6657):270–3.
- [7] Davis SJ, Caldeira K, Matthews HD. Future CO₂ emissions and climate change from existing energy infrastructure. *Science* 2010;329(5997):1330–3.
- [8] Mourshed M, Qudus MA. renewable energy RD&D expenditure and CO₂ emissions in 15 European countries. *Int J Energy Sect Manag* 2009;3(2):187–202.
- [9] Nguyen QK. Long term optimization of energy supply and demand in Vietnam with special reference to the potential of renewable energy. University of Oldenburg; 2005.
- [10] Barsky R, Kilian L. Oil and the Macroeconomy since the 1970s. National Bureau of Economic Research; 2004.
- [11] Mathur J. Development of a modified dynamic energy and greenhouse gas reduction planning approach through the case of Indian power sector [in Mechanical and Process Engineering]. University of Duisburg-Essen; 2001.
- [12] Mondal MAH. Implications of renewable energy technologies in the Bangladesh power sector: long-term planning strategies [in Institute of Agricultural Engineering/Center for Development Research (ZEF). University of Bonn; 2010.
- [13] Bolin B, et al., IPCC Second Assessment Synthesis of Scientific-Technical Information relevant to interpreting Article 2 of the UN Framework Convention on Climate Change; 2008.
- [14] Pfenninger S, Hawkes A, Keirstead J. Energy systems modeling for twenty-first century energy challenges. *Renew Sustain Energy Rev* 2014;33:74–86.
- [15] Suganthi L, Samuel AA. Energy models for demand forecasting—A review. *Renew Sustain Energy Rev* 2012;16(2):1223–40.
- [16] Weron R. Modeling and forecasting electricity loads and prices: a statistical approach 403. John Wiley & Sons; 2007.
- [17] Grubb M, et al. The costs of limiting fossil-fuel CO₂ emissions: a survey and analysis. *Annu Rev Energy Environ* 1993;18(1):397–478.
- [18] Dodge Y. The Oxford dictionary of statistical terms. Oxford University Press; 2006.
- [19] Song K-B, et al. Short-term load forecasting for the holidays using fuzzy linear regression method. *Power Syst, IEEE Trans on* 2005;20(1):96–101.
- [20] Bilgili M, et al. Electric energy demands of Turkey in residential and industrial sectors. *Renew Sustain Energy Rev* 2012;16(1):404–14.
- [21] Ghiassi M, Nangoy S. A dynamic artificial neural network model for forecasting nonlinear processes. *Comput Ind Eng* 2009;57(1):287–97.
- [22] Tsekouras GJ, et al. A non-linear multivariable regression model for midterm energy forecasting of power systems. *Electr Power Syst Res* 2007;77(12):1560–8.
- [23] Charytoniuk W, Chen M-S, Van Olinda P. Nonparametric regression based short-term load forecasting. *Power Syst, IEEE Trans on* 1998;13(3):725–30.
- [24] Wang C, et al. Short-term wind power forecast based on non-parametric regression model. *Autom Electr Power Syst* 2010;16:78–82.
- [25] Jónsson T, Pinson P, Madsen H. On the market impact of wind energy forecasts. *Energy Econ* 2010;32(2):313–20.
- [26] Zhang M, et al. Forecasting the transport energy demand based on PLSR method in China. *Energy* 2009;34(9):1396–400.
- [27] Meng M, Niu D. Annual electricity consumption analysis and forecasting of China based on few observations methods. *Energy Convers Manag* 2011;52(2):953–7.
- [28] Ekonomou L. Greek long-term energy consumption prediction using artificial neural networks. *Energy* 2010;35(2):512–7.
- [29] Tso GKF, Yau KKW. Predicting electricity energy consumption: a comparison of regression analysis, decision tree and neural networks. *Energy* 2007;32(9):1761–8.
- [30] Rao RD, Parikh JK. Forecast and analysis of demand for petroleum products in India. *Energy Policy* 1996;24(6):583–92.
- [31] Aranda A, et al. Multiple regression models to predict the annual energy consumption in the Spanish banking sector. *Energy Build* 2012;49(0):380–7.
- [32] Azadeh A, Ghaderi SF, Sohrabkhani S. Forecasting electrical consumption by integration of Neural Network, time series and ANOVA. *Appl Math Comput* 2007;186(2):1753–61.
- [33] Xu G, Wang W. Forecasting China's natural gas consumption based on a combination model. *J Nat Gas Chem* 2010;19(5):493–6.
- [34] Zhu S, et al. A seasonal hybrid procedure for electricity demand forecasting in China. *Appl Energy* 2011;88(11):3807–15.
- [35] Li Y, Su Y, Shu L. An ARMAX model for forecasting the power output of a grid connected photovoltaic system. *Renew Energy* 2014;66(0):78–89.
- [36] Cadenas E, Rivera W. Wind speed forecasting in the South Coast of Oaxaca, México. *Renew Energy* 2007;32(12):2116–28.
- [37] Jeong K, Koo C, Hong T. An estimation model for determining the annual energy cost budget in educational facilities using SARIMA (seasonal autoregressive integrated moving average) and ANN (artificial neural network). *Energy* 2014;71(0):71–9.
- [38] Ediger VŞ, Akar S. ARIMA forecasting of primary energy demand by fuel in Turkey. *Energy Policy* 2007;35(3):1701–8.
- [39] Damrongkulkarnjorn P, Churueang P. Monthly energy forecasting using decomposition method with application of seasonal ARIMA [in Power Engineering Conference, 2005. IPEC 2005. The 7th International]. IEEE.; 2005.
- [40] Ediger VŞ, Akar S, Uğurlu B. Forecasting production of fossil fuel sources in Turkey using a comparative regression and ARIMA model. *Energy Policy* 2006;34(18):3836–46.
- [41] Sumer KK, Goktas O, Hepsag A. The application of seasonal latent variable in forecasting electricity demand as an alternative method. *Energy Policy* 2009;37(4):1317–22.
- [42] Bouzderdoun M, Mellit A, Pavan A Massi. A hybrid model (SARIMA–SVM) for short-term power forecasting of a small-scale grid-connected photovoltaic plant. *Sol Energy* 2013;98(Part C(0)):226–35.
- [43] Guo Z, et al. A corrected hybrid approach for wind speed prediction in Hexi Corridor of China. *Energy* 2011;36(3):1668–79.
- [44] Wang Y, et al. Application of residual modification approach in seasonal ARIMA for electricity demand forecasting: a case study of China. *Energy Policy* 2012;48:284–94.
- [45] Boata R, Paulescu M. Application of Fuzzy Logic to Forecast Hourly Solar Irradiation.; 2014.
- [46] Wang J, et al. Combined modeling for electric load forecasting with adaptive particle swarm optimization. *Energy* 2010;35(4):1671–8.
- [47] Darbellay GA, Slama M. Forecasting the short-term demand for electricity: do neural networks stand a better chance? *Int J Forecast* 2000;16(1):71–83.
- [48] González V, Contreras J, Bunn DW. Forecasting power prices using a hybrid fundamental-econometric model. *Power Syst, IEEE Trans on* 2012;27(1):363–72.
- [49] Bakhat M, Rosselló J. Estimation of tourism-induced electricity consumption: the case study of Balearic Islands, Spain. *Energy Econ* 2011;33(3):437–44.
- [50] Wang B, et al. A new ARMAX model based on evolutionary algorithm and particle swarm optimization for short-term load forecasting. *Electr Power Syst Res* 2008;78(10):1679–85.
- [51] Lira F, et al. Short-term forecasting of electricity prices in the Colombian electricity market. *Gener, Transm Distrib, IET* 2009;3(11):980–6.
- [52] Hickey E, Loomis DG, Mohammadi H. Forecasting hourly electricity prices using ARMAX–GARCH models: an application to MISO hubs. *Energy Econ* 2012;34(1):307–15.
- [53] Chandramowli S, Lahr ML. Forecasting New Jersey's Electricity Demand Using Auto-Regressive Models; 2012. Available at SSRN 2258552.
- [54] Crompton P, Wu Y. Energy consumption in China: past trends and future directions. *Energy Econ* 2005;27(1):195–208.
- [55] Francis BM, Moseley L, Iyare SO. Energy consumption and projected growth in selected Caribbean countries. *Energy Econ* 2007;29(6):1224–32.
- [56] Miranda MS, Dunn RW. One-hour-ahead wind speed prediction using a Bayesian methodology [in Power Engineering Society General Meeting, 2006. IEEE]. IEEE; 2006.
- [57] García-Martos C, Rodríguez J, Sánchez MJ. Modelling and forecasting fossil fuels, CO₂ and electricity prices and their volatilities. *Appl Energy* 2013;101(0):363–75.
- [58] Dilaver Z, Hunt LC. Industrial electricity demand for Turkey: a structural time series analysis. *Energy Econ* 2011;33(3):426–36.
- [59] Dilaver Z, Hunt LC. Turkish aggregate electricity demand: an outlook to 2020. *Energy* 2011;36(11):6686–96.
- [60] Wang Y, Wu C. Forecasting energy market volatility using GARCH models: can multivariate models beat univariate models? *Energy Econ* 2012;34(6):2167–81.
- [61] Pao HT. Forecasting energy consumption in Taiwan using hybrid nonlinear models. *Energy* 2009;34(10):1438–46.
- [62] Bowden N, Payne JE. Short term forecasting of electricity prices for MISO hubs: evidence from ARIMA-EGARCH models. *Energy Econ* 2008;30(6):3186–97.
- [63] Adom PK, Bekoe W. Conditional dynamic forecast of electrical energy consumption requirements in Ghana by 2020: a comparison of ARDL and PAM. *Energy* 2012;44(1):367–80.
- [64] Kim SH, et al. Korean energy demand in the new millennium: outlook and policy implications, 2000–2005. *Energy Policy* 2001;29(11):899–910.
- [65] Zachariadis T. Forecast of electricity consumption in Cyprus up to the year 2030: the potential impact of climate change. *Energy Policy* 2010;38(2):744–50.

- [66] De Vita G, Endresen K, Hunt LC. An empirical analysis of energy demand in Namibia. *Energy Policy* 2006;34(18):3447–63.
- [67] Parikh J, Purohit P, Maitra P. Demand projections of petroleum products and natural gas in India. *Energy* 2007;32(10):1825–37.
- [68] Pili-Sihvola K, et al. Climate change and electricity consumption—Witnessing increasing or decreasing use and costs? *Energy Policy* 2010;38(5):2409–19.
- [69] Limanond T, Jomnonkwa S, Srikaew A. Projection of future transport energy demand of Thailand. *Energy Policy* 2011;39(5):2754–63.
- [70] Wadud Z, et al. Modeling and forecasting natural gas demand in Bangladesh. *Energy Policy* 2011;39(11):7372–80.
- [71] Mackay RM, Probert SD. Crude oil and natural gas supplies and demands up to the year ad 2010 for France. *Appl Energy* 1995;50(3):185–208.
- [72] Mackay RM, Probert SD. Crude oil and natural gas supplies and demands for Denmark. *Appl Energy* 1995;50(3):209–32.
- [73] Mackay RM, Probert SD. Forecasting the United Kingdom's supplies and demands for fluid fossil-fuels. *Appl Energy* 2001;69(3):161–89.
- [74] Furtado AT, Suslick SB. Forecasting of petroleum consumption in Brazil using the intensity of energy technique. *Energy Policy* 1993;21(9):958–68.
- [75] Nasr GE, Badr EA, Dibeh G. Econometric modeling of electricity consumption in post-war Lebanon. *Energy Econ* 2000;22(6):627–40.
- [76] Eltony MN. Demand for natural gas in Kuwait: an empirical analysis using two econometric models. *Int J Energy Res* 1996;20(11):957–63.
- [77] Azadeh A, Faiz ZS. A meta-heuristic framework for forecasting household electricity consumption. *Appl Soft Comput* 2011;11(1):614–20.
- [78] Azadeh A, Ghaderi SF, Sohrabkhani S. A simulated-based neural network algorithm for forecasting electrical energy consumption in Iran. *Energy Policy* 2008;36(7):2637–44.
- [79] Christoffersen PF, Diebold FX. Cointegration and long-horizon forecasting. *J Bus Econ Stat* 1998;16(4):450–6.
- [80] Curram SP, Mingers J. Neural networks, decision tree induction and discriminant analysis: an empirical comparison. *J Oper Res Soc* 1994:440–50.
- [81] Zhang G, Eddy Patuwo B, Hu MY. Forecasting with artificial neural networks: The state of the art. *Int J Forecast* 1998;14(1):35–62.
- [82] Ahmad MW, et al. Computational intelligence techniques for HVAC systems: a review. *Build Simul* 2016;9(4):359–98.
- [83] Yalcinoz T, Eminoglu U. Short term and medium term power distribution load forecasting by neural networks. *Energy Convers Manag* 2005;46(9–10):1393–405.
- [84] Carpintero OA, et al. Long-term load forecasting via a hierarchical neural model with time integrators. *Electr Power Syst Res* 2007;77(3):371–8.
- [85] Yuan X, et al. Short-term wind power prediction based on LSSVM-GSA model. *Energy Convers Manag* 2015;101:393–401.
- [86] Ju F-Y, Hong W-C. Application of seasonal SVR with chaotic gravitational search algorithm in electricity forecasting. *Appl Math Model* 2013;37(23):9643–51.
- [87] Abdel-Aal RE. Univariate modeling and forecasting of monthly energy demand time series using abductive and neural networks. *Comput Ind Eng* 2008;54(4):903–17.
- [88] Abdel-Aal R, Al-Garni A, Al-Nassar Y. Modelling and forecasting monthly electric energy consumption in eastern Saudi Arabia using abductive networks. *Energy* 1997;22(9):911–21.
- [89] Yu Z, et al. A decision tree method for building energy demand modeling. *Energy Build* 2010;42(10):1637–46.
- [90] Ho K-L, Hsu Y-Y, Yang C-C. Short term load forecasting using a multilayer neural network with an adaptive learning algorithm. *Power Syst, IEEE Trans on* 1992;7(1):141–9.
- [91] Rahman S, Bhatnagar R. An expert system based algorithm for short term load forecast. *Power Syst, IEEE Trans on* 1988;3(2):392–9.
- [92] Ho K-L, et al. Short term load forecasting of Taiwan power system using a knowledge-based expert system. *Power Syst, IEEE Trans on* 1990;5(4):1214–21.
- [93] Rahman S, Hazim O. Load forecasting for multiple sites: development of an expert system-based technique. *Electr Power Syst Res* 1996;39(3):161–9.
- [94] Jabbour K, et al. ALFA: automated load forecasting assistant. *Power Syst, IEEE Trans on* 1988;3(3):908–14.
- [95] Ghanbari A, et al. A Cooperative Ant Colony Optimization-Genetic Algorithm approach for construction of energy demand forecasting knowledge-based expert systems. *Knowl-Based Syst* 2013;39:194–206.
- [96] Ghanbari A, Abbasian-Naghneh S, Hadavandi E. An intelligent load forecasting expert system by integration of ant colony optimization, genetic algorithms and fuzzy logic [in Computational Intelligence and Data Mining (CIDM), 2011 IEEE Symposium on]. IEEE; 2011.
- [97] Elias CN, Hatziaargyriou ND. An annual midterm energy forecasting model using fuzzy logic. *Power Syst, IEEE Trans on* 2009;24(1):469–78.
- [98] Lin Y, Chen M-y, Liu S. Theory of grey systems: capturing uncertainties of grey information. *Kybernetes* 2004;33(2):196–218.
- [99] Deng J-L. Introduction to grey system theory. *J grey Syst* 1989;1(1):1–24.
- [100] Liu S, Lin Y. Grey information: theory and practical applications. Springer Science & Business Media; 2006.
- [101] Akay D, Atak M. Grey prediction with rolling mechanism for electricity demand forecasting of Turkey. *Energy* 2007;32(9):1670–5.
- [102] Canyurt OE, Ozturk HK. Application of genetic algorithm (GA) technique on demand estimation of fossil fuels in Turkey. *Energy Policy* 2008;36(7):2562–9.
- [103] Forouzanfar M, et al. Modeling and estimation of the natural gas consumption for residential and commercial sectors in Iran. *Appl Energy* 2010;87(1):268–74.
- [104] Zhang WY, et al. Application of SVR with chaotic GASA algorithm in cyclic electric load forecasting. *Energy* 2012;45(1):850–8.
- [105] Assareh E, Behrang M, Ghanbarzadeh A. Forecasting energy demand in Iran using genetic algorithm (GA) and particle swarm optimization (PSO) methods. *Energy Sources, Part B: Econ, Plan, Policy* 2012;7(4):411–22.
- [106] Assareh E, et al. Application of PSO (particle swarm optimization) and GA (genetic algorithm) techniques on demand estimation of oil in Iran. *Energy* 2010;35(12):5223–9.
- [107] Chaturvedi D, Mishra R, Agarwal A. Load forecasting using genetic algorithms. *J Inst Eng (India), EL* 1995;76(3):161–5.
- [108] Hu Z, Bao Y, Xiong T. Electricity load forecasting using support vector regression with memetic algorithms. *Sci World J* 2013;2013.
- [109] Kiran MS, et al. A novel hybrid approach based on Particle Swarm Optimization and Ant Colony Algorithm to forecast energy demand of Turkey. *Energy Convers Manag* 2012;53(1):75–83.
- [110] Rahmani R, et al. Hybrid technique of ant colony and particle swarm optimization for short term wind energy forecasting. *J Wind Eng Ind Aerodyn* 2013;123(Part A):163–70.
- [111] AlRashidi MR, El-Naggar KM. Long term electric load forecasting based on particle swarm optimization. *Appl Energy* 2010;87(1):320–6.
- [112] Kamrani E. Modeling and Forecasting long-term Natural Gas (NG) consumption in Iran, using Particle Swarm Optimization (PSO).; 2010.
- [113] Abdelfatah A, et al. Forecast Global Carbon Dioxide Emission Using Swarm Intelligence. *Int J Comput Appl* 2013;77(12):1–5.
- [114] Boeringer D, Werner D. A comparison of particle swarm optimization and genetic algorithms for a phased array synthesis problem [in Antennas and Propagation Society International Symposium, 2003. IEEE]. IEEE; 2003.
- [115] Niu D, et al. middle-long power load forecasting based on particle swarm optimization. *Comput Math Appl* 2009;57(11–12):1883–9.
- [116] Behrang M, et al. Using bees algorithm and artificial neural network to forecast world carbon dioxide emission. *Energy Sources, Part A: Recovery, Util, Environ Eff* 2011;33(19):1747–59.
- [117] Hong W-C. Electric load forecasting by seasonal recurrent SVR (support vector regression) with chaotic artificial bee colony algorithm. *Energy* 2011;36(9):5568–78.
- [118] Niu D, Wang Y, Wu DD. Power load forecasting using support vector machine and ant colony optimization. *Expert Syst Appl* 2010;37(3):2531–9.
- [119] Samsami R. Comparison Between genetic algorithm (GA), particle swarm Optimization (PSO) and ant colony Optimization (ACO) techniques for NO emission forecasting in Iran. *World Appl Sci J* 2013;28(12):1996–2002.
- [120] Duran Toksari M. Ant colony optimization approach to estimate energy demand of Turkey. *Energy Policy* 2007;35(8):3984–90.
- [121] Toksari MD. Estimating the net electricity energy generation and demand using the ant colony optimization approach: case of Turkey. *Energy Policy* 2009;37(3):1181–7.
- [122] Yu S, Zhu K, Zhang X. Energy demand projection of China using a path-coefficient analysis and PSO-GA approach. *Energy Convers Manag* 2012;53(1):142–53.
- [123] Yu S, Wei Y-M, Wang K. A PSO-GA optimal model to estimate primary energy demand of China. *Energy Policy* 2012;42(0):329–40.
- [124] Li L, et al. Parameters identification of chaotic systems via chaotic ant swarm. *Chaos, Solitons Fractals* 2006;28(5):1204–11.
- [125] Hong W-C. Application of chaotic ant swarm optimization in electric load forecasting. *Energy Policy* 2010;38(10):5830–9.
- [126] Hong W-C. Chaotic particle swarm optimization algorithm in a support vector regression electric load forecasting model. *Energy Convers Manag* 2009;50(1):105–17.
- [127] Wang J, et al. An annual load forecasting model based on support vector regression with differential evolution algorithm. *Appl Energy* 2012;94:65–70.
- [128] Wang L, Zeng Y, Chen T. Back propagation neural network with adaptive differential evolution algorithm for time series forecasting. *Expert Syst Appl* 2015;42(2):855–63.
- [129] Xiaobo X, et al. Short-term load forecasting for the electric bus station based on GRA-DE-SVR [in Innovative Smart Grid Technologies-Asia (ISGT Asia), 2014 IEEE]. IEEE; 2014.
- [130] Behrang MA, et al. Forecasting future oil demand in Iran using GSA (Gravitational Search Algorithm). *Energy* 2011;36(9):5649–54.
- [131] Gavrilas M, Ivanov O, Gavrilas G. Electricity load forecasting based on a mixed statistical-neural-computational intelligence approach [in Neural Network Applications in Electrical Engineering (NEUREL), 2014 12th Symposium on]. IEEE; 2014.
- [132] Ceylan H, et al. Transport energy modeling with meta-heuristic harmony search algorithm, an application to Turkey. *Energy Policy* 2008;36(7):2527–35.
- [133] Hong W-C. Electric load forecasting by support vector model. *Appl Math Model* 2009;33(5):2444–54.
- [134] Pai P-F, Hong W-C. Support vector machines with simulated annealing algorithms in electricity load forecasting. *Energy Convers Manag* 2005;46(17):2669–88.
- [135] Wang T-Y, Huang C-Y. Applying optimized BPN to a chaotic time series problem. *Expert Syst Appl* 2007;32(1):193–200.
- [136] Tan Z, et al. Day-ahead electricity price forecasting using wavelet transform combined with ARIMA and GARCH models. *Appl Energy* 2010;87(11):3606–10.
- [137] Liu H, Shi J. Applying ARMA-GARCH approaches to forecasting short-term electricity prices. *Energy Econ* 2013;37:152–66.
- [138] Cadenas E, Rivera W. Wind speed forecasting in three different regions of Mexico, using a hybrid ARIMA-ANN model. *Renew Energy* 2010;35(12):2732–8.
- [139] González-Romera E, Jaramillo-Morán MA, Carmona-Fernández D. Monthly electric energy demand forecasting with neural networks and Fourier series. *Energy Convers Manag* 2008;49(11):3135–42.
- [140] Maia, A.L.S., F.d.A. de Carvalho, and T.B. Ludermir. Symbolic interval time series forecasting using a hybrid model. In *Neural Networks, 2006. SBRN'06. Ninth Brazilian Symposium on*. 2006. IEEE.

- [141] Kandanand K. Forecasting electricity demand in Thailand with an artificial neural network approach. *Energies* 2011;4(8):1246–57.
- [142] Wang F, et al. Short-term solar irradiance forecasting model based on artificial neural network using statistical feature parameters. *Energies* 2012;5(5):1355–70.
- [143] Shi J, Guo J, Zheng S. Evaluation of hybrid forecasting approaches for wind speed and power generation time series. *Renew Sustain Energy Rev* 2012;16(5):3471–80.
- [144] Wang S, et al. A novel seasonal decomposition based least squares support vector regression ensemble learning approach for hydropower consumption forecasting in China. *Energy* 2011;36(11):6542–54.
- [145] Xu W, et al. Forecasting energy consumption using a new GM–ARMA model based on HP filter: the case of Guangdong Province of China. *Econ Model* 2015;45(0):127–35.
- [146] Amin-Naseri M, Soroush A. Combined use of unsupervised and supervised learning for daily peak load forecasting. *Energy Convers Manag* 2008;49(6):1302–8.
- [147] Chen SX, Gooi HB, Wang MQ. Solar radiation forecast based on fuzzy logic and neural networks. *Renew Energy* 2013;60(0):195–201.
- [148] Amjady N. Day-ahead price forecasting of electricity markets by a new fuzzy neural network. *Power Syst, IEEE Trans on* 2006;21(2):887–96.
- [149] Bazmi A, Davoody M, Zahedi G. Electricity demand estimation using an adaptive neuro-fuzzy network: a case study from the state of Johor, Malaysia. *Int J Chem Environ Eng* 2012;3(4):284–95.
- [150] Zahedi G, et al. Electricity demand estimation using an adaptive neuro-fuzzy network: a case study from the Ontario province–Canada. *Energy* 2013;49:323–8.
- [151] Esen H, et al. Artificial neural networks and adaptive neuro-fuzzy assessments for ground-coupled heat pump system. *Energy Build* 2008;40(6):1074–83.
- [152] Sfetos A, Coonick AH. Univariate and multivariate forecasting of hourly solar radiation with artificial intelligence techniques. *Sol Energy* 2000;68(2):169–78.
- [153] Akdemir B, Çetinkaya N. Long-term load forecasting based on adaptive neural fuzzy inference system using real energy data. *Energy Procedia* 2012;14:794–9.
- [154] Chen T, Wang Y-C. Long-term load forecasting by a collaborative fuzzy-neural approach. *Int J Electr Power Energy Syst* 2012;43(1):454–64.
- [155] Chen T. A collaborative fuzzy-neural approach for long-term load forecasting in Taiwan. *Comput Ind Eng* 2012;63(3):663–70.
- [156] Chang P-C, Fan C-Y, Lin J-J. Monthly electricity demand forecasting based on a weighted evolving fuzzy neural network approach. *Int J Electr Power Energy Syst* 2011;33(1):17–27.
- [157] Bakirtzis A, et al. Short term load forecasting using fuzzy neural networks. *Power Syst, IEEE Trans on* 1995;10(3):1518–24.
- [158] Srinivasan D, Chang C, Liew A. Demand forecasting using fuzzy neural computation, with special emphasis on weekend and public holiday forecasting. *Power Syst, IEEE Trans on* 1995;10(4):1897–903.
- [159] Papadakis S, et al. A novel approach to short-term load forecasting using fuzzy neural networks. *Power Syst, IEEE Trans on* 1998;13(2):480–92.
- [160] Padmakumari K, Mohandas KP, Thiruvengadam S. Long term distribution demand forecasting using neuro fuzzy computations. *Int J Electr Power Energy Syst* 1999;21(5):315–22.
- [161] El-Telbany M, El-Karmi F. Short-term forecasting of Jordanian electricity demand using particle swarm optimization. *Electr Power Syst Res* 2008;78(3):425–33.
- [162] Yu S, Wang K, Wei Y-M. A hybrid self-adaptive Particle Swarm Optimization–Genetic Algorithm–Radial Basis Function model for annual electricity demand prediction. *Energy Convers Manag* 2015;91:176–85.
- [163] Yu S-w, Zhu K-j. A hybrid procedure for energy demand forecasting in China. *Energy* 2012;37(1):396–404.
- [164] Lee Y-S, Tong L-I. Forecasting energy consumption using a grey model improved by incorporating genetic programming. *Energy Convers Manag* 2011;52(1):147–52.
- [165] Lee Y-S, Tong L-I. Forecasting nonlinear time series of energy consumption using a hybrid dynamic model. *Appl Energy* 2012;94(0):251–6.
- [166] Fan S, Chen L, Lee W-J. Machine learning based switching model for electricity load forecasting. *Energy Convers Manag* 2008;49(6):1331–44.
- [167] Hsu C-C, Chen C-Y. Applications of improved grey prediction model for power demand forecasting. *Energy Convers Manag* 2003;44(14):2241–9.
- [168] Bashir Z, El-Hawary M. Applying wavelets to short-term load forecasting using PSO-based neural networks. *Power Syst, IEEE Trans on* 2009;24(1):20–7.
- [169] Xie Y, Li M. Research on prediction model of natural gas consumption based on Grey modeling optimized by genetic algorithm [in Control, Automation and Systems Engineering, 2009. CASE 2009. IITA International Conference on]. IEEE; 2009.
- [170] Ko C-N, Lee C-M. Short-term load forecasting using SVR (support vector regression)-based radial basis function neural network with dual extended Kalman filter. *Energy* 2013;49:413–22.
- [171] Azadeh A, et al. Integration of artificial neural networks and genetic algorithm to predict electrical energy consumption. *Appl Math Comput* 2007;186(2):1731–41.
- [172] Cinar D, Kayakutlu G, Daim T. Development of future energy scenarios with intelligent algorithms: case of hydro in Turkey. *Energy* 2010;35(4):1724–9.
- [173] Shayeghi H, Shayanfar H, Azimi G. Intelligent neural network based STLF. *Int J Comput Syst Sci Eng* 2009;4:1.
- [174] Cao Z, Yuan P, Ma Y. Energy Demand Forecasting Based on Economy-related Factors in China. *Energy Sources, Part B: Econ, Plan, Policy* 2014;9(2):214–9.
- [175] Nguyen HT, Nabney IT. Short-term electricity demand and gas price forecasts using wavelet transforms and adaptive models. *Energy* 2010;35(9):3674–85.
- [176] Mohandes M, Rehman S, Halawani TO. Estimation of global solar radiation using artificial neural networks. *Renew Energy* 1998;14(1–4):179–84.
- [177] Mandal P, Senjyu T, Funabashi T. Neural networks approach to forecast several hour ahead electricity prices and loads in deregulated market. *Energy Convers Manag* 2006;47(15):2128–42.
- [178] Hill T, et al. Artificial neural network models for forecasting and decision making. *Int J Forecast* 1994;10(1):5–15.
- [179] Paliwal M, Kumar UA. Neural networks and statistical techniques: a review of applications. *Expert Syst Appl* 2009;36(1):2–17.
- [180] Srinivasan D. Energy demand prediction using GMDH networks. *Neurocomputing* 2008;72(1–3):625–9.
- [181] Zhao H-x, Magoules F. A review on the prediction of building energy consumption. *Renew Sustain Energy Rev* 2012;16(6):3586–92.
- [182] DominikSlezak SOK, Mirkin DHHBG. Rough sets, fuzzy sets, data mining and granular computing; 2011.
- [183] Shen X, et al. The Application of the Grey Disaster Model to Forecast Epidemic Peaks of Typhoid and Paratyphoid Fever in China. *PLoS ONE* 2013;8(4):e60601.
- [184] Li D-C, et al. Forecasting short-term electricity consumption using the adaptive grey-based approach—An Asian case. *Omega* 2012;40(6):767–73.
- [185] Moewes C, Nürnberger A. Computational Intelligence in Intelligent Data Analysis. Springer; 2013.
- [186] Devison UNS. Composition of macro geographical (continental) regions, geographical sub-regions, and selected economic and other groupings. United Nations; 2013.
- [187] Bianco V, Manca O, Nardini S. Electricity consumption forecasting in Italy using linear regression models. *Energy* 2009;34(9):1413–21.
- [188] Bianco V, Manca O, Nardini S. Linear regression models to forecast electricity consumption in Italy. *Energy Sources, Part B: Econ, Plan, Policy* 2013;8(1):86–93.
- [189] Rentziou A, Gkritza K, Souleyrette RR. VMT, energy consumption, and GHG emissions forecasting for passenger transportation. *Transp Res Part A: Policy Pract* 2012;46(3):487–500.
- [190] Mohamed Z, Bodger P. Forecasting electricity consumption in New Zealand using economic and demographic variables. *Energy* 2005;30(10):1833–43.
- [191] Pao H-T. Comparing linear and nonlinear forecasts for Taiwan's electricity consumption. *Energy* 2006;31(12):2129–41.
- [192] Papalexopoulos AD, Hesterberg TC. A regression-based approach to short-term system load forecasting. *Power Syst, IEEE Trans on* 1990;5(4):1535–47.
- [193] Melikoglu M. Vision 2023: forecasting Turkey's natural gas demand between 2013 and 2030. *Renew Sustain Energy Rev* 2013;22(0):393–400.
- [194] Bolton R. Regional Econometric Models*. *J Reg Sci* 1985;25(4):495–520.
- [195] Sharma DP, Chandramohan Nair PS, Balasubramanian R. Demand for commercial energy in the state of Kerala, India: an econometric analysis with medium-range projections. *Energy Policy* 2002;30(9):781–91.
- [196] Gori F, Ludovisi D, Cerritelli PF. Forecast of oil price and consumption in the short term under three scenarios: parabolic, linear and chaotic behaviour. *Energy* 2007;32(7):1291–6.
- [197] Haida T, Muto S. Regression based peak load forecasting using a transformation technique. *Power Syst, IEEE Trans on* 1994;9(4):1788–94.
- [198] Yumurtaci Z, Asmaz E. Electric energy demand of Turkey for the year 2050. *Energy Sources* 2004;26(12):1157–64.
- [199] Arsenaault E, et al. A total energy demand model of Québec: forecasting properties. *Energy Econ* 1995;17(2):163–71.
- [200] Köne AÇ, Büke T. Forecasting of CO₂ emissions from fuel combustion using trend analysis. *Renew Sustain Energy Rev* 2010;14(9):2906–15.
- [201] ZhiDong L. An econometric study on China's economy, energy and environment to the year 2030. *Energy Policy* 2003;31(11):1137–50.
- [202] Egelioglu F, Mohamad AA, Guven H. Economic variables and electricity consumption in Northern Cyprus. *Energy* 2001;26(4):355–62.
- [203] Bianco V, Scarpa F, Tagliafico LA. Scenario analysis of nonresidential natural gas consumption in Italy. *Appl Energy* 2014;113:392–403.
- [204] Chi KC, Nuttall WJ, Reiner DM. Dynamics of the UK natural gas industry: system dynamics modelling and long-term energy policy analysis. *Technol Forecast Social Change* 2009;76(3):339–57.
- [205] Kankal M, et al. Modeling and forecasting of Turkey's energy consumption using socio-economic and demographic variables. *Appl Energy* 2011;88(5):1927–39.
- [206] Elattar EE, Goulermas J, Wu QH. Electric load forecasting based on locally weighted support vector regression. *Syst, Man, Cybern, Part C: Appl Rev, IEEE Trans on* 2010;40(4):438–47.
- [207] Ramsami P, Oree V. A hybrid method for forecasting the energy output of photovoltaic systems. *Energy Convers Manag* 2015;95:406–13.
- [208] De Felice M, Alessandri A, Catalano F. Seasonal climate forecasts for medium-term electricity demand forecasting. *Appl Energy* 2015;137:435–44.
- [209] Baldacci L, et al. Natural gas consumption forecasting for anomaly detection. *Expert Syst Appl* 2016;62:190–201.
- [210] Khan MA. Modelling and forecasting the demand for natural gas in Pakistan. *Renew Sustain Energy Rev* 2015;49(Supplement C):1145–59.
- [211] Zhang W, Yang J. Forecasting natural gas consumption in China by Bayesian Model Averaging. *Energy Rep* 2015;1:216–20.
- [212] Mohamed Z, Bodger P. A comparison of Logistic and Harvey models for electricity consumption in New Zealand. *Technol Forecast Social Change* 2005;72(8):1030–43.
- [213] Gutiérrez R, Nafidi A, Sánchez R Gutiérrez. Forecasting total natural-gas consumption in Spain by using the stochastic Gompertz innovation diffusion model. *Appl Energy* 2005;80(2):115–24.
- [214] Siemek J, Nagy S, Rychlicki S. Estimation of natural-gas consumption in Poland based on the logistic-curve interpretation. *Appl Energy* 2003;75(1–2):1–7.
- [215] Bodger PS, Tay HS. Logistic and energy substitution models for electricity forecasting: a comparison using New Zealand consumption data. *Technol Forecast Social Change* 1987;31(1):27–48.
- [216] Purohit P, Kandpal TC. Renewable energy technologies for irrigation water

- pumping in India: projected levels of dissemination, energy delivery and investment requirements using available diffusion models. *Renew Sustain Energy Rev* 2005;9(6):592–607.
- [217] Carolin Mabel M, Fernandez E. Growth and future trends of wind energy in India. *Renew Sustain Energy Rev* 2008;12(6):1745–57.
- [218] Bessec M, Fouquau J. The non-linear link between electricity consumption and temperature in Europe: a threshold panel approach. *Energy Econ* 2008;30(5):2705–21.
- [219] Meng M, Niu D. Modeling CO₂ emissions from fossil fuel combustion using the logistic equation. *Energy* 2011;36(5):3355–9.
- [220] Nel WP, Cooper CJ. A critical review of IEA's oil demand forecast for China. *Energy Policy* 2008;36(3):1096–106.
- [221] Skiadas CH, Papayannakis LL, Mourelatos AG. An attempt to improve the forecasting ability of growth functions: the Greek electric system. *Technol Forecast Social Change* 1993;44(4):391–404.
- [222] McNeil MA, Letschert VE. Forecasting electricity demand in developing countries: a study of household income and appliance ownership [LBNL-58283]. Mandelieu, France: European Council for an Energy Efficient Economy-2005 Summer Study; 2005.
- [223] Daim T, Harell G, Hogaboam L. Forecasting renewable energy production in the US. *Foresight* 2012;14(3):225–41.
- [224] Debnath KB, Mourshed M, Chew SPK. Modelling and Forecasting Energy Demand in Rural Households of Bangladesh. *Energy Procedia* 2015;75:2731–7.
- [225] Bianco V, Scarpa F, Tagliafico LA. Analysis and future outlook of natural gas consumption in the Italian residential sector. *Energy Convers Manag* 2014;87:754–64.
- [226] Shaikh F, Ji Q. Forecasting natural gas demand in China: logistic modelling analysis. *Int J Electr Power Energy Syst* 2016;77:25–32.
- [227] Soldo B, et al. Improving the residential natural gas consumption forecasting models by using solar radiation. *Energy Build* 2014;69:498–506.
- [228] Potočník P, et al. Comparison of static and adaptive models for short-term residential natural gas forecasting in Croatia. *Appl Energy* 2014;129:94–103.
- [229] Contreras J, et al. ARIMA models to predict next-day electricity prices. *Power Syst, IEEE Trans on* 2003;18(3):1014–20.
- [230] Pao H-T, Tsai C-M. Modeling and forecasting the CO₂ emissions, energy consumption, and economic growth in Brazil. *Energy* 2011;36(5):2450–8.
- [231] Gonzalez-Romera E, Jaramillo-Moran MA, Carmona-Fernandez D. Monthly electric energy demand forecasting based on trend extraction. *Power Syst, IEEE Trans on* 2006;21(4):1946–53.
- [232] Ierapetritou M, et al. Cost minimization in an energy-intensive plant using mathematical programming approaches. *Ind Eng Chem Res* 2002;41(21):5262–77.
- [233] Erdogan E. Natural gas demand in Turkey. *Appl Energy* 2010;87(1):211–9.
- [234] Abdel-Aal RE, Al-Garni AZ. Forecasting monthly electric energy consumption in eastern Saudi Arabia using univariate time-series analysis. *Energy* 1997;22(11):1059–69.
- [235] Gonzales Chavez S, Xiberta Bernat J, Coalla H Llaneza. Forecasting of energy production and consumption in Asturias (northern Spain). *Energy* 1999;24(3):183–98.
- [236] Saab S, Badr E, Nasr G. Univariate modeling and forecasting of energy consumption: the case of electricity in Lebanon. *Energy* 2001;26(1):1–14.
- [237] Hagan MT, Behr SM. The time series approach to short term load forecasting. *Power Syst, IEEE Trans on* 1987;2(3):785–91.
- [238] Amjadi N. Short-term hourly load forecasting using time-series modeling with peak load estimation capability. *Power Syst, IEEE Trans on* 2001;16(3):498–505.
- [239] Harris JL, Liu L-M. Dynamic structural analysis and forecasting of residential electricity consumption. *Int J Forecast* 1993;9(4):437–55.
- [240] Erdogan E. Electricity demand analysis using cointegration and ARIMA modelling: a case study of Turkey. *Energy Policy* 2007;35(2):1129–46.
- [241] Cho M, Hwang J, Chen C. Customer short term load forecasting by using ARIMA transfer function model [in *Energy Management and Power Delivery*, 1995. Proceedings of EMPD'95., 1995 International Conference on]. IEEE; 1995.
- [242] Conejo AJ, et al. Day-ahead electricity price forecasting using the wavelet transform and ARIMA models. *Power Syst, IEEE Trans on* 2005;20(2):1035–42.
- [243] Reikard G. Predicting solar radiation at high resolutions: a comparison of time series forecasts. *Sol Energy* 2009;83(3):342–9.
- [244] Kavasseri RG, Seetharaman K. Day-ahead wind speed forecasting using f-ARIMA models. *Renew Energy* 2009;34(5):1388–93.
- [245] Liu L-M, Lin M-W. Forecasting residential consumption of natural gas using monthly and quarterly time series. *Int J Forecast* 1991;7(1):3–16.
- [246] Cadenas E, Jaramillo OA, Rivera W. Analysis and forecasting of wind velocity in chetumal, quintana roo, using the single exponential smoothing method. *Renew Energy* 2010;35(5):925–30.
- [247] Azadeh A, Tarverdian S. Integration of genetic algorithm, computer simulation and design of experiments for forecasting electrical energy consumption. *Energy Policy* 2007;35(10):5229–41.
- [248] Zhou P, Ang BW, Poh KL. A trigonometric grey prediction approach to forecasting electricity demand. *Energy* 2006;31(14):2839–47.
- [249] Wang J, Hu J. A robust combination approach for short-term wind speed forecasting and analysis – Combination of the ARIMA (Autoregressive integrated moving average), ELM (extreme learning machine), SVM (support vector machine) and LSSVM (least square SVM) forecasts using a GPR (Gaussian process regression) model. *Energy* 2015;93:41–56.
- [250] Nobre AM, et al. PV power conversion and short-term forecasting in a tropical, densely-built environment in Singapore. *Renew Energy* 2016;94:496–509.
- [251] Wang J, et al. A novel model: dynamic choice artificial neural network (DCANN) for an electricity price forecasting system. *Appl Soft Comput* 2016;48:281–97.
- [252] Bracale A, Falco P De. An Advanced Bayesian Method for Short-Term Probabilistic Forecasting of the Generation of Wind Power. *Energies* 2015;8(9):10293–314.
- [253] Barak S, Sadegh SS. Forecasting energy consumption using ensemble ARIMA–ANFIS hybrid algorithm. *Int J Electr Power Energy Syst* 2016;82:92–104.
- [254] Sen P, Roy M, Pal P. Application of ARIMA for forecasting energy consumption and GHG emission: a case study of an Indian pig iron manufacturing organization. *Energy* 2016;116:1031–8.
- [255] Yang Y, et al. Modelling a combined method based on ANFIS and neural network improved by DE algorithm: a case study for short-term electricity demand forecasting. *Appl Soft Comput* 2016;49:663–75.
- [256] Arciniegas AI, Rueda IEA. Forecasting short-term power prices in the Ontario Electricity Market (OEM) with a fuzzy logic based inference system. *Uti Policy* 2008;16(1):39–48.
- [257] Yan X, Chowdhury NA. Mid-term electricity market clearing price forecasting: a hybrid LSSVM and ARMAX approach. *Int J Electr Power Energy Syst* 2013;53:20–6.
- [258] Yan X, Chowdhury NA. Mid-term electricity market clearing price forecasting utilizing hybrid support vector machine and auto-regressive moving average with external input. *Int J Electr Power Energy Syst* 2014;63:64–70.
- [259] Nowicka-Zagrajek J, Weron R. Modeling electricity loads in California: arma models with hyperbolic noise. *Signal Process* 2002;82(12):1903–15.
- [260] Pappas SS, et al. Electricity demand loads modeling using AutoRegressive Moving Average (ARMA) models. *Energy* 2008;33(9):1353–60.
- [261] Fan J, McDonald J. A real-time implementation of short-term load forecasting for distribution power systems. *Power Syst, IEEE Trans on* 1994;9(2):988–94.
- [262] Al-Shobaki S, Mohsen M. Modeling and forecasting of electrical power demands for capacity planning. *Energy Convers Manag* 2008;49(11):3367–75.
- [263] Topalli AK, Erkmen I, Topalli I. Intelligent short-term load forecasting in Turkey. *Int J Electr Power Energy Syst* 2006;28(7):437–47.
- [264] Torres JL, et al. Forecast of hourly average wind speed with ARMA models in Navarre (Spain). *Sol Energy* 2005;79(1):65–77.
- [265] Pappas SS, et al. Electricity demand load forecasting of the Hellenic power system using an ARMA model. *Electr Power Syst Res* 2010;80(3):256–64.
- [266] Taylor JW. Triple seasonal methods for short-term electricity demand forecasting. *Eur J Oper Res* 2010;204(1):139–52.
- [267] Crespo Cuaresma J, et al. Forecasting electricity spot-prices using linear univariate time-series models. *Appl Energy* 2004;77(1):87–106.
- [268] Chu Y, et al. Short-term reforecasting of power output from a 48 MWe solar PV plant. *Sol Energy* 2015;112:68–77.
- [269] Yang Z, Ce L, Lian L. Electricity price forecasting by a hybrid model, combining wavelet transform, ARMA and kernel-based extreme learning machine methods. *Appl Energy* 2017;190:291–305.
- [270] Kavousi-Fard A, Samet H, Marzbani F. A new hybrid Modified Firefly Algorithm and Support Vector Regression model for accurate Short Term Load Forecasting. *Expert Syst Appl* 2014;41(13):6047–56.
- [271] Zhu L, et al. Short-term natural gas demand prediction based on support vector regression with false neighbours filtered. *Energy* 2015;80:428–36.
- [272] McAviney ID, Yannopoulos A. Stationarity, structural change and specification in a demand system: the case of energy. *Energy Econ* 2003;25(1):65–92.
- [273] Ghosh S. Future demand of petroleum products in India. *Energy Policy* 2006;34(15):2032–7.
- [274] Sari R, Soytaş U. Disaggregate energy consumption, employment and income in Turkey. *Energy Econ* 2004;26(3):335–44.
- [275] Lee C-C, Chien M-S. Dynamic modelling of energy consumption, capital stock, and real income in G-7 countries. *Energy Econ* 2010;32(3):564–81.
- [276] Kulshreshtha M, Parikh JK. Modeling demand for coal in India: vector autoregressive models with cointegrated variables. *Energy* 2000;25(2):149–68.
- [277] Abosedra S, Dah A, Ghosh S. Electricity consumption and economic growth, the case of Lebanon. *Appl Energy* 2009;86(4):429–32.
- [278] Narayan PK, Prasad A. Electricity consumption–real GDP causality nexus: evidence from a bootstrapped causality test for 30 OECD countries. *Energy Policy* 2008;36(2):910–8.
- [279] Inglesi R. Aggregate electricity demand in South Africa: conditional forecasts to 2030. *Appl Energy* 2010;87(1):197–204.
- [280] García-Ascanio C, Maté C. Electric power demand forecasting using interval time series: a comparison between VAR and iMLP. *Energy Policy* 2010;38(2):715–25.
- [281] Athukorala PPAW, Wilson C. Estimating short and long-term residential demand for electricity: new evidence from Sri Lanka. *Energy Econ* 2010;32(Supplement 1(0)):S34–40.
- [282] Baumeister C, Kilian L. Forecasting the real price of oil in a Changing world: a forecast combination approach. *J Bus Econ Stat* 2015;33(3):338–51.
- [283] Amarawickrama HA, Hunt LC. Electricity demand for Sri Lanka: a time series analysis. *Energy* 2008;33(5):724–39.
- [284] Wei Y, Wang Y, Huang D. Forecasting crude oil market volatility: further evidence using GARCH-class models. *Energy Econ* 2010;32(6):1477–84.
- [285] Garcia RC, et al. A GARCH forecasting model to predict day-ahead electricity prices. *Power Syst, IEEE Trans on* 2005;20(2):867–74.
- [286] Kang SH, Kang S-M, Yoon S-M. Forecasting volatility of crude oil markets. *Energy Econ* 2009;31(1):119–25.
- [287] Sadosky P. Modeling and forecasting petroleum futures volatility. *Energy Econ* 2006;28(4):467–88.
- [288] Diongue AK, Guéan D, Vignal B. Forecasting electricity spot market prices with a k-factor GIGARCH process. *Appl Energy* 2009;86(4):505–10.
- [289] Li M-J, He Y-L, Tao W-Q. Modeling a hybrid methodology for evaluating and forecasting regional energy efficiency in China. *Appl Energy* 2017;185:1769–77.
- [290] Zhang J-L, Zhang Y-J, Zhang L. A novel hybrid method for crude oil price

- forecasting. *Energy Econ* 2015;49:649–59.
- [291] Al-Ghandoor A, et al. Electricity consumption and associated GHG emissions of the Jordanian industrial sector: empirical analysis and future projection. *Energy Policy* 2008;36(1):258–67.
- [292] Al-Ghandoor A, et al. Residential past and future energy consumption: potential savings and environmental impact. *Renew Sustain Energy Rev* 2009;13(6–7):1262–74.
- [293] Azadeh A, Ghaderi SF, Sohrabkhani S. Annual electricity consumption forecasting by neural network in high energy consuming industrial sectors. *Energy Convers Manag* 2008;49(8):2272–8.
- [294] Trejo-Perea M, et al. Greenhouse energy consumption prediction using neural networks models. *Training* 2009;1(1):2.
- [295] Pao H-T, Tsai C-M. Multivariate Granger causality between CO₂ emissions, energy consumption, FDI (foreign direct investment) and GDP (gross domestic product): evidence from a panel of BRIC (Brazil, Russian Federation, India, and China) countries. *Energy* 2011;36(1):685–93.
- [296] Kwakwa PA. Disaggregated energy consumption and economic growth in Ghana. *Int J Energy Econ Policy* 2012;2(1):34–40.
- [297] Narayan PK, Smyth R. A panel cointegration analysis of the demand for oil in the Middle East. *Energy Policy* 2007;35(12):6258–65.
- [298] Narayan PK, Smyth R, Prasad A. Electricity consumption in G7 countries: a panel cointegration analysis of residential demand elasticities. *Energy Policy* 2007;35(9):4485–94.
- [299] Smith C, Hall S, Mabey N. Econometric modelling of international carbon tax regimes. *Energy Econ* 1995;17(2):133–46.
- [300] Masih AMM, Masih R. Energy consumption, real income and temporal causality: results from a multi-country study based on cointegration and error-correction modelling techniques. *Energy Econ* 1996;18(3):165–83.
- [301] Fouquet R, et al. The future of UK final user energy demand. *Energy Policy* 1997;25(2):231–40.
- [302] Glasure YU. Energy and national income in Korea: further evidence on the role of omitted variables. *Energy Econ* 2002;24(4):355–65.
- [303] Hondroyannis G, Lolos S, Papapetrou E. Energy consumption and economic growth: assessing the evidence from Greece. *Energy Econ* 2002;24(4):319–36.
- [304] Galindo LM. Short-and long-run demand for energy in Mexico: a cointegration approach. *Energy Policy* 2005;33(9):1179–85.
- [305] Lee C-C, Chang C-P. Structural breaks, energy consumption, and economic growth revisited: evidence from Taiwan. *Energy Econ* 2005;27(6):857–72.
- [306] Al-Iriani MA. Energy–GDP relationship revisited: an example from GCC countries using panel causality. *Energy Policy* 2006;34(17):3342–50.
- [307] Chen P-F, Lee C-C. Is energy consumption per capita broken stationary? New evidence from regional-based panels. *Energy Policy* 2007;35(6):3526–40.
- [308] Lise W, Montfort K Van. Energy consumption and GDP in Turkey: is there a co-integration relationship? *Energy Econ* 2007;29(6):1166–78.
- [309] Zhao X, Wu Y. Determinants of China's energy imports: an empirical analysis. *Energy Policy* 2007;35(8):4235–46.
- [310] Feng T, Sun L, Zhang Y. The relationship between energy consumption structure, economic structure and energy intensity in China. *Energy Policy* 2009;37(12):5475–83.
- [311] Sadorsky P. Renewable energy consumption, CO₂ emissions and oil prices in the G7 countries. *Energy Econ* 2009;31(3):456–62.
- [312] Sadorsky P. Renewable energy consumption and income in emerging economies. *Energy Policy* 2009;37(10):4021–8.
- [313] Narayan PK, Narayan S, Popp S. Energy consumption at the state level: the unit root null hypothesis from Australia. *Appl Energy* 2010;87(6):1953–62.
- [314] Apergis N, Payne JE. The emissions, energy consumption, and growth nexus: evidence from the commonwealth of independent states. *Energy Policy* 2010;38(1):650–5.
- [315] Sadorsky P. Trade and energy consumption in the Middle East. *Energy Econ* 2011;33(5):739–49.
- [316] Hatzigeorgiou E, Polatidis H, Haralambopoulos D. CO₂ emissions, GDP and energy intensity: a multivariate cointegration and causality analysis for Greece, 1977–2007. *Appl Energy* 2011;88(4):1377–85.
- [317] Masih R, Masih AM. Stock-Watson dynamic OLS (DOLS) and error-correction modelling approaches to estimating long-and short-run elasticities in a demand function: new evidence and methodological implications from an application to the demand for coal in mainland China. *Energy Econ* 1996;18(4):315–34.
- [318] Lin Chan H, Lee S Kam. Modelling and forecasting the demand for coal in China. *Energy Econ* 1997;19(3):271–87.
- [319] Eltony MN, Al-Mutairi NH. Demand for gasoline in Kuwait: an empirical analysis using cointegration techniques. *Energy Econ* 1995;17(3):249–53.
- [320] Ramanathan R. Short-and long-run elasticities of gasoline demand in India: an empirical analysis using cointegration techniques. *Energy Econ* 1999;21(4):321–30.
- [321] Alves DCO, De Lasso da Silveira Bueno R. Short-run, long-run and cross elasticities of gasoline demand in Brazil. *Energy Econ* 2003;25(2):191–9.
- [322] Akinboade OA, Ziramba E, Kumo WL. The demand for gasoline in South Africa: an empirical analysis using co-integration techniques. *Energy Econ* 2008;30(6):3222–9.
- [323] Park SY, Zhao G. An estimation of U.S. gasoline demand: a smooth time-varying cointegration approach. *Energy Econ* 2010;32(1):110–20.
- [324] Zou G, Chau KW. Short- and long-run effects between oil consumption and economic growth in China. *Energy Policy* 2006;34(18):3644–55.
- [325] Ziramba E. Price and income elasticities of crude oil import demand in South Africa: a cointegration analysis. *Energy Policy* 2010;38(12):7844–9.
- [326] Gallo A, et al. What is behind the increase in oil prices? Analyzing oil consumption and supply relationship with oil price. *Energy* 2010;35(10):4126–41.
- [327] Silk JI, Joutz FL. Short and long-run elasticities in US residential electricity demand: a co-integration approach. *Energy Econ* 1997;19(4):493–513.
- [328] Narayan PK, Smyth R. Electricity consumption, employment and real income in Australia evidence from multivariate Granger causality tests. *Energy Policy* 2005;33(9):1109–16.
- [329] Zachariadis T, Pashourtidou N. An empirical analysis of electricity consumption in Cyprus. *Energy Econ* 2007;29(2):183–98.
- [330] Yuan J, et al. Electricity consumption and economic growth in China: cointegration and co-feature analysis. *Energy Econ* 2007;29(6):1179–91.
- [331] Odhiambo NM. Electricity consumption and economic growth in South Africa: a trivariate causality test. *Energy Econ* 2009;31(5):635–40.
- [332] Yoo S-H, Kwak S-Y. Electricity consumption and economic growth in seven South American countries. *Energy Policy* 2010;38(1):181–8.
- [333] Lim K-M, Lim S-Y, Yoo S-H. Short-and long-run elasticities of electricity demand in the Korean service sector. *Energy Policy* 2014;67:517–21.
- [334] Sánchez-Úbeda EF, Berzosa A. Modeling and forecasting industrial end-use natural gas consumption. *Energy Econ* 2007;29(4):710–42.
- [335] Ang B. Decomposition methodology in industrial energy demand analysis. *Energy* 1995;20(11):1081–95.
- [336] Ang BW. Multilevel decomposition of industrial energy consumption. *Energy Econ* 1995;17(1):39–51.
- [337] Ang BW, Zhang FQ. A survey of index decomposition analysis in energy and environmental studies. *Energy* 2000;25(12):1149–76.
- [338] Ang BW, Lee PW. Decomposition of industrial energy consumption: the energy coefficient approach. *Energy Econ* 1996;18(1–2):129–43.
- [339] Sun JW. Energy demand in the fifteen European Union countries by 2010 —: a forecasting model based on the decomposition approach. *Energy* 2001;26(6):549–60.
- [340] Tao Z. Scenarios of China's oil consumption per capita (OCP) using a hybrid Factor Decomposition–System Dynamics (SD) simulation. *Energy* 2010;35(1):168–80.
- [341] Afshar K, Bigdeli N. Data analysis and short term load forecasting in Iran electricity market using singular spectral analysis (SSA). *Energy* 2011;36(5):2620–7.
- [342] He YX, et al. Energy-saving decomposition and power consumption forecast: the case of liaoning province in China. *Energy Convers Manag* 2011;52(1):340–8.
- [343] Kawase R, Matsuoka Y, Fujino J. Decomposition analysis of CO₂ emission in long-term climate stabilization scenarios. *Energy Policy* 2006;34(15):2113–22.
- [344] An N, et al. Using multi-output feedforward neural network with empirical mode decomposition based signal filtering for electricity demand forecasting. *Energy* 2013;49:279–88.
- [345] Xiong T, Bao Y, Hu Z. Interval forecasting of electricity demand: a novel bivariate EMD-based support vector regression modeling framework. *Int J Electr Power Energy Syst* 2014;63:353–62.
- [346] Wang D, et al. Multi-step ahead electricity price forecasting using a hybrid model based on two-layer decomposition technique and BP neural network optimized by firefly algorithm. *Appl Energy* 2017;190:390–407.
- [347] Kavaklioglu K. Modeling and prediction of Turkey's electricity consumption using Support Vector Regression. *Appl Energy* 2011;88(1):368–75.
- [348] Wang J, et al. A trend fixed on firstly and seasonal adjustment model combined with the ϵ -SVR for short-term forecasting of electricity demand. *Energy Policy* 2009;37(11):4901–9.
- [349] Mohandes MA, et al. Support vector machines for wind speed prediction. *Renew Energy* 2004;29(6):939–47.
- [350] Niu D-x, et al. Mid-term load forecasting based on dynamic least squares SVMs [in Machine Learning and Cybernetics, 2008 International Conference on]. IEEE; 2008.
- [351] Hong W-C, et al. Cyclic electric load forecasting by seasonal SVR with chaotic genetic algorithm. *Int J Electr Power Energy Syst* 2013;44(1):604–14.
- [352] Patil MSB, Patil MBK. Support Vector Machine for Wind Speed Prediction; 2015.
- [353] Ji G-R, Han P, Zhai Y-J. Wind speed forecasting based on support vector machine with forecasting error estimation [in Machine Learning and Cybernetics, 2007 International Conference on]. IEEE; 2007.
- [354] Küçükdenez T. Long term electricity demand Forecasting: an alternative approach With support vector machines. *İÜ Mühendislik Bilim Derg* 2010;1(1):45–54.
- [355] Chen B-J, Chang M-W. Load forecasting using support vector machines: a study on EUNITE competition 2001. *IEEE Trans Power Syst* 2004;19(4):1821–30.
- [356] Wu H, Chang X. Power load forecasting with least squares support vector machines and chaos theory [in 2006 6th World Congress on Intelligent Control and Automation]. IEEE; 2006.
- [357] Ying L-C, Pan M-C. Using adaptive network based fuzzy inference system to forecast regional electricity loads. *Energy Convers Manag* 2008;49(2):205–11.
- [358] Wang F, et al. Solar irradiance feature extraction and support vector machines based weather status pattern recognition model for short-term photovoltaic power forecasting. *Energy Build* 2015;86:427–38.
- [359] Hu J, Wang J, Ma K. A hybrid technique for short-term wind speed prediction. *Energy* 2015;81:563–74.
- [360] Rana M, Koprinska I, Agelidis VG. Univariate and multivariate methods for very short-term solar photovoltaic power forecasting. *Energy Convers Manag* 2016;121:380–90.
- [361] Lauret P, et al. A benchmarking of machine learning techniques for solar radiation forecasting in an insular context. *Sol Energy* 2015;112:446–57.
- [362] Feijoo F, Silva W, Das TK. A computationally efficient electricity price forecasting model for real time energy markets. *Energy Convers Manag* 2016;113:27–35.
- [363] Hu Z, et al. Hybrid filter-wrapper feature selection for short-term load forecasting. *Eng Appl Artif Intell* 2015;40:17–27.

- [364] Hu Z, Bao Y, Xiong T. Comprehensive learning particle swarm optimization based memetic algorithm for model selection in short-term load forecasting using support vector regression. *Appl Soft Comput* 2014;25:15–25.
- [365] Cecati C, et al. A Novel RBF Training Algorithm for Short-Term Electric Load Forecasting and Comparative Studies. *IEEE Trans Ind Electron* 2015;62(10):6519–29.
- [366] Yan X, Chowdhury NA. Mid-term electricity market clearing price forecasting: a multiple SVM approach. *Int J Electr Power Energy Syst* 2014;58:206–14.
- [367] Abdoos A, Hemmati M, Abdoos AA. Short term load forecasting using a hybrid intelligent method. *Knowl-Based Syst* 2015;76:139–47.
- [368] Chen Y, et al. A hybrid application algorithm based on the support vector machine and artificial intelligence: an example of electric load forecasting. *Appl Math Model* 2015;39(9):2617–32.
- [369] Bai Y, Li C. Daily natural gas consumption forecasting based on a structure-calibrated support vector regression approach. *Energy Build* 2016;127:571–9.
- [370] Deo RC, Wen X, Qi F. A wavelet-coupled support vector machine model for forecasting global incident solar radiation using limited meteorological dataset. *Appl Energy* 2016;168:568–93.
- [371] Ibarra-Berastegi G, et al. Short-term forecasting of the wave energy flux: analogues, random forests, and physics-based models. *Ocean Eng* 2015;104:530–9.
- [372] Lahouar A, Slama J Ben Hadj. Day-ahead load forecast using random forest and expert input selection. *Energy Convers Manag* 2015;103:1040–51.
- [373] Khashei M, Bijari M. An artificial neural network (p, \hat{A} , d, \hat{A} , q) model for time-series forecasting. *Expert Syst Appl* 2010;37(1):479–89.
- [374] Sun M, et al. Energy resources demand-supply system analysis and empirical research based on non-linear approach. *Energy* 2011;36(9):5460–5.
- [375] Hsu C-C, Chen C-Y. Regional load forecasting in Taiwan—applications of artificial neural networks. *Energy Convers Manag* 2003;44(12):1941–9.
- [376] Chakraborty S, Simoes MG. PV-microgrid operational cost minimization by neural forecasting and heuristic optimization [in Industry Applications Society Annual Meeting, 2008. IAS'08. IEEE]. IEEE; 2008.
- [377] Al-Saba T, El-Amin I. Artificial neural networks as applied to long-term demand forecasting. *Artif Intell Eng* 1999;13(2):189–97.
- [378] Es HA, Kalender FY, Hamzacebi C. Forecasting The net energy demand Of Turkey By artificial neural networks. *J Fac Eng Archit Univ* 2014;29(3):495–504.
- [379] Hamzacebi C. Forecasting of Turkey's net electricity energy consumption on sectoral bases. *Energy Policy* 2007;35(3):2009–16.
- [380] Sözen A, Arcaklioglu E, Özkaymak M. Turkey's net energy consumption. *Appl Energy* 2005;81(2):209–21.
- [381] Sözen A. Future projection of the energy dependency of Turkey using artificial neural network. *Energy Policy* 2009;37(11):4827–33.
- [382] Sözen A, Arcaklioglu E. Prediction of net energy consumption based on economic indicators (GNP and GDP) in Turkey. *Energy Policy* 2007;35(10):4981–92.
- [383] Murat YS, Ceylan H. Use of artificial neural networks for transport energy demand modeling. *Energy Policy* 2006;34(17):3165–72.
- [384] Liu X, Ang B, Goh T. Forecasting of electricity consumption: a comparison between an econometric model and a neural network model [in Neural Networks, 1991. 1991 IEEE International Joint Conference on]. IEEE; 1991.
- [385] Aydinalp M, Ismet Ugursal V, Fung AS. Modeling of the appliance, lighting, and space-cooling energy consumptions in the residential sector using neural networks. *Appl Energy* 2002;71(2):87–110.
- [386] Ermis K, et al. Artificial neural network analysis of world green energy use. *Energy Policy* 2007;35(3):1731–43.
- [387] Sözen A, Gülseven Z, Arcaklioglu E. Forecasting based on sectoral energy consumption of GHGs in Turkey and mitigation policies. *Energy Policy* 2007;35(12):6491–505.
- [388] Geem ZW, Roper WE. Energy demand estimation of South Korea using artificial neural network. *Energy Policy* 2009;37(10):4049–54.
- [389] Geem ZW. Transport energy demand modeling of South Korea using artificial neural network. *Energy Policy* 2011;39(8):4644–50.
- [390] Xue Y, Cao Z, Xu L. The Application of Combination Forecasting Model in Energy Consumption System. *Energy Procedia* 2011;5(0):2599–603.
- [391] Hsu Y-Y, Yang C-C. Design of artificial neural networks for short-term load forecasting. Part 1: self-organising feature maps for day type identification [in IEE Proceedings C (Generation, Transmission and Distribution). IET; 1991.
- [392] Park DC, et al. Electric load forecasting using an artificial neural network. *Power Syst, IEEE Trans on* 1991;6(2):442–9.
- [393] Lee K, Cha Y, Park J. Short-term load forecasting using an artificial neural network. *Power Syst, IEEE Trans on* 1992;7(1):124–32.
- [394] Peng T, Hubele N, Karady G. Advancement in the application of neural networks for short-term load forecasting. *Power Syst, IEEE Trans on* 1992;7(1):250–7.
- [395] Chen S-T, Yu DC, Moghaddamjo AR. Weather sensitive short-term load forecasting using nonfully connected artificial neural network. *Power Syst, IEEE Trans on* 1992;7(3):1098–105.
- [396] Lu C, Wu H-T, Vemuri S. Neural network based short term load forecasting. *Power Syst, IEEE Trans on* 1993;8(1):336–42.
- [397] Papalexopoulos AD, Hao S, Peng T-M. An implementation of a neural network based load forecasting model for the EMS. *Power Syst, IEEE Trans on* 1994;9(4):1956–62.
- [398] Sforina M, Proverbio F. A neural network operator oriented short-term and online load forecasting environment. *Electr Power Syst Res* 1995;33(2):139–49.
- [399] Mohammed O, et al. Practical experiences with an adaptive neural network short-term load forecasting system. *Power Syst, IEEE Trans on* 1995;10(1):254–65.
- [400] Khotanzad A, et al. An adaptive modular artificial neural network hourly load forecaster and its implementation at electric utilities. *Power Syst, IEEE Trans on* 1995;10(3):1716–22.
- [401] Khotanzad A, et al. An artificial neural network hourly temperature forecaster with applications in load forecasting. *Power Syst, IEEE Trans on* 1996;11(2):870–6.
- [402] Bakirtzis AG, et al. A neural network short term load forecasting model for the Greek power system. *Power Syst, IEEE Trans on* 1996;11(2):858–63.
- [403] Chow T, Leung C. Neural network based short-term load forecasting using weather compensation. *Power Syst, IEEE Trans on* 1996;11(4):1736–42.
- [404] Vermaak J, Botha E. Recurrent neural networks for short-term load forecasting. *Power Syst, IEEE Trans on* 1998;13(1):126–32.
- [405] Hobbs BF, et al. Artificial neural networks for short-term energy forecasting: accuracy and economic value. *Neurocomputing* 1998;23(1):71–84.
- [406] Khotanzad A, Afkhami-Rohani R, Maratukulam D. ANNSTLF-artificial neural network short-term load forecaster generation three. *Power Syst, IEEE Trans on* 1998;13(4):1413–22.
- [407] Gao R, Tsoukalas LH. Neural-wavelet methodology for load forecasting. *J Intell Robot Syst* 2001;31(1–3):149–57.
- [408] Gareta R, Romeo LM, Gil A. Forecasting of electricity prices with neural networks. *Energy Convers Manag* 2006;47(13–14):1770–8.
- [409] Kandil N, et al. An efficient approach for short term load forecasting using artificial neural networks. *Int J Electr Power Energy Syst* 2006;28(8):525–30.
- [410] Santos P, Martins A, Pires A. Designing the input vector to ANN-based models for short-term load forecast in electricity distribution systems. *Int J Electr Power Energy Syst* 2007;29(4):338–47.
- [411] Al-Shareef A, Mohamed E, Al-Judaibi E. One hour ahead load forecasting using artificial neural network for the western area of Saudi Arabia. *Int J Electr Syst Sci Eng* 2008;1(1):35–40.
- [412] Vahidinassab V, Jadid S, Kazemi A. Day-ahead price forecasting in restructured power systems using artificial neural networks. *Electr Power Syst Res* 2008;78(8):1332–42.
- [413] Catalão JPS, et al. Short-term electricity prices forecasting in a competitive market: a neural network approach. *Electr Power Syst Res* 2007;77(10):1297–304.
- [414] Pao H-T. Forecasting electricity market pricing using artificial neural networks. *Energy Convers Manag* 2007;48(3):907–12.
- [415] Xiao Z, et al. BP neural network with rough set for short term load forecasting. *Expert Syst Appl* 2009;36(1):273–9.
- [416] Kurban M, Filik UB. Next day load forecasting using artificial neural network models with autoregression and weighted frequency bin blocks. *Int J Innov Comput, Inf Control* 2009;5(4):889–98.
- [417] Siwek K, Osowski S, Szupiluk R. Ensemble neural network approach for accurate load forecasting in a power system. *Int J Appl Math Comput Sci* 2009;19(2):303–15.
- [418] Islam SM, Al-Alawi SM, Ellithy KA. Forecasting monthly electric load and energy for a fast growing utility using an artificial neural network. *Electr Power Syst Res* 1995;34(1):1–9.
- [419] González-Romera E, Jaramillo-Morán MÁ, Carmona-Fernández D. Forecasting of the electric energy demand trend and monthly fluctuation with neural networks. *Comput Ind Eng* 2007;52(3):336–43.
- [420] Al-Shehri A. Artificial neural network for forecasting residential electrical energy. *Int J Energy Res* 1999;23(8):649–61.
- [421] Ghiassi M, Zimbra DK, Saidane H. Medium term system load forecasting with a dynamic artificial neural network model. *Electr Power Syst Res* 2006;76(5):302–16.
- [422] Xia C, Wang J, McMenemy K. Short, medium and long term load forecasting model and virtual load forecaster based on radial basis function neural networks. *Int J Electr Power Energy Syst* 2010;32(7):743–50.
- [423] Chaturvedi D, Premdayal SA, Chandiok A. Short-term load forecasting using soft computing techniques. *Int'l J Commun, Netw Syst Sci* 2010;3(03):273.
- [424] Benaouda D, et al. Wavelet-based nonlinear multiscale decomposition model for electricity load forecasting. *Neurocomputing* 2006;70(1–3):139–54.
- [425] Beccali M, et al. Forecasting daily urban electric load profiles using artificial neural networks. *Energy Convers Manag* 2004;45(18–19):2879–900.
- [426] Amjadi N, Keynia F. Mid-term load forecasting of power systems by a new prediction method. *Energy Convers Manag* 2008;49(10):2678–87.
- [427] Sözen A, et al. Solar-energy potential in Turkey. *Appl Energy* 2005;80(4):367–81.
- [428] Kavaklioglu K, et al. Modeling and prediction of Turkey's electricity consumption using Artificial Neural Networks. *Energy Convers Manag* 2009;50(11):2719–27.
- [429] Dorvlo ASS, Jervase JA, Al-Lawati A. Solar radiation estimation using artificial neural networks. *Appl Energy* 2002;71(4):307–19.
- [430] Nizami SJ, Al-Garni AZ. Forecasting electric energy consumption using neural networks. *Energy Policy* 1995;23(12):1097–104.
- [431] González PA, Zamarreño JM. Prediction of hourly energy consumption in buildings based on a feedback artificial neural network. *Energy Build* 2005;37(6):595–601.
- [432] Mohandes MA, Rehman S, Halawani TO. A neural networks approach for wind speed prediction. *Renew Energy* 1998;13(3):345–54.
- [433] Ringwood JV, Bofelli D, Murray FT. Forecasting electricity demand on short, medium and long time scales using neural networks. *J Intell Robot Syst* 2001;31(1–3):129–47.
- [434] Esen H, et al. Forecasting of a ground-coupled heat pump performance using neural networks with statistical data weighting pre-processing. *Int J Therm Sci* 2008;47(4):431–41.
- [435] Sideratos G, Hatzigiorgiou ND. An advanced statistical method for wind power forecasting. *Power Syst, IEEE Trans on* 2007;22(1):258–65.
- [436] Marquez R, Pedro HTC, Coimbra CFM. Hybrid solar forecasting method uses satellite imaging and ground telemetry as inputs to ANNs. *Sol Energy* 2013;92:176–88.

- [437] Fonte P, Silva GX, Quadrado J. Wind speed prediction using artificial neural networks. *WSEAS Trans Syst* 2005;4(4):379–84.
- [438] Lee J, et al., Wind speed modeling based on artificial neural networks for Jeju area. vol. 2012. 5, pp. 81–88.
- [439] İzgi E, et al. Short-term solar power prediction by using artificial neural networks. *Sol Energy* 2012;86(2):725–33.
- [440] Szkuta B, Sanabria L, Dillon T. Electricity price short-term forecasting using artificial neural networks. *Power Syst, IEEE Trans on* 1999;14(3):851–7.
- [441] Cadenas E, Rivera W. Short term wind speed forecasting in La Venta, Oaxaca, México, using artificial neural networks. *Renew Energy* 2009;34(1):274–8.
- [442] Wang J-m, Liang X-h. The forecast of energy demand on artificial neural network [in Artificial Intelligence and Computational Intelligence, 2009. AICI'09. International Conference on]. IEEE; 2009.
- [443] Kermanshahi B, Iwamiya H. Up to year 2020 load forecasting using neural nets. *Int J Electr Power Energy Syst* 2002;24(9):789–97.
- [444] Swarup KS, Satish B. Integrated ANN approach to forecast load. *Comput Appl Power, IEEE* 2002;15(2):46–51.
- [445] Asgharizadeh E, Taghizadeh M. A Hierarchical artificial neural network for gasoline demand forecast of Iran. *Int J* 2012;19(1):1–13.
- [446] Hamzaeebi C. Improving artificial neural networks' performance in seasonal time series forecasting. *Inf Sci* 2008;178(23):4550–9.
- [447] Kiartzis SJ, Bakirtzis AG, Petridis V. Short-term load forecasting using neural networks. *Electr Power Syst Res* 1995;33(1):1–6.
- [448] Sözen A, et al. Forecasting based on neural network approach of solar potential in Turkey. *Renew Energy* 2005;30(7):1075–90.
- [449] Sözen A, et al. Use of artificial neural networks for mapping of solar potential in Turkey. *Appl Energy* 2004;77(3):273–86.
- [450] Saini LM. Peak load forecasting using Bayesian regularization, Resilient and adaptive backpropagation learning based artificial neural networks. *Electr Power Syst Res* 2008;78(7):1302–10.
- [451] Lauret P, et al. Bayesian neural network approach to short time load forecasting. *Energy Convers Manag* 2008;49(5):1156–66.
- [452] Assareh E, et al. Global electricity consumption estimation using particle swarm Optimization (PSO). *World Acad Sci, Eng Technol* 2011;79.
- [453] Yu S, Wei Y-M, Wang K. China's primary energy demands in 2020: predictions from an MPPO-RBF estimation model. *Energy Convers Manag* 2012;61:59–66.
- [454] Pai P-F. Hybrid ellipsoidal fuzzy systems in forecasting regional electricity loads. *Energy Convers Manag* 2006;47(15):2283–9.
- [455] Dolara A, et al. A physical hybrid artificial neural network for short term forecasting of PV plant power output. *Energies* 2015;8(2):1138–53.
- [456] Mellit A, Massi Pavan A, Lughi V. Short-term forecasting of power production in a large-scale photovoltaic plant. *Sol Energy* 2014;105:401–13.
- [457] Kashyap Y, Bansal A, Sao AK. Solar radiation forecasting with multiple parameters neural networks. *Renew Sustain Energy Rev* 2015;49:825–35.
- [458] Laouafi A, et al. Daily peak electricity demand forecasting based on an adaptive hybrid two-stage methodology. *Int J Electr Power Energy Syst* 2016;77:136–44.
- [459] Ortiz M, et al. Price forecasting and validation in the Spanish electricity market using forecasts as input data. *Int J Electr Power Energy Syst* 2016;77:123–7.
- [460] Sandhu HS, Fang L, Guan L. Forecasting day-ahead price spikes for the Ontario electricity market. *Electr Power Syst Res* 2016;141:450–9.
- [461] Osório GJ, Matias JCO, Catalão JPS. Short-term wind power forecasting using adaptive neuro-fuzzy inference system combined with evolutionary particle swarm optimization, wavelet transform and mutual information. *Renew Energy* 2015;75:301–7.
- [462] Singh N, Mohanty SR, Shukla R. Dev. Short term electricity price forecast based on environmentally adapted generalized neuron. *Energy* 2017;125:127–39.
- [463] Kouhi S, Keynia F. A new cascade NN based method to short-term load forecast in deregulated electricity market. *Energy Convers Manag* 2013;71:76–83.
- [464] Kouhi S, Keynia F, Ravadanegh S Najafi. A new short-term load forecast method based on neuro-evolutionary algorithm and chaotic feature selection. *Int J Electr Power Energy Syst* 2014;62:862–7.
- [465] Chaturvedi DK, Sinha AP, Malik OP. Short term load forecast using fuzzy logic and wavelet transform integrated generalized neural network. *Int J Electr Power Energy Syst* 2015;67:230–7.
- [466] Ghofrani M, et al. A hybrid short-term load forecasting with a new input selection framework. *Energy* 2015;81:777–86.
- [467] Rana M, Koprinska I. Forecasting electricity load with advanced wavelet neural networks. *Neurocomputing* 2016;182:118–32.
- [468] Khwaja AS, et al. Improved short-term load forecasting using bagged neural networks. *Electr Power Syst Res* 2015;125:109–15.
- [469] Li S, Wang P, Goel L. Short-term load forecasting by wavelet transform and evolutionary extreme learning machine. *Electr Power Syst Res* 2015;122:96–103.
- [470] Li S, Goel L, Wang P. An ensemble approach for short-term load forecasting by extreme learning machine. *Appl Energy* 2016;170:22–9.
- [471] Liu N, et al. A hybrid forecasting model with parameter optimization for short-term load forecasting of micro-grids. *Appl Energy* 2014;129:336–45.
- [472] Hernández L, et al. Artificial neural networks for short-term load forecasting in microgrids environment. *Energy* 2014;75:252–64.
- [473] Sharma V, et al. Short term solar irradiance forecasting using a mixed wavelet neural network. *Renew Energy* 2016;90:481–92.
- [474] Kim MK. Short-term price forecasting of Nordic power market by combination Levenberg–Marquardt and Cuckoo search algorithms. *IET Gener, Transm Distrib* 2015;9(13):1553–63.
- [475] Chae YT, et al. Artificial neural network model for forecasting sub-hourly electricity usage in commercial buildings. *Energy Build* 2016;111:184–94.
- [476] Szoplik J. Forecasting of natural gas consumption with artificial neural networks. *Energy* 2015;85:208–20.
- [477] Panapakidis IP, Dagoumas AS. Day-ahead natural gas demand forecasting based on the combination of wavelet transform and ANFIS/genetic algorithm/neural network model. *Energy* 2017;118:231–45.
- [478] Zjavka L. Short-term power demand forecasting using the differential polynomial neural network. *Int J Comput Intell Syst* 2015;8(2):297–306.
- [479] Pao H-T, Fu H-C, Tseng C-L. Forecasting of CO₂ emissions, energy consumption and economic growth in China using an improved grey model. *Energy* 2012;40(1):400–9.
- [480] Lin C-S, Liou F-M, Huang C-P. Grey forecasting model for CO₂ emissions: a Taiwan study. *Appl Energy* 2011;88(11):3816–20.
- [481] Lu LJ, Lewis C, Lin SJ. The forecast of motor vehicle, energy demand and CO₂ emission from Taiwan's road transportation sector. *Energy Policy* 2009;37(8):2952–61.
- [482] Ma H, Wu Y. Grey predictive on natural gas consumption and production in China [in Web Mining and Web-based Application, 2009. WMAWA'09. Second Pacific-Asia Conference on]. IEEE; 2009.
- [483] Kumar U, Jain VK. Time series models (Grey-Markov, Grey Model with rolling mechanism and singular spectrum analysis) to forecast energy consumption in India. *Energy* 2010;35(4):1709–16.
- [484] Lee S-C, Shih L-H. Forecasting of electricity costs based on an enhanced gray-based learning model: a case study of renewable energy in Taiwan. *Technol Forecast Social Change* 2011;78(7):1242–53.
- [485] Yao AWL, Chi SC, Chen JH. An improved Grey-based approach for electricity demand forecasting. *Electr Power Syst Res* 2003;67(3):217–24.
- [486] Wang X. Grey prediction with rolling mechanism for electricity demand forecasting of Shanghai [in Grey Systems and Intelligent Services, 2007. GSIS 2007. IEEE International Conference on]. IEEE; 2007.
- [487] Yao AWL, Chi SC. Analysis and design of a Taguchi–Grey based electricity demand predictor for energy management systems. *Energy Convers Manag* 2004;45(7–8):1205–17.
- [488] Bianco V, et al. Analysis and forecasting of nonresidential electricity consumption in Romania. *Appl Energy* 2010;87(11):3584–90.
- [489] Mu H, et al. Grey relative analysis and future prediction on rural household bio-fuels consumption in China. *Fuel Process Technol* 2004;85(8–10):1231–48.
- [490] Pi D, Liu J, Qin X. A grey prediction approach to forecasting energy demand in China. *Energy Sources, Part A: Recovery, Util, Environ Eff* 2010;32(16):1517–28.
- [491] Hamzaeebi C, Es HA. Forecasting the annual electricity consumption of Turkey using an optimized grey model. *Energy* 2014;70:165–71.
- [492] Wang Q. Grey prediction model and multivariate statistical techniques forecasting electrical energy consumption in Wenzhou, China [in Intelligent Information Technology and Security Informatics, 2009. IITSI'09. Second International Symposium on]. IEEE; 2009.
- [493] Bahrami S, Hooshmand R-A, Parastegari M. Short term electric load forecasting by wavelet transform and grey model improved by PSO (particle swarm optimization) algorithm. *Energy* 2014;72:434–42.
- [494] Tsai S-B, et al. Models for forecasting growth trends in renewable energy. *Renew Sustain Energy Rev* 2017;77:1169–78.
- [495] Wu L, et al. Modelling and forecasting CO₂ emissions in the BRICS (Brazil, Russia, India, China, and South Africa) countries using a novel multi-variable grey model. *Energy* 2015;79:489–95.
- [496] Kucukali S, Baris K. Turkey's short-term gross annual electricity demand forecast by fuzzy logic approach. *Energy Policy* 2010;38(5):2438–45.
- [497] Kiartzis S, et al. A fuzzy expert system for peak load forecasting. Application to the Greek power system [in Electrotechnical Conference, 2000. MELECON 2000. 10th Mediterranean]. IEEE; 2000.
- [498] Miranda V, Monteiro C. Fuzzy inference in spatial load forecasting [in Power Engineering Society Winter Meeting, 2000. IEEE]. IEEE; 2000.
- [499] Mamlouk R, Badran O, Abdulhadi E. A fuzzy inference model for short-term load forecasting. *Energy Policy* 2009;37(4):1239–48.
- [500] Ahmadi S, Bevrani H, Jannaty H. A fuzzy inference model for short-term load forecasting [in Renewable Energy and Distributed Generation (ICREDG), 2012 Second Iranian Conference on]. IEEE; 2012.
- [501] Jain A, Srinivas E, Rauta R. Short term load forecasting using fuzzy adaptive inference and similarity [in Nature & Biologically Inspired Computing, 2009. NaBIC 2009. World Congress on]. IEEE; 2009.
- [502] Lau HCW, et al. A fuzzy logic approach to forecast energy consumption change in a manufacturing system. *Expert Syst Appl* 2008;34(3):1813–24.
- [503] Al-Ghandoor A, et al. Projection of future transport energy demand of Jordan using adaptive neuro-fuzzy technique. *Energy* 2012;38(1):128–35.
- [504] Mori H, Nakano K. An efficient hybrid intelligent method for electricity price forecasting. *Procedia Comput Sci* 2016;95:287–96.
- [505] Da Silva EL, Gil HA, Areiza JM. Transmission network expansion planning under an improved genetic algorithm. *Power Syst, IEEE Trans on* 2000;15(3):1168–74.
- [506] Sirikum J, Techanisawad A. Power generation expansion planning with emission control: a nonlinear model and a GA-based heuristic approach. *Int J Energy Res* 2006;30(2):81–99.
- [507] Ceylan H, Öztürk HK. Estimating energy demand of Turkey based on economic indicators using genetic algorithm approach. *Energy Convers Manag* 2004;45(15):2525–37.
- [508] Öztürk HK, et al. Electricity estimation using genetic algorithm approach: a case study of Turkey. *Energy* 2005;30(7):1003–12.
- [509] Haldenbilen S, Ceylan H. Genetic algorithm approach to estimate transport energy demand in Turkey. *Energy Policy* 2005;33(1):89–98.
- [510] Canyurt OE, Öztürk HK. Three different applications of genetic algorithm (GA) search techniques on oil demand estimation. *Energy Convers Manag*

- 2006;47(18–19):3138–48.
- [511] Ozturk HK, et al. Estimating petroleum exergy production and consumption using vehicle ownership and GDP based on genetic algorithm approach. *Renew Sustain Energy Rev* 2004;8(3):289–302.
 - [512] Ozturk HK, Ceylan H. Forecasting total and industrial sector electricity demand based on genetic algorithm approach: turkey case study. *Int J Energy Res* 2005;29(9):829–40.
 - [513] Kavoori H, et al. Forecast Global carbon dioxide emission By use of genetic algorithm (GA). *Int J Comput Sci Issues(IJCSI)* 2012;9(5).
 - [514] Aghaei J, et al. Scenario-based dynamic economic emission dispatch considering load and wind power uncertainties. *Int J Electr Power Energy Syst* 2013;47(0):351–67.
 - [515] Nazari H, et al. The application of particle swarm optimization algorithm in forecasting energy demand of residential-commercial sector with the use of economic indicators. *Manag Sci Lett* 2014;4(11):2415–22.
 - [516] Hu Z, et al. Mid-term interval load forecasting using multi-output support vector regression with a memetic algorithm for feature selection. *Energy* 2015;84:419–31.
 - [517] Nomiya F, et al. A study on global solar radiation forecasting using weather forecast data [in 2011 IEEE 54th International Midwest Symposium on Circuits and Systems (MWSCAS)]. *IEEE*; 2011.